

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας		Τετάρτη, 26 Νοεμβρίου 2025							
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 26 Νοεμβρίου 2025	00:00	0,774	1								
	01:00	0,746	1								
	02:00	0,702	1								
	03:00	0,684	1								
	04:00	0,676	1								
	05:00	0,707	1								
	06:00	0,781	1								
	07:00	0,799	1								
	08:00	0,775	1								
	09:00	0,744	1								
	10:00	0,790	1								
	11:00	0,827	1								
	12:00	0,890	1								
	13:00	0,907	1								
	14:00	0,947	1								1
	15:00	0,959	1								1
	16:00	1,006	1								1
	17:00	1,159	1								1
	18:00	1,207	1								1
	19:00	1,144	1								1
	20:00	1,086	1								1
	21:00	1,009	1								1
	22:00	0,902	1								1
	23:00	0,820	1								1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Πέμπτη, 27 Νοεμβρίου 2025							
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 27 Νοεμβρίου 2025	00:00	0,743	1								
	01:00	0,707	1								
	02:00	0,679	1								
	03:00	0,686	1								
	04:00	0,694	1								
	05:00	0,695	1								
	06:00	0,776	1								
	07:00	0,758	1								
	08:00	0,730	1								
	09:00	0,704	1								
	10:00	0,703	1								
	11:00	0,739	1								
	12:00	0,750	1								
	13:00	0,777	1								
	14:00	0,771	1								
	15:00	0,821	1								
	16:00	0,898	1								
	17:00	1,073	1								1
	18:00	1,129	1								1
	19:00	1,084	1								1
	20:00	1,053	1								1
	21:00	0,966	1								1
	22:00	0,908	1								1
	23:00	0,849	1								1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Παρασκευή, 28 Νοεμβρίου 2025							
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α ρ α χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 28 Νοεμβρίου 2025	00:00	0,759	1								
	01:00	0,712	1								
	02:00	0,679	1								
	03:00	0,671	1								
	04:00	0,661	1								
	05:00	0,675	1								
	06:00	0,749	1								
	07:00	0,744	1								
	08:00	0,741	1								
	09:00	0,791	1								
	10:00	0,788	1								
	11:00	0,916	1								1
	12:00	1,002	1								1
	13:00	1,002	1								1
	14:00	0,939	1								1
	15:00	0,921	1								1
	16:00	0,948	1								1
	17:00	1,127	1								1
	18:00	1,163	1								1
	19:00	1,120	1								1
	20:00	1,101	1								1
	21:00	1,062	1								1
	22:00	0,973	1								1
	23:00	0,877	1								1



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας		Σάββατο, 29 Νοεμβρίου 2025							
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 29 Νοεμβρίου 2025	00:00	0,767	1								
	01:00	0,700	1								
	02:00	0,664	1								
	03:00	0,661	1								
	04:00	0,678	1								
	05:00	0,681	1								
	06:00	0,758	1								
	07:00	0,741	1								
	08:00	0,729	1								
	09:00	0,713	1								
	10:00	0,708	1								
	11:00	0,732	1								
	12:00	0,805	1								
	13:00	0,793	1								
	14:00	0,829	1								
	15:00	0,900	1								
	16:00	0,975	1								1
	17:00	1,155	1								1
	18:00	1,271	1								1
	19:00	1,213	1								1
	20:00	1,138	1								1
	21:00	1,088	1								1
	22:00	1,013	1								1
	23:00	0,931	1								1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Κυριακή, 30 Νοεμβρίου 2025							
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α Ρ Ε Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 30 Νοεμβρίου 2025	00:00	0,779	1								
	01:00	0,712	1								
	02:00	0,673	1								
	03:00	0,677	1								
	04:00	0,675	1								
	05:00	0,687	1								
	06:00	0,759	1								
	07:00	0,751	1								
	08:00	0,724	1								
	09:00	0,709	1								
	10:00	0,733	1								
	11:00	0,745	1								
	12:00	0,758	1								
	13:00	0,735	1								
	14:00	0,761	1								
	15:00	0,824	1								
	16:00	0,942	1								1
	17:00	1,041	1								1
	18:00	1,105	1								1
	19:00	1,112	1								1
	20:00	1,101	1								1
	21:00	1,027	1								1
	22:00	0,935	1								1
	23:00	0,864	1								1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Δευτέρα, 1 Δεκεμβρίου 2025							
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
α ρ α ξ ι α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 1 Δεκεμβρίου 2025	00:00	0,772									1
	01:00	0,714									1
	02:00	0,684									1
	03:00	0,683									1
	04:00	0,697									1
	05:00	0,698									1
	06:00	0,799									1
	07:00	0,779									1
	08:00	0,737									1
	09:00	0,663	1								
	10:00	0,641	1								
	11:00	0,701	1								
	12:00	0,716	1								
	13:00	0,704	1								
	14:00	0,726	1								
	15:00	0,797	1								
	16:00	0,918	1								1
	17:00	1,096	1								1
	18:00	1,164	1								1
	19:00	1,252	1								1
	20:00	1,241	1								1
	21:00	1,112	1								1
	22:00	1,018	1								1
	23:00	0,918	1								1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Τρίτη, 2 Δεκεμβρίου 2025							
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 2 Δεκεμβρίου 2025	00:00	0,799	1								
	01:00	0,747	1								
	02:00	0,712	1								
	03:00	0,715	1								
	04:00	0,707	1								
	05:00	0,755	1								
	06:00	0,885	1								
	07:00	0,913	1								
	08:00	0,802	1								
	09:00	0,894	1								
	10:00	0,905	1								
	11:00	0,931	1								
	12:00	0,934	1								1
	13:00	0,892	1								1
	14:00	0,926	1								1
	15:00	0,952	1								1
	16:00	1,071	1								1
	17:00	1,300	1								1
	18:00	1,434	1								1
	19:00	1,406	1								1
	20:00	1,303	1								1
	21:00	1,187	1								1
	22:00	1,061	1								1
	23:00	0,969	1								1



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης