

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Πέμπτη, 11 Δεκεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 11 Δεκεμβρίου 2025	00:00	0,866	1								
	01:00	0,811	1								
	02:00	0,776	1								
	03:00	0,760	1								
	04:00	0,763	1								
	05:00	0,786	1								
	06:00	0,835	1								
	07:00	0,879	1						1		
	08:00	0,887	1						1		
	09:00	0,897	1						1		
	10:00	0,896	1						1		
	11:00	0,901	1						1		
	12:00	0,916	1						1		
	13:00	0,927	1						1		
	14:00	0,950	1						1		
	15:00	0,999	1						1		
	16:00	1,093	1						1		
	17:00	1,229	1						1		
	18:00	1,298	1						1		
	19:00	1,329	1						1		
	20:00	1,299	1						1		
	21:00	1,214	1						1		
	22:00	1,090	1						1		
	23:00	0,953	1						1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Παρασκευή, 12 Δεκεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 12 Δεκεμβρίου 2025	00:00	0,862	1								
	01:00	0,805	1								
	02:00	0,766	1								
	03:00	0,747	1								
	04:00	0,748	1								
	05:00	0,764	1								
	06:00	0,809	1								
	07:00	0,856	1						1		
	08:00	0,881	1						1		
	09:00	0,900	1						1		
	10:00	0,934	1						1		
	11:00	0,932	1						1		
	12:00	0,922	1						1		
	13:00	0,940	1						1		
	14:00	0,965	1						1		
	15:00	0,991	1						1		
	16:00	1,074	1						1		
	17:00	1,211	1						1		
	18:00	1,297	1						1		
	19:00	1,341	1						1		
	20:00	1,325	1						1		
	21:00	1,244	1						1		
	22:00	1,117	1						1		
	23:00	0,973	1						1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Σάββατο, 13 Δεκεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 13 Δεκεμβρίου 2025	00:00	0,887	1								
	01:00	0,826	1								
	02:00	0,783	1								
	03:00	0,761	1								
	04:00	0,761	1								
	05:00	0,778	1								
	06:00	0,823	1								
	07:00	0,876	1						1		
	08:00	0,920	1						1		
	09:00	0,929	1						1		
	10:00	0,955	1						1		
	11:00	0,957	1						1		
	12:00	0,961	1						1		
	13:00	0,966	1						1		
	14:00	0,983	1						1		
	15:00	1,026	1						1		
	16:00	1,107	1						1		
	17:00	1,235	1						1		
	18:00	1,313	1						1		
	19:00	1,356	1						1		
	20:00	1,349	1						1		
	21:00	1,278	1						1		
	22:00	1,153	1						1		
	23:00	1,007	1						1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Κυριακή, 14 Δεκεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α Ρ Ο Ρ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 14 Δεκεμβρίου 2025	00:00	0,902	1								
	01:00	0,830	1								
	02:00	0,780	1								
	03:00	0,750	1								
	04:00	0,743	1								
	05:00	0,756	1								
	06:00	0,801	1								
	07:00	0,843	1								
	08:00	0,895	1						1		
	09:00	0,904	1						1		
	10:00	0,914	1						1		
	11:00	0,912	1						1		
	12:00	0,912	1						1		
	13:00	0,910	1						1		
	14:00	0,916	1						1		
	15:00	0,951	1						1		
	16:00	1,019	1						1		
	17:00	1,139	1						1		
	18:00	1,211	1						1		
	19:00	1,246	1						1		
	20:00	1,242	1						1		
	21:00	1,185	1						1		
	22:00	1,076	1						1		
	23:00	0,945	1						1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ			Προτεινόμενος ΗΕΠ			Δευτέρα, 15 Δεκεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 15 Δεκεμβρίου 2025	00:00	0,826	1								
	01:00	0,772	1								
	02:00	0,737	1								
	03:00	0,721	1								
	04:00	0,724	1								
	05:00	0,744	1								
	06:00	0,792	1								
	07:00	0,839	1								
	08:00	0,873	1						1		
	09:00	0,867	1						1		
	10:00	0,865	1						1		
	11:00	0,869	1						1		
	12:00	0,868	1						1		
	13:00	0,864	1						1		
	14:00	0,884	1						1		
	15:00	0,932	1						1		
	16:00	1,023	1						1		
	17:00	1,166	1						1		
	18:00	1,250	1						1		
	19:00	1,290	1						1		
	20:00	1,281	1						1		
	21:00	1,215	1						1		
	22:00	1,093	1						1		
	23:00	0,954	1						1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Τρίτη, 16 Δεκεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 16 Δεκεμβρίου 2025	00:00	0,812	1								
	01:00	0,762	1								
	02:00	0,733	1								
	03:00	0,724	1								
	04:00	0,734	1								
	05:00	0,760	1								
	06:00	0,813	1								
	07:00	0,864	1						1		
	08:00	0,901	1						1		
	09:00	0,901	1						1		
	10:00	0,889	1						1		
	11:00	0,890	1						1		
	12:00	0,896	1						1		
	13:00	0,898	1						1		
	14:00	0,922	1						1		
	15:00	0,971	1						1		
	16:00	1,091	1						1		
	17:00	1,202	1						1		
	18:00	1,273	1						1		
	19:00	1,311	1						1		
	20:00	1,287	1						1		
	21:00	1,211	1						1		
	22:00	1,085	1						1		
	23:00	0,939	1						1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ			Προτεινόμενος ΗΕΠ			Τετάρτη, 17 Δεκεμβρίου 2025					
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α Ρ Ο Ρ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 17 Δεκεμβρίου 2025	00:00	0,820	1								
	01:00	0,774	1								
	02:00	0,746	1								
	03:00	0,737	1								
	04:00	0,746	1								
	05:00	0,772	1								
	06:00	0,822	1								
	07:00	0,875	1							1	
	08:00	0,923	1							1	
	09:00	0,967	1							1	
	10:00	0,975	1							1	
	11:00	0,915	1							1	
	12:00	0,920	1							1	
	13:00	0,926	1							1	
	14:00	0,947	1							1	
	15:00	0,990	1							1	
	16:00	1,072	1							1	
	17:00	1,207	1							1	
	18:00	1,284	1							1	
	19:00	1,317	1							1	
	20:00	1,287	1							1	
	21:00	1,205	1							1	
	22:00	1,076	1							1	
	23:00	0,924	1							1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης