

ΗΣ ΡΟΔΟΥ						Απολογιστική Λειτουργία για την Προηγούμενη Ημέρα																Monday, January 5, 2026							
Αποδιδόμενη Ισχύς (Μw)						14.50	10.50	18.00	18.00	18.00	17.50	22.00	20.00	27.00	32.90	27.90	17.10	17.10	17.10	17.10	17.10	17.10							
ΤΕ (Μw)						6.00	4.90	14.00	14.00	14.00	5.00	5.00	5.00	5.00	5.60	6.60	6.80	6.80	6.80	6.80	6.80	6.80							
H R E E	Χρονική στιγμή	Πραγματικό Μέσο Δοτatio φορτίο (Μw)	Θερμική Παραγωγή (Μw)	Αιολική Παραγωγή (Μw)	Φωτοβολταϊκή Παραγωγή (Μw)	ΑΗΣ ΣΟΡΩΝΗΣ										ΟΗΣ Ν.ΡΟΔΟΥ							Στρεφόμενη εφεδρεία (Μw)	Εντολή περιορισμού των Αιολικών Πάρκων (Μw)	Μέγιστη δυνατότητα απορρόφησης Αιολικής Παραγωγής (Μw)	Μέση φόρτιση Μονάδων ΑΣΠ (% επί της αποδιδόμενης)	Κόστος καυσίμου (€)		
						ΑΤΗ 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	AEP 1	AEP 2	AEP 3	AEP 4	AEP 5	AEP 6	DIESEL 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	DIESEL 6						DIESEL 7	
Monday, January 5, 2026	00:00	64.27	49.72	14.55	0.00				1	1		1					1		1						42.48	16.52	17.67	54%	12,969
	01:00	57.42	45.74	11.67	0.00				1			1					1		1						28.46	16.95	17.22	62%	12,491
	02:00	53.68	42.87	10.81	0.00				1			1					1		1						31.33	16.04	16.10	58%	12,043
	03:00	51.73	37.61	14.11	0.00				1			1					1		1						36.59	15.43	15.52	51%	11,168
	04:00	50.75	39.13	11.62	0.00				1			1					1		1						35.07	15.13	15.22	53%	11,430
	05:00	51.39	38.89	12.50	0.00				1			1					1		1						35.31	15.34	15.42	52%	11,390
	06:00	56.03	44.45	11.58	0.00				1			1					1		1						29.75	16.70	16.81	60%	12,292
	07:00	62.79	46.53	15.68	0.58				1			1					1		1						27.67	18.73	18.66	63%	12,610
	08:00	69.19	50.53	17.14	1.52				1	1		1					1		1						41.67	20.19	20.30	55%	13,168
	09:00	75.55	50.05	21.98	3.53				1	1		1					1								25.05	22.49	21.61	67%	13,308
	10:00	79.07	44.64	22.08	12.35				1	1					1		1								41.36	22.04	20.02	52%	13,184
	11:00	77.55	44.80	20.25	12.50				1	1					1		1								41.20	22.09	19.52	52%	13,219
	12:00	80.28	52.67	18.42	9.19				1	1					1		1								33.33	24.19	21.33	61%	15,154
	13:00	81.92	57.03	16.88	8.01				1	1					1		1		1						46.07	24.59	22.17	55%	15,176
	14:00	80.78	58.37	15.97	6.43				1	1					1		1		1						44.73	24.28	22.30	57%	15,410
	15:00	81.84	59.92	18.26	3.66				1	1					1		1		1						43.18	24.56	23.46	58%	15,755
	16:00	85.66	66.81	17.94	0.91				1	1					1		1		1						36.29	25.63	25.43	65%	17,228
	17:00	93.46	76.92	16.53	0.00				1	1					1		1		1				1		43.28	27.97	28.04	64%	18,486
	18:00	95.67	80.62	15.05	0.00				1	1					1		1		1					1	39.58	28.68	28.70	67%	19,124
	19:00	94.40	76.11	18.29	0.00				1	1					1		1		1					1	44.09	28.22	28.32	63%	18,256
	20:00	91.77	72.51	19.27	0.00				1	1					1		1		1					1	47.69	27.51	27.53	60%	17,537
	21:00	86.49	66.01	20.48	0.00				1	1		1			1		1		1					1	76.19	25.97	25.95	46%	21,536
	22:00	78.60	57.60	21.00	0.00				1	1		1			1		1		1					1	34.60	23.64	23.58	62%	14,167
	23:00	69.79	48.40	21.40	0.00				1	1		1							1				1	43.80	20.62	20.94	52%	12,757	
		1770.09 MWh																					ΑΩΛ: 10.72		349,859 €				

Παρατηρήσεις:

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης