

ΗΣ ΡΟΔΟΥ			Απολογιστική Λειτουργία για την Προηγούμενη Ημέρα																	Tuesday, January 6, 2026								
Αποδιδόμενη Ισχύς (Mw)						14.50	10.50	18.00	18.00	18.00	17.50	22.00	20.00	27.00	32.90	27.90	17.10	17.10	17.10	17.10	17.10	17.10						
ΤΕ (Mw)						6.00	4.90	14.00	14.00	14.00	5.00	5.00	5.00	5.00	5.60	6.60	6.80	6.80	6.80	6.80	6.80	6.80						
Η Ρ Ε Ρ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (Mw)	Θερμική Παραγωγή (Mw)	Αιολική Παραγωγή (Mw)	Φωτοβολταϊκή Παραγωγή (Mw)	ΑΗΣ ΣΩΡΟΝΗΣ										ΘΗΣ Ν.ΡΟΔΟΥ							Στρεφόμενη εφεδρεία (Mw)	Εντολή περιορισμού των Αιολικών Πάρκων (Mw)	Μέγιστη δυνατότητα απορρόφησης Αιολικής Παραγωγής (Mw)	Μέση φόρτιση Μονάδων ΑΣΠ (% επί της αποδιδόμενης)	Κόστος καυσίμου (€)	
						ATM 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	AEP 1	AEP 2	AEP 3	AEP 4	AEP 5	AEP 6	DIESEL 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	DIESEL 6						DIESEL 7
Tuesday, January 6, 2026	00:00	61.02	42.80	18.22	0.00				1				1						1				1	31.40	18.11	18.31	58%	12,033
	01:00	54.57	38.55	16.02	0.00				1				1						1				1	35.65	16.35	16.37	52%	11,331
	02:00	52.26	36.65	15.61	0.00				1				1						1				1	37.55	15.63	15.68	49%	10,998
	03:00	50.19	35.14	15.05	0.00				1				1						1				1	39.06	14.91	15.06	47%	10,724
	04:00	49.17	34.82	14.35	0.00				1				1						1				1	39.38	14.70	14.75	47%	10,664
	05:00	48.25	34.33	13.92	0.00				1				1						1				1	39.87	14.29	14.47	46%	10,573
	06:00	50.81	36.09	14.72	0.00				1				1						1				1	38.11	15.17	15.24	49%	10,898
	07:00	54.11	38.67	15.37	0.08				1				1						1				1	35.53	16.15	16.21	52%	11,351
	08:00	59.18	41.20	17.18	0.79				1				1						1				1	33.00	17.64	17.52	56%	11,775
	09:00	63.90	42.99	18.48	2.42				1				1						1				1	31.21	19.07	18.44	58%	12,063
	10:00	66.83	42.52	19.14	5.18				1				1						1				1	31.68	19.98	18.50	57%	11,987
	11:00	70.13	42.95	20.30	6.87				1				1						1				1	31.25	21.12	18.98	58%	12,056
	12:00	75.69	48.23	22.13	5.33				1				1						1				1	25.97	22.81	21.11	65%	12,865
	13:00	75.91	48.25	22.18	5.47				1				1						1				1	25.95	22.82	21.13	65%	12,868
	14:00	72.40	46.57	21.38	4.45				1				1						1				1	27.63	21.74	20.39	63%	12,616
	15:00	69.38	46.63	20.67	2.09				1				1						1				1	27.57	20.79	20.19	63%	12,625
	16:00	71.56	50.02	20.93	0.61				1				1						1				1	24.18	21.39	21.29	67%	13,129
	17:00	78.99	56.49	22.50	0.00				1				1			1			1				1	50.61	23.65	23.70	53%	20,940
	18:00	83.29	59.61	23.68	0.00				1				1			1			1				1	47.49	24.95	24.99	56%	21,733
	19:00	82.87	58.69	24.18	0.00				1				1			1			1				1	48.41	24.83	24.86	55%	21,499
	20:00	81.82	57.62	24.20	0.00				1				1			1			1				1	49.48	24.54	24.55	54%	21,224
	21:00	77.29	54.04	23.24	0.00				1				1			1			1				1	53.06	23.13	23.19	50%	20,284
	22:00	70.98	49.42	21.56	0.00				1				1			1			1				1	24.78	21.09	21.29	67%	13,041
	23:00	63.07	48.70	14.37	0.00				1				1			1			1				1	25.50	13.99	18.92	66%	12,935
		1583.67 MWh																								ΑΔΑ: 9.60		332,212 €

Παρατηρήσεις:

Δεν προτείνεται οποιαδήποτε αλλαγή στην απολογιστική λειτουργία.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης