

ΗΣ ΡΟΔΟΥ						Απολογιστική Λειτουργία για την Προηγούμενη Ημέρα															Thursday, January 15, 2026							
Αποδιδόμενη Ισχύς (Μw)						14.50	10.50	18.00	18.00	18.00	17.50	22.00	20.00	27.00	32.90	27.90	17.10	17.10	17.10	17.10	17.10	17.10						
ΤΕ (Μw)						6.00	4.90	14.00	14.00	14.00	5.00	5.00	5.00	5.00	5.60	6.60	6.80	6.80	6.80	6.80	6.80	6.80						
H Ρ Ε Σ Η						ΑΗΣ ΣΟΡΩΝΗΣ											ΟΗΣ Ν. ΡΟΔΟΥ							Στρεφόμενη εφεδρεία (Μw)	Εντολή περιορισμού των Αιολικών Πάρκων (Μw)	Μέγιστη δυνατότητα απορρόφησης Αιολικής Παραγωγής (Μw)	Μέση φόρτιση Μονάδων ΑΠΗ (% επί της αποδιδόμενης)	Κόστος καυσίμου (€)
	ΑΤΗ 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	AEP 1	AEP 2	AEP 3	AEP 4	AEP 5	AEP 6	DIESEL 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	DIESEL 6	DIESEL 7										
Thursday, January 15, 2026	00:00	67.41	63.12	4.29	0.00			1		1		1							1	1			1	46.18	12.75	14.01	58%	14,752
	01:00	59.96	55.95	4.01	0.00			1		1		1							1	1			1	53.35	8.27	6.56	51%	13,664
	02:00	57.26	51.98	5.29	0.00			1		1		1							1				1	23.12	13.18	17.18	69%	13,590
	03:00	55.32	49.65	5.66	0.00			1		1		1							1				1	25.45	13.05	15.52	66%	13,249
	04:00	54.81	46.93	7.88	0.00			1		1		1							1				1	28.17	12.75	15.01	62%	12,840
	05:00	56.28	49.48	6.80	0.00			1		1		1							1				1	25.62	14.24	16.48	66%	13,223
	06:00	61.92	56.63	5.29	0.00			1		1		1							1				1	52.67	13.67	8.52	52%	13,911
	07:00	74.90	67.34	6.94	0.62					1		1							1	1			1	23.96	22.28	22.28	74%	15,369
	08:00	77.94	65.80	6.05	6.08					1		1							1	1			1	25.50	23.35	21.56	72%	15,154
	09:00	78.92	59.49	6.21	13.22					1		1							1	1			1	64.71	20.06	19.71	48%	20,575
	10:00	77.28	55.32	4.62	17.34					1		1							1	1			1	68.88	14.03	14.94	45%	19,479
	11:00	75.67	52.48	3.90	19.29					1		1							1	1			1	38.82	17.54	16.92	57%	13,238
	12:00	77.22	55.71	2.31	19.20					1		1							1	1			1	35.59	4.23	17.41	61%	13,718
	13:00	75.67	55.11	3.84	16.72					1		1							1	1			1	36.19	16.10	17.68	60%	13,629
	14:00	76.49	60.29	4.02	12.18					1		1							1	1			1	31.01	22.45	19.29	66%	14,379
	15:00	76.43	64.00	4.24	8.19			1		1		1							1	1			1	45.30	14.01	14.84	59%	14,951
	16:00	80.55	73.94	4.53	2.08			1		1		1							1	1			1	35.36	22.23	23.54	68%	16,282
	17:00	91.29	87.88	3.38	0.03			1		1		1							1	1			1	54.32	27.28	27.38	62%	26,212
	18:00	97.95	94.09	3.86	0.00			1		1		1							1	1			1	48.11	29.29	29.38	66%	27,443
	19:00	100.03	96.79	3.24	0.00			1		1		1							1	1			1	45.41	29.96	30.01	68%	27,962
	20:00	99.80	97.28	2.53	0.00			1		1		1							1	1			1	44.92	29.95	29.94	68%	28,055
	21:00	95.02	93.55	1.46	0.00			1		1		1							1	1			1	48.65	28.54	28.51	66%	27,339
	22:00	85.74	84.68	1.06	0.00			1		1		1							1	1			1	57.52	25.68	25.72	60%	25,542
	23:00	74.00	73.23	0.77	0.00			1		1		1							1	1			1	36.07	19.30	20.60	67%	16,185
		1827.87 MWh																						ΑΩΛ: 9.30				430,742 €

Παρατηρήσεις:

Περικοπή Α/Π απο 11:50 έως 13:14 λόγω σβησίματος SCADA ΚΚΦ.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης