

ΗΣ ΡΟΔΟΥ						Απολογιστική Λειτουργία για την Προηγούμενη Ημέρα																Saturday, January 17, 2026							
Αποδιδόμενη Ισχύς (Μw)						14.50	10.50	18.00	18.00	18.00	17.50	22.00	20.00	27.00	32.90	27.90	17.10	17.10	17.10	17.10	17.10	17.10							
ΤΕ (Μw)						6.00	4.90	14.00	14.00	14.00	5.00	5.00	5.00	5.00	5.60	6.60	6.80	6.80	6.80	6.80	6.80	6.80							
H O U R	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (Μw)	Θερμική Παραγωγή (Μw)	Αιολική Παραγωγή (Μw)	Φωτοβολταϊκή Παραγωγή (Μw)	ΑΗΣ ΣΟΡΩΝΗΣ										ΟΗΣ Ν.ΡΟΔΟΥ							Στρεφόμενη εφεδρεία (Μw)	Εντολή περιορισμού των Αιολικών Πάρκων (Μw)	Μέγιστη δυνατότητα απορρόφησης Αιολικής Παραγωγής (Μw)	Μέση φόρτιση Μονάδων ΑΣΠ (% επί της αποδιδόμενης)	Κόστος καυσίμου (€)		
						ΑΤΗ 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	AEP 1	AEP 2	AEP 3	AEP 4	AEP 5	AEP 6	DIESEL 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	DIESEL 6						DIESEL 7	
Saturday, January 17, 2026	00:00	63.61	61.18	2.43	0.00						1			1					1	1	1			1	47.22	17.74	17.41	56%	14,300
	01:00	57.72	55.78	1.94	0.00						1			1					1	1				1	35.52	16.58	17.32	61%	13,728
	02:00	55.29	53.79	1.50	0.00						1			1					1	1				1	37.51	14.32	15.89	59%	13,434
	03:00	53.22	51.26	1.96	0.00						1			1					1	1				1	40.04	12.18	13.82	56%	13,051
	04:00	52.58	51.28	1.30	0.00						1			1					1	1				1	40.02	11.55	13.18	56%	13,054
	05:00	53.09	50.29	2.80	0.00						1			1					1	1				1	41.01	11.98	13.69	55%	12,901
	06:00	57.47	50.38	7.09	0.00						1			1					1	1				1	40.92	16.06	17.24	55%	12,914
	07:00	63.70	51.14	12.38	0.18						1			1					1	1				1	40.16	18.98	19.06	56%	13,032
	08:00	70.88	56.51	12.62	1.75						1			1					1	1				1	34.79	21.19	20.74	62%	13,835
	09:00	76.45	65.25	5.72	5.48						1			1					1	1				1	26.05	22.83	21.29	71%	15,076
	10:00	76.95	61.57	4.08	11.30						1			1					1	1				1	29.73	23.08	19.69	67%	14,559
	11:00	75.53	55.61	3.30	16.62						1			1					1	1				1	35.69	18.04	17.67	61%	13,703
	12:00	75.94	53.36	3.00	19.58						1			1					1	1				1	37.94	15.61	16.91	58%	13,370
	13:00	74.48	50.35	5.46	18.67						1			1					1	1				1	40.95	14.82	16.41	55%	12,911
	14:00	72.67	48.42	9.55	14.70						1			1					1	1				1	42.88	16.73	17.39	53%	12,607
	15:00	71.98	52.80	11.83	7.36						1			1					1	1				1	38.50	21.40	19.39	58%	13,285
	16:00	74.79	64.06	8.63	2.09						1			1					1	1				1	60.14	22.41	21.81	52%	21,721
	17:00	85.51	75.02	10.43	0.06						1			1					1	1				1	49.18	25.55	25.64	60%	24,258
	18:00	93.35	76.57	16.78	0.00						1			1					1	1		1		1	64.73	27.94	28.00	54%	23,728
	19:00	93.50	75.95	17.55	0.00						1			1					1	1		1		1	65.35	27.96	28.05	54%	23,519
	20:00	90.62	74.39	16.22	0.00						1			1					1	1		1		1	66.91	27.13	27.18	53%	23,168
	21:00	85.09	71.69	13.40	0.00						1			1					1	1		1		1	36.71	25.52	25.53	66%	15,793
	22:00	78.40	65.52	12.88	0.00						1			1					1	1		1		1	42.88	23.46	23.52	60%	14,928
	23:00	71.28	56.48	14.79	0.00						1			1						1	1			1	34.82	21.35	21.38	62%	13,831
		1724.09 MWh																						ΑΩΛ: 9.71		376,705 €			

Παρατηρήσεις:

Δεν προτείνεται οποιαδήποτε αλλαγή στην απολογιστική λειτουργία.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης