

ΗΣ ΡΟΔΟΥ						Απολογιστική Λειτουργία για την Προηγούμενη Ημέρα															Sunday, January 18, 2026							
Αποδιδόμενη Ισχύς (Μw)						14.50	10.50	18.00	18.00	18.00	17.50	22.00	20.00	27.00	32.90	27.90	17.10	17.10	17.10	17.10	17.10	17.10						
ΤΕ (Μw)						6.00	4.90	14.00	14.00	14.00	5.00	5.00	5.00	5.00	5.60	6.60	6.80	6.80	6.80	6.80	6.80	6.80						
ΕΡΕΣΗ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (Μw)	Θερμική Παραγωγή (Μw)	Αιολική Παραγωγή (Μw)	Φωτοβολταϊκή Παραγωγή (Μw)	ΑΗΣ ΣΟΡΩΝΗΣ										ΟΗΣ Ν.ΡΟΔΟΥ							Στρεφόμενη εφεδρεία (Μw)	Εντολή περιτομής των Αιολικών Πάρκων (Μw)	Μέγιστη δυνατότητα απορρόφησης Αιολικής Παραγωγής (Μw)	Μέση φόρτιση Μονάδων ΑΣΠ (% επί της αποδιδόμενης)	Κόστος καυσίμου (€)	
						ΑΤΗ 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	AEP 1	AEP 2	AEP 3	AEP 4	AEP 5	AEP 6	DIESEL 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	DIESEL 6						DIESEL 7
Sunday, January 18, 2026	00:00	63.60	50.05	13.55	0.00					1		1							1	1			1	41.25	19.04	19.08	55%	12,863
	01:00	57.54	46.77	10.77	0.00					1		1							1				1	27.43	17.27	17.26	63%	12,646
	02:00	54.96	46.83	8.14	0.00					1		1							1				1	27.37	16.42	16.49	63%	12,655
	03:00	52.58	42.38	10.20	0.00					1		1							1				1	31.82	15.70	15.77	57%	11,965
	04:00	52.16	40.36	11.81	0.00					1		1							1				1	33.84	15.57	15.65	54%	11,636
	05:00	52.19	39.79	12.41	0.00					1		1							1				1	34.41	15.57	15.66	54%	11,541
	06:00	55.20	40.62	14.58	0.00					1		1							1				1	33.58	16.45	16.56	55%	11,679
	07:00	58.15	41.77	15.76	0.62					1		1							1				1	32.43	17.31	17.26	56%	11,867
	08:00	62.93	41.52	15.08	6.32					1		1							1				1	32.68	18.79	16.98	56%	11,827
	09:00	66.60	36.70	16.04	13.86					1		1							1				1	37.50	18.84	15.82	49%	11,007
	10:00	69.46	35.37	15.57	18.52					1		1							1				1	38.83	17.16	15.28	48%	10,766
	11:00	70.61	35.23	14.46	20.92					1		1							1				1	38.97	16.00	14.91	47%	10,740
	12:00	72.37	35.27	15.53	21.57					1		1							1				1	38.93	16.95	15.24	48%	10,747
	13:00	72.43	35.79	16.19	20.45					1		1							1				1	38.41	18.25	15.59	48%	10,842
	14:00	71.22	35.44	18.48	17.30					1		1							1				1	38.76	20.09	16.18	48%	10,779
	15:00	69.89	38.59	19.90	11.39					1		1							1				1	35.61	21.28	17.55	52%	11,338
	16:00	73.18	52.84	16.80	3.54					1		1							1				1	21.36	22.03	20.89	71%	13,539
	17:00	84.71	72.41	12.23	0.07					1		1							1		1		1	18.89	28.07	25.39	79%	16,155
	18:00	94.20	83.16	11.04	0.00					1		1			1			1	1	1	1		1	58.14	32.95	28.26	59%	25,163
	19:00	96.79	87.22	9.58	0.00					1		1			1			1	1	1	1		1	54.08	33.89	29.04	62%	25,930
	20:00	96.29	89.90	6.39	0.00					1		1			1			1	1	1	1		1	51.40	32.27	28.89	64%	26,472
	21:00	91.95	86.16	5.78	0.00					1		1			1			1	1	1	1		1	55.14	27.56	27.58	61%	25,713
	22:00	84.40	78.57	5.83	0.00					1		1			1			1	1	1	1		1	62.73	25.30	25.32	56%	24,099
	23:00	74.76	70.38	4.37	0.00					1		1			1			1	1	1	1		1	38.02	22.46	22.43	65%	15,612
		1698.16 MWh																					ΑΩΛ: 10.34		357,583 €			

Παρατηρήσεις:

Δεν προτείνεται οποιαδήποτε αλλαγή στην απολογιστική λειτουργία.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης