

ΗΣ ΡΟΔΟΥ						Απολογιστική Λειτουργία για την Προηγούμενη Ημέρα																Monday, January 19, 2026						
Αποδιδόμενη Ισχύς (Μw)						14.50	10.50	18.00	18.00	18.00	17.50	22.00	20.00	27.00	32.90	27.90	17.10	17.10	17.10	17.10	17.10	17.10						
ΤΕ (Μw)						6.00	4.90	14.00	14.00	14.00	5.00	5.00	5.00	5.00	5.60	6.60	6.80	6.80	6.80	6.80	6.80	6.80						
ΕΡΕΣΗ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (Μw)	Θερμική Παραγωγή (Μw)	Αιολική Παραγωγή (Μw)	Φωτοβολταϊκή Παραγωγή (Μw)	ΑΗΣ ΣΟΡΩΝΗΣ										ΟΗΣ Ν.ΡΟΔΟΥ							Στρεφόμενη εφεδρεία (Μw)	Εντολή περτορισμού των Αιολικών Πάρκων (Μw)	Μέγιστη δυνατότητα απορρόφησης Αιολικής Παραγωγής (Μw)	Μέση φόρτιση Μονάδων ΑΣΠ (% επί της αποδιδόμενης)	Κόστος καυσίμου (€)	
						ΑΤΗ 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	AEP 1	AEP 2	AEP 3	AEP 4	AEP 5	AEP 6	DIESEL 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	DIESEL 6						DIESEL 7
Monday, January 19, 2026	00:00	64.67	61.16	3.51	0.00					1		1						1	1	1			1	47.24	19.02	18.47	56%	14,297
	01:00	57.71	54.31	3.41	0.00					1		1						1		1			1	36.99	16.65	17.31	59%	13,511
	02:00	55.86	49.80	6.06	0.00					1		1								1			1	24.40	16.55	16.76	67%	13,097
	03:00	53.94	48.34	5.60	0.00					1		1								1			1	25.86	16.14	16.18	65%	12,881
	04:00	53.54	46.71	6.82	0.00					1		1								1			1	27.49	15.95	16.06	63%	12,637
	05:00	54.92	48.29	6.62	0.00					1		1								1			1	25.91	16.40	16.47	65%	12,874
	06:00	63.08	58.49	4.59	0.00					1		1						1		1			1	32.81	18.88	18.92	64%	14,192
	07:00	75.24	71.09	3.38	0.77					1		1					1	1		1			1	37.31	22.07	22.34	66%	15,781
	08:00	79.67	70.51	2.10	7.05					1		1			1		1	1		1			1	70.79	18.91	20.82	50%	22,282
	09:00	82.41	67.19	1.36	13.86					1		1			1		1	1		1			1	57.01	21.37	20.56	54%	22,468
	10:00	82.90	66.44	0.42	16.05					1		1			1		1	1		1			1	57.76	20.32	20.06	53%	22,289
	11:00	82.11	68.79	0.12	13.21					1		1			1		1	1		1			1	55.41	22.48	20.67	55%	22,845
	12:00	85.31	71.48	0.15	13.68					1		1			1		1	1		1			1	52.72	24.74	21.49	58%	23,465
	13:00	85.07	70.48	0.11	14.48					1		1			1		1	1		1			1	53.72	24.03	21.18	57%	23,236
	14:00	84.21	69.78	0.82	13.60					1		1			1		1	1		1			1	54.42	24.28	21.18	56%	23,076
	15:00	84.84	72.93	1.11	10.80					1		1			1		1	1		1			1	51.27	25.30	22.21	59%	23,794
	16:00	88.12	83.59	0.82	3.70			1		1		1			1		1	1		1			1	58.61	24.79	25.33	59%	25,384
	17:00	100.11	99.74	0.30	0.06			1		1		1			1		1	1		1			1	42.46	29.91	30.01	70%	28,519
	18:00	109.58	109.08	0.49	0.00			1		1		1			1		1	1		1			1	50.22	32.83	32.87	68%	29,593
	19:00	111.56	110.28	1.28	0.00			1		1		1			1		1	1		1			1	49.02	33.47	33.47	69%	29,739
	20:00	111.24	109.09	2.15	0.00			1		1		1			1		1	1		1			1	50.21	33.43	33.37	68%	29,524
	21:00	105.47	102.59	2.88	0.00			1		1		1			1		1	1		1			1	56.71	31.68	31.64	64%	28,316
	22:00	94.96	91.79	3.17	0.00			1		1		1			1		1	1		1			1	49.51	28.55	28.49	65%	26,847
	23:00	81.84	76.12	5.71	0.00			1		1		1			1		1		1	1			1	32.28	24.31	24.55	70%	16,402
		1948.35 MWh																						ΑΩΛ: 11.51		507,047 €		

Παρατηρήσεις:

Δεν προτείνεται οποιαδήποτε αλλαγή στην απολογιστική λειτουργία.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης