

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 31 Δεκεμβρίου 2025								
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α Ρ Θ Ε Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τετάρτη, 31 Δεκεμβρίου 2025	00:00	0,806							1		
	01:00	0,760							1		
	02:00	0,713							1		
	03:00	0,693							1		
	04:00	0,712							1		
	05:00	0,709							1		
	06:00	0,825							1		
	07:00	0,808							1		
	08:00	0,903	1						1		
	09:00	1,001	1								1
	10:00	1,025	1								1
	11:00	1,083							1		1
	12:00	1,074							1		1
	13:00	1,139							1		1
	14:00	1,180							1		1
	15:00	1,181							1		1
	16:00	1,260							1		1
	17:00	1,294							1		1
	18:00	1,354							1		1
	19:00	1,287							1		1
	20:00	1,236							1		1
	21:00	1,094							1		1
	22:00	1,005							1		1
	23:00	0,917							1		1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 1 Ιανουαρίου 2026								
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Πέμπτη, 1 Ιανουαρίου 2026	00:00	0,906							1		
	01:00	0,881							1		
	02:00	0,837							1		
	03:00	0,805							1		
	04:00	0,793							1		
	05:00	0,777							1		
	06:00	0,863							1		
	07:00	0,824							1		
	08:00	0,821							1		
	09:00	0,812							1		
	10:00	0,868							1		
	11:00	0,865							1		
	12:00	0,882							1		
	13:00	0,866							1		
	14:00	0,875							1		
	15:00	0,867							1		
	16:00	0,948	1						1		
	17:00	1,045	1						1		
	18:00	1,142	1						1		
	19:00	1,156	1						1		
	20:00	1,152	1						1		
	21:00	1,115	1						1		
	22:00	1,014	1						1		
	23:00	0,889	1						1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΝΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 2 Ιανουαρίου 2026								
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Παρασκευή, 2 Ιανουαρίου 2026	00:00	0,862							1		
	01:00	0,789							1		
	02:00	0,764							1		
	03:00	0,739							1		
	04:00	0,774							1		
	05:00	0,796							1		
	06:00	0,895							1		
	07:00	0,868							1		
	08:00	0,859							1		
	09:00	0,805							1		
	10:00	0,817							1		
	11:00	0,848							1		
	12:00	0,865							1		
	13:00	0,865							1		
	14:00	0,918	1						1		
	15:00	0,945	1						1		
	16:00	1,061	1						1		
	17:00	1,165	1						1		
	18:00	1,319	1						1		
	19:00	1,308	1						1		
	20:00	1,241	1						1		
	21:00	1,151	1						1		
	22:00	1,078	1						1		
	23:00	0,952	1						1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 3 Ιανουαρίου 2026								
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
α ρ χ ή	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Σάββατο, 3 Ιανουαρίου 2026	00:00	0,892	1						1		
	01:00	0,824							1		
	02:00	0,796							1		
	03:00	0,775							1		
	04:00	0,786							1		
	05:00	0,774							1		
	06:00	0,857							1		
	07:00	0,841	1						1		
	08:00	0,920	1						1		
	09:00	0,959	1						1		
	10:00	1,007	1						1		
	11:00	1,043	1						1		
	12:00	0,977	1						1		
	13:00	0,980	1						1		
	14:00	1,024	1						1		
	15:00	1,034	1						1		
	16:00	1,111	1						1		
	17:00	1,209	1						1		
	18:00	1,285	1						1		
	19:00	1,229	1						1		
	20:00	1,188	1						1		
	21:00	1,101	1						1		
	22:00	1,034	1						1		
	23:00	0,958	1						1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 4 Ιανουαρίου 2026								
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Η Ε- Ρ- Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Κυριακή, 4 Ιανουαρίου 2026	00:00	0,906							1		
	01:00	0,818							1		
	02:00	0,777							1		
	03:00	0,759							1		
	04:00	0,799							1		
	05:00	0,781							1		
	06:00	0,858							1		
	07:00	0,864							1		
	08:00	0,822							1		
	09:00	0,829							1		
	10:00	0,833							1		
	11:00	0,794							1		
	12:00	0,823							1		
	13:00	0,814							1		
	14:00	0,843							1		
	15:00	0,831							1		
	16:00	0,931	1						1		
	17:00	1,060	1						1		
	18:00	1,163	1						1		
	19:00	1,135	1						1		
	20:00	1,083	1						1		
	21:00	1,004	1						1		
	22:00	0,937	1						1		
	23:00	0,846	1						1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 5 Ιανουαρίου 2026								
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Δευτέρα, 5 Ιανουαρίου 2026	00:00	0,787							1		
	01:00	0,722							1		
	02:00	0,707							1		
	03:00	0,686							1		
	04:00	0,705							1		
	05:00	0,718							1		
	06:00	0,800							1		
	07:00	0,786							1		
	08:00	0,849							1		
	09:00	0,842							1		
	10:00	0,859							1		
	11:00	0,857							1		
	12:00	0,896	1						1		
	13:00	0,874	1						1		
	14:00	0,877	1						1		
	15:00	0,928	1						1		
	16:00	1,032	1						1		
	17:00	1,052	1						1		
	18:00	1,177	1						1		
	19:00	1,147	1						1		
	20:00	1,194	1						1		
	21:00	1,158	1						1		
	22:00	1,057	1						1		
	23:00	0,939	1						1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 6 Ιανουαρίου 2026								
Αποδιδόμενη Ισχύς (MW)			1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000
Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
Τρίτη, 6 Ιανουαρίου 2026	00:00	0,852							1		
	01:00	0,767							1		
	02:00	0,746							1		
	03:00	0,716							1		
	04:00	0,727							1		
	05:00	0,737							1		
	06:00	0,809							1		
	07:00	0,808							1		
	08:00	0,830							1		
	09:00	0,836							1		
	10:00	0,819							1		
	11:00	0,825							1		
	12:00	0,863							1		
	13:00	0,902							1		
	14:00	0,910	1						1		
	15:00	0,897	1						1		
	16:00	0,980	1						1		
	17:00	1,064	1						1		
	18:00	1,159	1						1		
	19:00	1,117	1						1		
	20:00	1,097	1						1		
	21:00	1,042	1						1		
	22:00	1,003	1						1		
	23:00	0,924							1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης