

ΗΣ ΡΟΔΟΥ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα																		Thursday, January 1, 2026			
Αποδιδόμενη Ισχύς (ΜW)			14.50	10.50	18.00	18.00	18.00	17.50	22.00	20.00	27.00	32.90	27.90	17.10	17.10	17.10	17.10	17.10	17.10	17.10				
ΤΕ (ΜW)			6.00	4.90	14.00	14.00	14.00	5.00	5.00	5.00	5.60	6.60	6.80	6.80	6.80	6.80	6.80	6.80	6.80	6.80				
Η Ε Ρ Ε Τ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου φορτίου (ΜW)	Πρόβλεψη Θερμικής Παραγωγής (ΜW)	Πρόβλεψη Αιολικής Παραγωγής (ΜW)	Πρόβλεψη Φωτοβολταϊκής Παραγωγής (ΜW)	ΑΗΣ ΣΙΔΩΝΗΣ						ΘΗΣ Ν.ΡΟΔΟΥ							Στρεφόμενη εφεδρεία (ΜW)	Set-point Αιολικών Πάρκων (ΜW)	Μέση φόρτιση Μονάδων ΑΣΠ (% επί της αποδιδόμενης)	Κόστος καυσίμου (€)		
						ΑΤΜ 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	AEP 1	AEP 2	AEP 3	AEP 4	AEP 5	AEP 6	DIESEL 1	DIESEL 2					DIESEL 3	DIESEL 4
Thursday, January 1, 2026	00:00	62.31	43.62	18.69	0.00			1							1		1				35.58	18.69	55%	11,911
	01:00	55.83	39.08	16.75	0.00			1							1		1				40.12	16.75	49%	10,806
	02:00	51.52	36.07	15.46	0.00			1							1		1				43.13	15.46	46%	10,047
	03:00	49.16	34.41	14.75	0.00			1							1		1				44.79	14.75	43%	9,623
	04:00	48.71	34.10	14.61	0.00			1							1		1				45.10	14.61	43%	9,541
	05:00	50.48	35.33	15.14	0.00			1							1		1				43.87	15.14	45%	9,859
	06:00	54.75	38.32	16.42	0.00			1							1		1				40.88	16.42	48%	10,617
	07:00	60.27	41.85	17.93	0.49			1							1		1				37.35	17.93	53%	11,485
	08:00	65.10	42.67	18.29	4.14			1							1		1				36.53	18.29	54%	11,684
	09:00	69.08	42.21	18.09	8.78			1							1		1				36.99	18.09	53%	11,573
	10:00	70.63	40.83	17.50	12.30			1							1		1				38.37	17.50	52%	11,238
	11:00	69.51	38.41	16.46	14.64			1							1		1				40.79	16.46	48%	10,638
	12:00	69.28	37.76	16.18	15.34			1							1		1				41.44	16.18	48%	10,476
	13:00	67.57	37.37	16.01	14.19			1							1		1				41.83	16.01	47%	10,376
	14:00	66.34	38.44	16.47	11.42			1							1		1				40.76	16.47	49%	10,647
	15:00	67.37	42.05	18.02	7.30			1							1		1				37.15	18.02	53%	11,534
	16:00	73.29	49.58	21.25	2.46			1							1		1				29.62	21.25	63%	13,283
	17:00	84.87	59.39	25.45	0.03			1							1		1				19.81	25.45	75%	15,316
	18:00	90.77	63.54	27.23	0.00			1							1		1				32.76	27.23	66%	15,337
	19:00	92.64	67.50	25.13	0.00			1							1		1			1	28.80	27.79	70%	16,032
	20:00	90.95	78.75	12.20	0.00			1							1		1			1	17.55	27.28	82%	18,016
	21:00	84.48	72.90	11.59	0.00			1							1		1			1	23.40	25.35	76%	17,020
	22:00	74.87	64.05	10.82	0.00			1							1		1			1	32.25	22.46	67%	15,367
	23:00	61.90	52.30	9.60	0.00			1							1		1			1	26.90	18.57	66%	13,877
		1631.66 MWh																			ΑΩΛ: 9.46		296,302 €	
		1.00																						

Παρατηρήσεις:

1.00

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης