

ΗΣ ΡΟΔΟΥ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα																		Friday, January 2, 2026						
Αποδιδόμενη Ισχύς (ΜW)			14.50	10.50	18.00	18.00	18.00	17.50	22.00	20.00	27.00	32.90	27.90	17.10	17.10	17.10	17.10	17.10	17.10								
TE (ΜW)			6.00	4.90	14.00	14.00		5.00	5.00	5.00	5.00	5.60	6.60	6.80	6.80	6.80	6.80	6.80	6.80								
H Α Ρ Χ Η	Χρονική στιγμή	Πρόβλεψη Μέσου ημερήσιου φορτίου (ΜW)	Πρόβλεψη Θερμικής Παραγωγής (ΜW)	Πρόβλεψη Αιολικής Παραγωγής (ΜW)	Πρόβλεψη Φωτοβολταϊκής Παραγωγής (ΜW)	ΑΗΣ ΣΟΡΩΝΗΣ										ΘΗΣ Ν.ΡΟΔΟΥ							Στρεφόμενη εφεδρεία (ΜW)	Set-point Αιολικών Πάρκων (ΜW)	Μέση φόρτιση Μονάδων ΑΣΠ (%) επί της αποδιδόμενης)	Κόστος καυσίμου (€)	
						ΑΤΜ 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	ΑΕΡ 1	ΑΕΡ 2	ΑΕΡ 3	ΑΕΡ 4	ΑΕΡ 5	ΑΕΡ 6	DIESEL 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	DIESEL 6					DIESEL 7
Friday, January 2, 2026	00:00	63.30	55.66	7.64	0.00			1						1		1	1							23.54	18.99	70%	14,651
	01:00	57.59	52.71	4.88	0.00			1						1		1	1							26.49	17.28	67%	13,964
	02:00	53.52	47.87	5.65	0.00			1						1		1	1							31.33	16.06	60%	12,899
	03:00	51.21	41.87	9.34	0.00			1						1		1	1							37.33	15.36	53%	11,492
	04:00	51.10	39.46	11.64	0.00			1						1		1	1							39.74	15.33	50%	10,900
	05:00	53.55	43.48	10.06	0.00			1						1		1	1							35.72	16.06	55%	11,878
	06:00	58.29	47.84	10.44	0.00			1						1		1	1							31.36	17.49	60%	12,893
	07:00	63.41	51.30	11.61	0.50			1						1		1	1							27.90	18.87	65%	13,662
	08:00	65.02	52.98	7.81	4.23			1						1		1	1							26.22	18.24	67%	14,022
	09:00	68.07	52.80	6.59	8.67			1						1		1	1							26.40	17.82	67%	13,985
	10:00	70.55	52.84	5.63	12.07			1						1		1	1							26.36	17.54	67%	13,993
	11:00	70.92	51.73	5.08	14.11			1						1		1	1							27.47	17.04	65%	13,754
	12:00	70.66	50.68	5.35	14.63			1						1		1	1							28.52	16.81	64%	13,525
	13:00	69.40	50.20	5.65	13.55			1						1		1	1							29.00	16.75	63%	13,421
	14:00	68.36	50.00	5.84	12.52			1						1		1	1							29.20	16.75	63%	13,376
	15:00	71.65	60.98	1.89	8.78			1						1		1	1							18.22	18.86	77%	15,616
	16:00	76.59	70.56	1.44	4.59			1						1		1	1		1					25.74	21.60	73%	16,670
	17:00	88.90	87.91	0.68	0.30			1	1					1		1	1	1						26.39	26.58	77%	19,188
	18:00	94.55	94.19	0.36	0.00			1	1					1		1	1	1						20.11	28.36	82%	20,121
	19:00	95.96	95.96	0.00	0.00			1	1					1		1	1	1						18.34	28.79	84%	20,391
	20:00	93.96	93.96	0.00	0.00			1	1					1		1	1	1						20.34	28.19	82%	20,085
	21:00	88.51	88.51	0.00	0.00			1	1					1		1	1	1						25.79	26.55	77%	19,217
	22:00	79.90	79.90	0.00	0.00			1	1					1		1	1	1						34.40	23.97	70%	17,742
	23:00	68.54	68.54	0.00	0.00			1	1					1		1	1	1						45.76	15.14	60%	15,620
		1693.51 MWh																				ΑΩΛ: 9.71		363,066 €			

παρατηρήσεις:

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης