

ΗΣ ΡΟΔΟΥ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα																		Saturday, January 3, 2026					
Αποδιδόμενη Ισχύς (ΜW)			14.50	10.50	18.00	18.00	18.00	17.50	22.00	20.00	27.00	32.90	27.90	17.10	17.10	17.10	17.10	17.10	17.10	17.10						
ΤΕ (ΜW)			6.00	4.90	14.00	14.00	14.00	5.00	5.00	5.00	5.60	6.60	6.80	6.80	6.80	6.80	6.80	6.80								
Η Ε Ρ Ε Τ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου φορτίου (ΜW)	Πρόβλεψη Θερμικής Παραγωγής (ΜW)	Πρόβλεψη Αιολικής Παραγωγής (ΜW)	Πρόβλεψη Φωτοβολτατικής Παραγωγής (ΜW)	ΑΗΣ ΣΙΦΩΝΗΣ						ΘΗΣ Ν.ΡΟΔΟΥ							Στρεφόμενη εφεδρεία (ΜW)	Set-point Αιολικών Πάρκων (ΜW)	Μέση φόρτιση Μονάδων ΑΣΠ (% επί της αποδιδόμενης)	Κόστος καυσίμου (€)				
						ΑΤΗ 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	AEP 1	AEP 2	AEP 3	AEP 4	AEP 5	AEP 6	DIESEL 1	DIESEL 2					DIESEL 3	DIESEL 4	DIESEL 5	DIESEL 6
Saturday, January 3, 2026	00:00	63.36	63.01	0.35	0.00			1					1					1				1	16.19	19.01	80%	15,986
	01:00	57.55	56.99	0.57	0.00			1					1					1				1	22.21	17.27	72%	14,847
	02:00	53.23	52.54	0.69	0.00			1					1					1				1	26.66	15.97	66%	13,928
	03:00	50.95	50.06	0.89	0.00			1					1					1				1	29.14	15.29	63%	13,390
	04:00	50.77	49.47	1.29	0.00			1					1					1				1	29.73	15.23	62%	13,260
	05:00	52.79	50.84	1.95	0.00			1					1					1				1	28.36	15.84	64%	13,561
	06:00	57.21	53.96	3.25	0.00			1					1					1				1	25.24	17.16	68%	14,228
	07:00	62.49	56.75	5.74	0.00			1					1					1				1	22.45	18.75	72%	14,801
	08:00	66.53	56.92	8.07	1.53			1					1					1				1	22.28	19.50	72%	14,834
	09:00	69.27	52.74	10.63	5.91			1					1					1				1	26.46	19.01	67%	13,970
	10:00	71.61	50.48	11.47	9.66			1					1					1				1	28.72	18.59	64%	13,481
	11:00	72.19	48.25	11.70	12.24			1					1					1				1	30.95	17.99	61%	12,986
	12:00	71.85	45.81	12.59	13.45			1					1					1				1	33.39	17.52	58%	12,425
	13:00	70.75	44.42	13.13	13.20			1					1					1				1	34.78	17.26	56%	12,101
	14:00	69.96	44.13	14.34	11.49			1					1					1				1	35.07	17.54	56%	12,032
	15:00	72.01	48.00	15.56	8.46			1					1					1				1	31.20	19.07	61%	12,928
	16:00	76.58	56.88	15.32	4.39			1					1					1				1	22.32	21.66	72%	14,825
	17:00	87.54	73.00	14.25	0.30			1					1		1	1		1				1	23.30	26.17	76%	17,108
	18:00	93.40	79.46	13.94	0.00			1					1		1	1		1				1	16.84	28.02	83%	18,131
	19:00	95.19	79.80	15.39	0.00			1					1		1	1		1				1	16.50	28.56	83%	18,186
	20:00	93.47	76.34	17.13	0.00			1					1		1	1		1				1	19.96	28.04	79%	17,615
	21:00	88.30	69.66	18.63	0.00			1					1		1	1		1				1	26.64	26.49	72%	16,435
	22:00	80.00	59.77	20.23	0.00			1					1		1	1		1				1	19.43	24.00	75%	15,390
	23:00	69.20	48.44	20.76	0.00			1					1		1	1		1				1	30.76	20.76	61%	13,028
		1696.21 MWh																			ΑΩΛ: 9.92		349,478 €			

Παρατηρήσεις:

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης