

ΗΣ ΡΟΔΟΥ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα																		Sunday, January 4, 2026						
Αποδιδόμενη Ισχύς (ΜW)			14.50	10.50	18.00	18.00	18.00	17.50	22.00	20.00	27.00	32.90	27.90	17.10	17.10	17.10	17.10	17.10	17.10	17.10							
ΤΕ (ΜW)			6.00	4.90	14.00	14.00	14.00	5.00	5.00	5.00	5.60	6.60	6.80	6.80	6.80	6.80	6.80	6.80									
Η Ε Ρ Ε Δ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου φορτίου (ΜW)	Πρόβλεψη Θερμικής Παραγωγής (ΜW)	Πρόβλεψη Αιολικής Παραγωγής (ΜW)	Πρόβλεψη Φωτοβολταϊκής Παραγωγής (ΜW)	ΑΗΣ ΣΙΔΡΩΝΗΣ										ΘΗΣ Ν.ΡΟΔΟΥ							Στρεφόμενη εφεδρεία (ΜW)	Set-point Αιολικών Πάρκων (ΜW)	Μέση φόρτιση Μονάδων ΑΣΠ (% επί της αποδιδόμενης)	Κόστος καυσίμου (€)	
						ΑΤΗ 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	AEP 1	AEP 2	AEP 3	AEP 4	AEP 5	AEP 6	DIESEL 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	DIESEL 6					DIESEL 7
Sunday, January 4, 2026	00:00	62.20	43.54	18.66	0.00			1					1					1				1	35.66	18.66	55%	11,892	
	01:00	56.58	39.60	16.97	0.00			1					1					1				1	39.60	16.97	50%	10,936	
	02:00	52.25	36.57	15.67	0.00			1					1					1				1	42.63	15.67	46%	10,176	
	03:00	49.75	34.82	14.92	0.00			1					1					1				1	44.38	14.92	44%	9,728	
	04:00	49.23	34.46	14.77	0.00			1					1					1				1	44.74	14.77	44%	9,635	
	05:00	50.77	35.54	15.23	0.00			1					1					1				1	43.66	15.23	45%	9,912	
	06:00	54.49	38.15	16.35	0.00			1					1					1				1	41.05	16.35	48%	10,573	
	07:00	59.38	41.56	17.81	0.00			1					1					1				1	37.64	17.81	52%	11,417	
	08:00	64.20	45.58	17.84	0.78			1					1					1				1	33.62	19.03	58%	12,373	
	09:00	68.04	47.23	17.54	3.27			1					1					1				1	31.97	19.43	60%	12,754	
	10:00	70.63	46.88	18.06	5.68			1					1					1				1	32.32	19.48	59%	12,674	
	11:00	71.36	46.04	17.02	8.30			1					1					1				1	33.16	18.92	58%	12,480	
	12:00	70.83	42.33	15.31	13.19			1					1					1				1	36.87	17.29	53%	11,602	
	13:00	69.40	42.61	13.72	13.07			1					1					1				1	36.59	16.90	54%	11,670	
	14:00	68.27	44.33	12.49	11.45			1					1					1				1	34.87	17.04	56%	12,078	
	15:00	69.30	50.62	10.24	8.45			1					1					1				1	28.58	18.26	64%	13,512	
	16:00	73.10	59.86	8.83	4.42			1	1				1					1				1	37.34	20.60	62%	14,737	
	17:00	82.49	72.24	9.97	0.29			1	1				1					1				1	24.96	24.66	74%	17,053	
	18:00	87.30	77.19	10.11	0.00			1	1				1					1			1	1	37.11	26.19	68%	17,323	
	19:00	89.40	79.57	9.83	0.00			1	1				1					1			1	1	34.73	26.82	70%	17,682	
	20:00	88.09	68.26	19.83	0.00			1	1				1					1			1	1	46.04	26.43	60%	15,563	
	21:00	83.64	59.67	23.96	0.00			1	1				1					1			1	1	37.53	25.09	61%	14,628	
	22:00	75.92	53.15	22.78	0.00			1	1				1					1			1	1	44.05	22.78	55%	13,244	
	23:00	65.89	46.12	19.77	0.00			1					1					1			1	1	33.08	19.77	58%	12,499	
		1632.51 MWh																						ΑΩΛ: 9.60		306,142 €	

Παρατηρήσεις:

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης