

ΗΣ ΡΟΔΟΥ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα																	Thursday, January 8, 2026							
Αποδιδόμενη Ισχύς (MW)			14.50	10.50	18.00	18.00	18.00	17.50	22.00	20.00	27.00	32.90	27.90	17.10	17.10	17.10	17.10	17.10	17.10	17.10							
ΤΕ (MW)			6.00	4.90	14.00	14.00	14.00	5.00	5.00	5.00	5.00	5.60	6.60	6.80	6.80	6.80	6.80	6.80	6.80	6.80							
Η Ε Ρ Ε Τ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	Πρόβλεψη Θερμικής Παραγωγής (MW)	Πρόβλεψη Αιολικής Παραγωγής (MW)	Πρόβλεψη Φωτοβολταϊκής Παραγωγής (MW)	ΑΗΣ ΣΙΦΩΝΗΣ						ΘΗΣ Ν.ΡΟΔΟΥ							Στρεφόμενη εφεδρεία (MW)	Set-point Αιολικών Πάρκων (MW)	Μέση φόρτιση Μονάδων ΑΣΠ (% επί της αποδιδόμενης)	Κόστος καυσίμου (€)					
						ΑΤΗ 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	AEP 1	AEP 2	AEP 3	AEP 4	AEP 5	AEP 6	DIESEL 1	DIESEL 2					DIESEL 3	DIESEL 4	DIESEL 5	DIESEL 6	DIESEL 7
Thursday, January 8, 2026	00:00	66.67	46.67	20.00	0.00					1		1						1		1				27.53	20.00	63%	12,631
	01:00	62.07	43.45	18.62	0.00					1		1						1		1				30.75	18.62	59%	12,135
	02:00	59.13	41.39	17.74	0.00					1		1						1		1				32.81	17.74	56%	11,806
	03:00	58.08	40.65	17.42	0.00					1		1						1		1				33.55	17.42	55%	11,685
	04:00	59.09	41.36	17.73	0.00					1		1						1		1				32.84	17.73	56%	11,801
	05:00	62.38	43.66	18.71	0.00					1		1						1		1				30.54	18.71	59%	12,169
	06:00	68.06	47.64	20.42	0.00					1		1						1		1				26.56	20.42	64%	12,777
	07:00	75.20	52.59	22.54	0.08					1		1						1		1				21.61	22.54	71%	13,503
	08:00	82.88	58.57	23.54	0.77					1		1						1	1	1				32.73	24.63	64%	14,203
	09:00	89.38	74.01	13.88	1.49					1		1						1	1	1				17.29	26.37	81%	16,312
	10:00	92.87	64.09	27.47	1.30					1		1						1	1	1				27.21	27.47	70%	14,915
	11:00	92.60	64.10	27.47	1.03					1		1						1	1	1				27.20	27.47	70%	14,915
	12:00	91.86	63.52	27.22	1.12					1		1						1	1	1				27.78	27.22	70%	14,833
	13:00	89.78	61.66	26.43	1.70					1		1						1	1	1				29.64	26.43	68%	14,572
	14:00	87.78	60.19	25.80	1.79					1		1						1	1	1				31.11	25.80	66%	14,364
	15:00	86.32	57.96	24.84	3.51					1		1						1	1	1				33.34	24.84	63%	14,045
	16:00	88.22	60.04	25.73	2.46					1		1						1	1	1				31.26	25.73	66%	14,342
	17:00	94.45	66.05	28.31	0.09					1		1						1	1	1				25.25	28.31	72%	15,188
	18:00	98.18	68.73	29.46	0.00					1		1						1	1	1				22.57	29.46	75%	15,564
	19:00	99.76	69.83	29.93	0.00					1		1						1	1	1				21.47	29.93	76%	15,719
	20:00	97.86	68.50	29.36	0.00					1		1						1	1	1				22.80	29.36	75%	15,532
	21:00	92.15	64.51	27.65	0.00					1		1						1	1	1				26.79	27.65	71%	14,972
	22:00	84.11	58.88	25.23	0.00					1		1						1	1	1				32.42	25.23	64%	14,177
	23:00	73.97	51.78	22.19	0.00					1		1						1	1	1				22.42	22.19	70%	13,386
		1952.84 MWh																							ΑΩΛ: 11.90		335,547 €

Παρατηρήσεις:

1.Ενταξη D5 ΑΗΣ με αίτημα σταθμού για ανάγκες ατμού.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης