

ΗΣ ΡΟΔΟΥ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα																	Friday, January 16, 2026						
Αποδιδόμενη Ισχύς (MW)			14.50	18.00	18.00	18.00	17.50	22.00	20.00	27.00	32.90	27.90	17.10	17.10	17.10	17.10	17.10	17.10								
ΤΕ (MW)			6.00	14.00	14.00	14.00	5.00	5.00	5.00	5.00	5.60	6.60	6.80	6.80	6.80	6.80	6.80	6.80								
Η Ε Ρ Ε Δ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ορισίου Φορτίου (MW)	Πρόβλεψη θερμικής Παραγωγής (MW)	Πρόβλεψη Αιολικής Παραγωγής (MW)	Πρόβλεψη Φωτοβολταϊκής Παραγωγής (MW)	ΑΗΣ ΣΟΡΑΝΗΣ						ΟΗΣ Ν.ΡΟΔΟΥ							Στρεφόμενη εφεδρεία (MW)	Set-point Αιολικών Πάρκων (MW)	Μέση φόρτιση Μονάδων ΑΣΠ (% επί της αποδιδόμενης)	Κόστος καυσίμου (€)				
						ΑΤΜ 1	DIESEL 3	DIESEL 4	DIESEL 5	AEP 1	AEP 2	AEP 3	AEP 4	AEP 5	AEP 6	DIESEL 1	DIESEL 2	DIESEL 3					DIESEL 4	DIESEL 5	DIESEL 6	DIESEL 7
Friday, January 16, 2026	00:00	68.87	68.86	0.00	0.00				1		1						1		1			1	22.44	20.66	75%	15,583
	01:00	62.81	62.81	0.00	0.00				1		1						1		1			1	28.49	18.84	69%	14,734
	02:00	58.76	58.76	0.00	0.00				1		1						1		1			1	32.54	17.63	64%	14,160
	03:00	56.37	56.35	0.02	0.00				1		1						1		1				17.85	16.91	76%	14,048
	04:00	56.05	55.95	0.10	0.00				1		1						1		1				18.25	16.81	75%	13,991
	05:00	57.93	57.72	0.21	0.00				1		1						1		1		1		33.58	17.38	63%	14,080
	06:00	63.13	62.96	0.17	0.00				1		1						1		1			1	28.34	18.94	69%	14,756
	07:00	70.90	70.38	0.16	0.36				1		1			1			1		1			1	53.82	21.16	57%	23,220
	08:00	77.34	73.97	0.13	3.24				1		1			1			1		1			1	50.23	22.23	60%	24,026
	09:00	81.97	75.16	0.00	6.81				1		1			1			1		1			1	49.04	22.55	61%	24,289
	10:00	84.22	74.48	0.00	9.73				1		1			1			1		1			1	49.72	22.34	60%	24,139
	11:00	85.07	74.52	0.01	10.55				1		1			1			1		1			1	49.68	22.36	60%	24,147
	12:00	84.68	75.40	0.18	9.10				1		1			1			1		1			1	48.80	22.67	61%	24,342
	13:00	83.06	75.37	0.25	7.44				1		1			1			1		1			1	48.83	22.69	61%	24,334
	14:00	81.79	77.24	0.48	4.07				1		1			1			1		1			1	46.96	23.32	62%	24,741
	15:00	81.04	78.13	0.67	2.25				1		1			1			1		1			1	46.07	23.64	63%	24,931
	16:00	83.62	81.13	0.72	1.77				1		1			1			1		1			1	43.07	24.55	65%	25,563
	17:00	93.20	92.45	0.54	0.22				1		1			1			1		1			1	31.75	27.89	74%	27,787
	18:00	99.51	98.64	0.87	0.00				1		1			1			1		1			1	25.56	29.85	79%	28,910
	19:00	101.55	100.24	1.31	0.00				1		1			1			1		1			1	23.96	30.46	81%	29,190
	20:00	101.06	99.96	1.10	0.00				1		1			1			1		1			1	24.24	30.32	80%	29,141
	21:00	96.19	95.22	0.97	0.00				1		1			1			1		1			1	28.98	28.86	77%	28,298
	22:00	87.76	86.82	0.94	0.00				1		1			1			1		1			1	37.38	26.33	70%	26,711
	23:00	78.69	77.23	1.46	0.00				1		1					1	1	1	1			1	31.17	23.61	71%	16,623
		1895.55 MWh																				ΑΩΛ: 11.30		531,745 €		

Παρατηρήσεις:

Μπορεί να γίνει εναλλαγή μεταξύ μονάδων με όμοια χαρακτηριστικά κατά την κρίση του ΑΣΠ, ανάλογα και με τις συμπληρωμένες ώρες λειτουργίας τους.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης