

ΗΣ ΡΟΔΟΥ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα																			Sunday, January 18, 2026				
Αποδιδόμενη Ισχύς (MW)						14.50	10.50	18.00	18.00	18.00	17.50	22.00	20.00	27.00	32.90	27.90	17.10	17.10	17.10	17.10	17.10	17.10	17.10			
TE (MW)						6.00	4.90	14.00	14.00	14.00	5.00	5.00	5.00	5.60	6.60	6.80	6.80	6.80	6.80	6.80	6.80					
H O R E	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου φορτίου (MW)	Πρόβλεψη Θερμικής Παραγωγής (MW)	Πρόβλεψη Αιολικής Παραγωγής (MW)	Πρόβλεψη Φωτοβολταϊκής Παραγωγής (MW)	ΑΗΣ ΣΙΦΩΝΗΣ										ΘΗΣ Ν.ΡΟΔΟΥ							Στρεφόμενη εφεδρεία (MW)	Set-point Αιολικών Πάρκων (MW)	Μέση φόρτιση Μονάδων ΑΣΠ (% επί της αποδιδόμενης)	Κόστος καυσίμου (€)
						ΑΤΜ 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	AEP 1	AEP 2	AEP 3	AEP 4	AEP 5	AEP 6	DIESEL 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	DIESEL 6				
Sunday, January 18, 2026	00:00	64.11	54.86	9.25	0.00					1		1			1			1				1	52.24	19.23	51%	20,502
	01:00	58.51	47.74	10.77	0.00					1		1			1			1				1	59.36	17.55	45%	18,520
	02:00	54.23	40.96	13.27	0.00					1		1			1			1				1	66.14	16.03	38%	16,467
	03:00	51.51	36.06	15.45	0.00					1		1						1				1	38.14	15.45	49%	10,892
	04:00	50.64	35.45	15.19	0.00					1		1						1				1	38.75	15.19	48%	10,780
	05:00	51.81	36.27	15.54	0.00					1		1						1				1	37.93	15.54	49%	10,930
	06:00	55.49	38.84	16.65	0.00					1		1						1				1	35.36	16.65	52%	11,381
	07:00	60.95	42.26	18.11	0.57					1		1						1				1	31.94	18.11	57%	11,947
	08:00	65.62	42.74	18.32	4.55					1		1						1				1	31.46	18.32	58%	12,024
	09:00	69.87	47.83	12.72	9.31					1		1						1				1	26.37	18.17	64%	12,806
	10:00	72.86	50.19	9.69	12.98					1		1						1				1	24.01	17.96	68%	13,154
	11:00	74.37	51.80	7.37	15.20					1		1						1				1	22.40	17.75	70%	13,388
	12:00	74.46	51.42	7.20	15.84					1		1						1				1	22.78	17.59	69%	13,334
	13:00	73.07	48.49	9.71	14.87					1		1						1				1	25.71	17.46	65%	12,903
	14:00	71.23	45.60	11.74	13.89					1		1						1				1	28.60	17.20	61%	12,469
	15:00	72.34	43.99	18.85	9.50					1		1						1				1	30.21	18.85	59%	12,219
	16:00	75.57	49.13	21.06	5.39					1		1						1				1	25.07	21.06	66%	12,998
	17:00	84.24	58.28	24.98	0.99			1				1						1				1	33.92	24.98	63%	14,335
	18:00	90.37	65.47	24.91	0.00			1		1		1						1				1	26.73	27.11	71%	15,286
	19:00	92.64	71.35	21.29	0.00			1		1		1						1	1			1	37.95	27.79	65%	15,995
	20:00	92.52	75.58	16.94	0.00			1		1		1						1	1			1	33.72	27.76	69%	16,508
	21:00	89.66	76.86	12.80	0.00			1		1		1						1	1			1	32.44	26.90	70%	16,683
	22:00	82.85	72.64	10.21	0.00			1		1		1						1	1			1	36.66	24.85	66%	16,103
	23:00	74.84	65.52	9.33	0.00			1		1		1						1				1	26.68	22.45	71%	15,293
		1703.76 MWh																				ΑΩΛ: 9.83		336,916 €		

Παρατηρήσεις:

Μπορεί να γίνει εναλλαγή μεταξύ μονάδων με όμοια χαρακτηριστικά κατά την κρίση του ΑΣΠ, ανάλογα και με τις συμπληρωμένες ώρες λειτουργίας τους.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης