

ΗΣ ΡΟΔΟΥ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα																	Monday, January 19, 2026							
Αποδιδόμενη Ισχύς (ΜW)			14.50	10.50	18.00	18.00	18.00	17.50	22.00	20.00	27.00	32.90	27.90	17.10	17.10	17.10	17.10	17.10	17.10	17.10							
ΤΕ (ΜW)			6.00	4.90	14.00	14.00	14.00	5.00	5.00	5.00	5.00	5.60	6.60	6.80	6.80	6.80	6.80	6.80	6.80	6.80							
Ημερομηνία	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου φορτίου (ΜW)	Πρόβλεψη Θερμικής Παραγωγής (ΜW)	Πρόβλεψη Αιολικής Παραγωγής (ΜW)	Πρόβλεψη Φωτοβολταϊκής Παραγωγής (ΜW)	ΑΗΣ ΣΙΦΑΝΗΣ						ΘΗΣ Ν.ΡΟΔΟΥ							Στρεφόμενη εφεδρεία (ΜW)	Set-point Αιολικών Πάρκων (ΜW)	Μέση φόρτιση Μονάδων ΑΣΠ (% επί της αποδιδόμενης)	Κόστος καυσίμου (€)					
						ΑΤΜ 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	ΑΕΡ 1	ΑΕΡ 2	ΑΕΡ 3	ΑΕΡ 4	ΑΕΡ 5	ΑΕΡ 6	DIESEL 1	DIESEL 2					DIESEL 3	DIESEL 4	DIESEL 5	DIESEL 6	DIESEL 7
Monday, January 19, 2026	00:00	61.41	52.97	8.44	0.00					1		1							1				1	21.23	18.42	71%	13,558
	01:00	55.94	48.20	7.75	0.00					1		1							1				1	26.00	16.78	65%	12,860
	02:00	52.44	46.05	6.39	0.00					1		1							1				1	28.15	15.73	62%	12,537
	03:00	50.89	46.22	4.67	0.00					1		1							1				1	27.98	15.27	62%	12,563
	04:00	51.64	48.49	3.15	0.00					1		1							1				1	25.71	15.49	65%	12,903
	05:00	54.80	52.69	2.11	0.00					1		1							1				1	21.51	16.44	71%	13,518
	06:00	61.30	59.58	1.72	0.00					1		1							1				1	14.62	18.39	80%	14,523
	07:00	69.75	68.34	1.41	0.00					1		1							1			1	1	22.96	20.93	75%	15,580
	08:00	76.37	73.78	1.05	1.54					1		1							1			1	1	17.52	22.45	81%	16,280
	09:00	78.72	71.66	1.08	5.98					1		1							1			1	1	19.64	21.82	78%	15,977
	10:00	81.16	70.20	1.10	9.86					1		1							1			1	1	21.10	21.39	77%	15,770
	11:00	81.74	69.14	1.40	11.20					1		1							1			1	1	22.16	21.16	76%	15,622
	12:00	81.44	67.68	1.99	11.77					1		1							1			1	1	23.62	20.90	74%	15,416
	13:00	81.01	68.20	2.61	10.20					1		1							1			1	1	23.10	21.25	75%	15,490
	14:00	80.69	70.75	2.85	7.10					1		1							1			1	1	20.55	22.08	77%	15,848
	15:00	82.08	75.11	2.86	4.12					1		1							1			1	1	16.19	23.39	82%	16,471
	16:00	85.71	80.43	2.98	2.30					1		1							1			1	1	10.87	25.02	88%	17,261
	17:00	93.64	90.61	2.69	0.33					1		1			1				1			1	1	33.59	27.99	73%	27,450
	18:00	98.27	95.18	3.09	0.00					1		1			1				1			1	1	29.02	29.48	77%	28,291
	19:00	98.82	94.88	3.94	0.00					1		1			1				1			1	1	29.32	29.65	76%	28,236
	20:00	96.78	86.41	10.37	0.00					1		1			1				1			1	1	37.79	29.03	70%	26,630
	21:00	92.05	77.25	14.80	0.00					1		1			1				1			1	1	14.05	27.62	85%	16,785
	22:00	83.68	67.64	16.05	0.00					1		1			1				1			1	1	23.66	25.11	74%	15,411
	23:00	74.35	55.80	18.54	0.00					1		1			1				1			1	1	18.40	22.30	75%	13,969
		1824.70 MWh																				ΑΩΛ: 10.81		408,951 €			

Παρατηρήσεις:

Μπορεί να γίνει εναλλαγή μεταξύ μονάδων με όμοια χαρακτηριστικά κατά την κρίση του ΑΣΠ, ανάλογα και με τις συμπληρωμένες ώρες λειτουργίας τους.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης