

ΗΣ ΡΟΔΟΥ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα																	Tuesday, January 20, 2026							
Αποδιδόμενη Ισχύς (ΜW)						14.50	10.50	18.00	18.00	18.00	17.50	22.00	20.00	27.00	32.90	27.90	17.10	17.10	17.10	17.10	17.10	17.10	17.10				
ΤΕ (ΜW)						6.00	4.90	14.00	14.00	14.00	14.00	5.00	5.00	5.00	6.60	6.60	6.80	6.80	6.80	6.80	6.80	6.80					
Η Ε Ρ Ε Τ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου φορτίου (ΜW)	Πρόβλεψη Θερμικής Παραγωγής (ΜW)	Πρόβλεψη Αιολικής Παραγωγής (ΜW)	Πρόβλεψη Φωτοβολταϊκής Παραγωγής (ΜW)	ΑΗΣ ΣΟΡΑΝΗΣ						ΘΗΣ Ν.ΡΟΔΟΥ							Στρεφόμενη σφεδρεία (ΜW)	Set-point Αιολικών Πάρκων (ΜW)	Μέση φόρτιση Μονάδων ΑΣΠ (% επί της αποδιδόμενης)	Κόστος καυσίμου (€)					
						ΑΤΗ 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	AEP 1	AEP 2	AEP 3	AEP 4	AEP 5	AEP 6	DIESEL 1	DIESEL 2					DIESEL 3	DIESEL 4	DIESEL 5	DIESEL 6	DIESEL 7
Tuesday, January 20, 2026	00:00	62.74	45.75	16.98	0.00			1				1				1	1							28.45	18.82	62%	12,492
	01:00	57.12	39.98	17.13	0.00			1				1				1	1							34.22	17.13	54%	11,573
	02:00	53.75	37.63	16.13	0.00			1				1				1	1							36.57	16.13	51%	11,171
	03:00	52.32	36.63	15.70	0.00			1				1				1	1							37.57	15.70	49%	10,994
	04:00	53.56	37.49	16.07	0.00			1				1				1	1							36.71	16.07	51%	11,147
	05:00	57.31	40.12	17.19	0.00			1				1				1	1							34.08	17.19	54%	11,596
	06:00	65.35	45.74	19.60	0.00			1				1				1	1							28.46	19.60	62%	12,491
	07:00	74.80	51.99	22.28	0.53			1				1				1	1							22.21	22.28	70%	13,416
	08:00	78.14	55.11	18.88	4.15			1				1				1	1							19.09	22.20	74%	13,869
	09:00	81.03	63.44	9.37	8.23			1				1				1	1		1					27.86	21.84	69%	14,893
	10:00	82.56	65.48	6.33	10.76			1				1				1	1		1					25.82	21.54	72%	15,108
	11:00	84.14	67.78	4.49	11.87			1				1				1	1		1					23.52	21.68	74%	15,431
	12:00	83.97	68.43	3.35	12.19			1				1				1	1		1					22.87	21.53	75%	15,522
	13:00	83.20	69.05	3.36	10.79			1				1				1	1		1					22.25	21.72	76%	15,609
	14:00	82.74	70.19	4.33	8.21			1				1				1	1		1					21.11	22.36	77%	15,770
	15:00	82.79	68.74	8.36	5.68			1				1				1	1		1					22.56	23.13	75%	15,565
	16:00	86.83	68.50	15.87	2.46			1				1				1	1		1					22.80	25.31	75%	15,531
	17:00	97.85	72.63	24.99	0.24			1				1				1	1		1					18.67	29.28	80%	16,115
	18:00	103.42	72.39	31.03	0.00			1				1				1	1		1					18.91	31.03	79%	16,081
	19:00	103.42	72.40	31.03	0.00			1				1				1	1		1					18.90	31.03	79%	16,082
	20:00	100.11	70.08	30.03	0.00			1				1				1	1		1					21.22	30.03	77%	15,753
	21:00	93.35	65.35	28.01	0.00			1				1				1	1		1					25.95	28.01	72%	15,090
	22:00	84.11	58.87	25.23	0.00			1				1					1		1					15.33	25.23	79%	14,418
	23:00	73.23	51.26	21.97	0.00			1				1					1		1					22.94	21.97	69%	13,311
		1877.83 MWh																						ΑΩΛ: 11.07		339,029 €	

Παρατηρήσεις:

Μπορεί να γίνει εναλλαγή μεταξύ μονάδων με όμοια χαρακτηριστικά κατά την κρίση του ΑΣΠ, ανάλογα και με τις συμπληρωμένες ώρες λειτουργίας τους.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης