

ΗΣ ΡΟΔΟΥ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα																		Wednesday, January 21, 2026			
Αποδιδόμενη Ισχύς (ΜW)			14.50	10.50	18.00	18.00	18.00	17.50	22.00	20.00	27.00	32.90	27.90	17.10	17.10	17.10	17.10	17.10	17.10	17.10				
ΤΕ (ΜW)			6.00	4.90	14.00	14.00	14.00	14.00	5.00	5.00	5.00	5.60	6.60	6.80	6.80	6.80	6.80	6.80	6.80	6.80				
ΑΡΧΗ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (ΜW)	Πρόβλεψη Θερμικής Παραγωγής (ΜW)	Πρόβλεψη Αιολικής Παραγωγής (ΜW)	Πρόβλεψη Φωτοβολταϊκής Παραγωγής (ΜW)	ΑΗΣ ΣΟΡΩΝΗΣ						ΘΗΣ Ν.ΡΟΔΟΥ							Στρεφόμενη εφεδρεία (ΜW)	Set-point Αιολικών Πάρκων (ΜW)	Μέση φόρτιση Μονάδων ΑΣΠ (% επί της αποδιδόμενης)	Κόστος καυσίμου (€)		
						ΑΤΜ 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	AEP 1	AEP 2	AEP 3	AEP 4	AEP 5	AEP 6	DIESEL 1	DIESEL 2					DIESEL 3	DIESEL 4
Wednesday, January 21, 2026	00:00	66.27	46.39	19.88	0.00			1						1	1						27.81	19.88	63%	12,588
	01:00	61.00	42.70	18.30	0.00			1						1	1						31.50	18.30	58%	12,017
	02:00	57.93	40.55	17.38	0.00			1						1	1						33.65	17.38	55%	11,668
	03:00	56.48	39.54	16.94	0.00			1						1	1						34.66	16.94	53%	11,499
	04:00	57.13	39.99	17.14	0.00			1						1	1						34.21	17.14	54%	11,575
	05:00	60.20	42.14	18.06	0.00			1						1	1						32.06	18.06	57%	11,927
	06:00	67.27	47.09	20.18	0.00			1						1	1						27.11	20.18	63%	12,694
	07:00	76.47	53.32	22.85	0.30			1						1	1						20.88	22.85	72%	13,610
	08:00	81.60	55.59	23.83	2.18			1						1	1						18.61	23.83	75%	13,939
	09:00	85.18	56.41	24.18	4.59			1						1	1						17.79	24.18	76%	14,058
	10:00	86.40	55.81	23.92	6.67			1						1	1						18.39	23.92	75%	13,971
	11:00	87.58	56.58	24.25	6.74			1						1	1						17.62	24.25	76%	14,083
	12:00	87.54	57.03	24.44	6.07			1						1	1						17.17	24.44	77%	14,148
	13:00	86.43	57.78	24.76	3.89			1						1	1						16.42	24.76	78%	14,258
	14:00	85.37	56.38	24.16	4.83			1						1	1						17.82	24.16	76%	14,053
	15:00	85.59	56.52	24.22	4.85			1						1	1						17.68	24.22	76%	14,074
	16:00	89.36	61.11	26.19	2.06			1						1	1			1			30.19	26.19	67%	14,565
	17:00	99.74	69.67	29.86	0.21			1						1	1			1			21.63	29.86	76%	15,697
	18:00	105.73	74.01	31.72	0.00			1						1	1			1			17.29	31.72	81%	16,313
	19:00	106.87	74.81	32.06	0.00			1						1	1			1			16.49	32.06	82%	16,429
	20:00	105.30	73.71	31.59	0.00			1						1	1			1			17.59	31.59	81%	16,270
	21:00	99.23	69.46	29.77	0.00			1						1	1			1			21.84	29.77	76%	15,667
	22:00	89.02	62.31	26.70	0.00			1						1	1			1			28.99	26.70	68%	14,664
	23:00	73.14	51.20	21.94	0.00			1						1	1			1			23.00	21.94	69%	13,302
		1956.83 MWh																				ΑΩΛ: 11.76		333,066 €

Παρατηρήσεις:

Μπορεί να γίνει εναλλαγή μεταξύ μονάδων με όμοια χαρακτηριστικά κατά την κρίση του ΑΣΠ, ανάλογα και με τις συμπληρωμένες ώρες λειτουργίας τους.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης