

ΗΣ ΡΟΔΟΥ			Προτεινόμενος ΝΕΠ για την Επόμενη Ημέρα																		Sunday, January 25, 2026					
Αποδιδόμενη Ισχύς (ΜW)			14.50	10.50	18.00	18.00	18.00	17.50	22.00	20.00	27.00	32.90	27.90	17.10	17.10	17.10	17.10	17.10	17.10	17.10						
ΤΕ (ΜW)			6.00	4.90	14.00	14.00	14.00	5.00	5.00	5.00	5.00	5.60	6.60	6.80	6.80	6.80	6.80	6.80	6.80							
ΗΜΕΡΑ	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (ΜW)	Πρόβλεψη Θερμικής Παραγωγής (ΜW)	Πρόβλεψη Αιολικής Παραγωγής (ΜW)	Πρόβλεψη Φωτοβολταϊκής Παραγωγής (ΜW)	ΑΗΣ ΣΟΡΩΝΗΣ						ΘΗΣ Ν.ΡΟΔΟΥ							Στρεφόμενη εφεδρεία (ΜW)	Set-point Αιολικών Πάρκων (ΜW)	Μέση φόρτιση Μονάδων ΑΣΠ (% επί της αποδιδόμενης)	Κόστος καυσίμου (€)				
						ΑΤΜ 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	ΑΕΡ 1	ΑΕΡ 2	ΑΕΡ 3	ΑΕΡ 4	ΑΕΡ 5	ΑΕΡ 6	DIESEL 1	DIESEL 2					DIESEL 3	DIESEL 4	DIESEL 5	DIESEL 6
Sunday, January 25, 2026	00:00	68.93	54.16	14.77	0.00			1								1	1						20.04	20.68	73%	13,801
	01:00	63.61	45.32	18.29	0.00			1								1	1						28.88	19.08	61%	12,425
	02:00	59.38	41.77	17.61	0.00			1								1	1						32.43	17.81	56%	11,868
	03:00	57.29	41.35	15.94	0.00			1								1	1						32.85	17.19	56%	11,800
	04:00	56.95	43.35	13.60	0.00			1								1	1						30.85	17.08	58%	12,119
	05:00	58.67	45.58	13.09	0.00			1								1	1						28.62	17.60	61%	12,466
	06:00	62.90	49.88	13.02	0.00			1								1	1						24.32	18.87	67%	13,108
	07:00	68.81	57.09	11.44	0.27			1						1		1	1						50.01	20.56	53%	21,096
	08:00	75.60	61.67	11.62	2.32			1						1		1	1						45.43	21.99	58%	22,243
	09:00	81.04	62.71	14.02	4.32			1						1		1	1						44.39	23.02	59%	22,497
	10:00	84.45	61.21	15.84	7.40			1						1		1	1						45.89	23.11	57%	22,130
	11:00	85.72	56.25	17.36	12.10			1						1		1	1						50.85	22.08	53%	20,870
	12:00	85.48	57.57	16.69	11.21			1						1		1	1						49.53	22.28	54%	21,214
	13:00	83.80	60.80	14.27	8.73			1						1		1	1						46.30	22.52	57%	22,028
	14:00	82.03	59.89	14.53	7.60			1						1		1	1						47.21	22.33	56%	21,802
	15:00	81.07	58.90	19.45	2.72			1						1		1	1						48.20	23.51	55%	21,553
	16:00	82.98	61.49	20.14	1.34			1						1		1	1						45.61	24.49	57%	22,200
	17:00	89.22	67.11	21.70	0.41			1						1		1	1						39.99	26.64	63%	23,535
	18:00	94.96	70.60	24.36	0.00			1						1		1	1						36.50	28.49	66%	24,318
	19:00	97.32	70.93	26.39	0.00			1						1		1	1						36.17	29.20	66%	24,392
	20:00	96.41	69.36	27.05	0.00			1						1		1	1						37.74	28.92	65%	24,044
	21:00	91.83	64.45	27.38	0.00			1						1		1	1						42.65	27.55	60%	22,915
	22:00	83.87	58.71	25.16	0.00			1						1		1	1						48.39	25.16	55%	21,505
	23:00	75.14	52.60	22.54	0.00			1						1		1	1						54.50	22.54	49%	19,891
		1867.46 MWh																				ΑΩΛ: 11.11		465,820 €		

Παρατηρήσεις:

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης