

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Τετάρτη, 4 Φεβρουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 4 Φεβρουαρίου 2026	00:00	76	1						
	01:00	72	1						
	02:00	70	1						
	03:00	70	1						
	04:00	71	1						
	05:00	74	1						
	06:00	78	1						
	07:00	81	1						
	08:00	85	1						
	09:00	86	1						
	10:00	86	1						
	11:00	84	1						
	12:00	81	1						
	13:00	79	1						
	14:00	78	1						
	15:00	79	1						
	16:00	83	1						
	17:00	94	1		1				
	18:00	106	1		1				
	19:00	109	1		1				
	20:00	108	1		1				
	21:00	103	1		1				
	22:00	92	1		1				
	23:00	78	1						

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Πέμπτη, 5 Φεβρουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 5 Φεβρουαρίου 2026	00:00	75	1						
	01:00	72	1						
	02:00	70	1						
	03:00	70	1						
	04:00	71	1						
	05:00	73	1						
	06:00	75	1						
	07:00	79	1						
	08:00	83	1						
	09:00	85	1						
	10:00	87	1						
	11:00	87	1						
	12:00	86	1						
	13:00	84	1						
	14:00	83	1						
	15:00	82	1						
	16:00	85	1						
	17:00	95	1		1				
	18:00	103	1		1				
	19:00	108	1		1				
	20:00	106	1		1				
	21:00	100	1		1				
	22:00	89	1						
	23:00	76	1						

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Παρασκευή, 6 Φεβρουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 6 Φεβρουαρίου 2026	00:00	76	1						
	01:00	73	1						
	02:00	71	1						
	03:00	71	1						
	04:00	71	1						
	05:00	73	1						
	06:00	75	1						
	07:00	79	1						
	08:00	83	1						
	09:00	84	1						
	10:00	84	1						
	11:00	83	1						
	12:00	83	1						
	13:00	82	1						
	14:00	79	1						
	15:00	77	1						
	16:00	78	1						
	17:00	87	1						
	18:00	99	1		1				
	19:00	104	1		1				
	20:00	101	1		1				
	21:00	96	1		1				
	22:00	87	1						
	23:00	75	1						

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Σάββατο, 7 Φεβρουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ρ Α Τ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 7 Φεβρουαρίου 2026	00:00	74	1						
	01:00	70	1						
	02:00	68	1						
	03:00	67	1						
	04:00	67	1						
	05:00	70	1						
	06:00	72	1						
	07:00	76	1						
	08:00	77	1						
	09:00	80	1						
	10:00	82	1						
	11:00	83	1						
	12:00	83	1						
	13:00	82	1						
	14:00	80	1						
	15:00	79	1						
	16:00	79	1						
	17:00	85	1						
	18:00	96	1		1				
	19:00	100	1		1				
	20:00	98	1		1				
	21:00	93	1		1				
	22:00	85	1						
	23:00	75	1						

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Κυριακή, 8 Φεβρουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 8 Φεβρουαρίου 2026	00:00	71	1						
	01:00	65	1						
	02:00	62	1						
	03:00	61	1						
	04:00	62	1						
	05:00	64	1						
	06:00	68	1						
	07:00	72	1						
	08:00	76	1						
	09:00	79	1						
	10:00	81	1						
	11:00	84	1						
	12:00	85	1						
	13:00	83	1						
	14:00	81	1						
	15:00	81	1						
	16:00	83	1						
	17:00	90	1		1				
	18:00	97	1		1				
	19:00	99	1		1				
	20:00	98	1		1				
	21:00	94	1		1				
	22:00	87	1						
	23:00	77	1						

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Δευτέρα, 9 Φεβρουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 9 Φεβρουαρίου 2026	00:00	70	1						
	01:00	67	1						
	02:00	66	1						
	03:00	67	1						
	04:00	69	1						
	05:00	72	1						
	06:00	77	1						
	07:00	80	1						
	08:00	82	1						
	09:00	83	1						
	10:00	83	1						
	11:00	84	1						
	12:00	84	1						
	13:00	83	1						
	14:00	83	1						
	15:00	84	1						
	16:00	89	1						
	17:00	97	1		1				
	18:00	106	1		1				
	19:00	111	1		1				
	20:00	111	1		1				
	21:00	106	1		1				
	22:00	98	1		1				
	23:00	86	1						

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Τρίτη, 10 Φεβρουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 10 Φεβρουαρίου 2026	00:00	76	1						
	01:00	72	1						
	02:00	70	1						
	03:00	70	1						
	04:00	72	1						
	05:00	76	1						
	06:00	81	1						
	07:00	87	1						
	08:00	90	1						
	09:00	91	1						
	10:00	91	1						
	11:00	89	1						
	12:00	87	1						
	13:00	86	1						
	14:00	89	1						
	15:00	95	1		1				
	16:00	103	1		1				
	17:00	113	1		1				
	18:00	122	1		1				
	19:00	127	1		1				
	20:00	125	1		1				
	21:00	118	1		1				
	22:00	106	1		1				
	23:00	90	1						

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης