

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Τετάρτη, 11 Φεβρουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 11 Φεβρουαρίου 2026	00:00	66	1						
	01:00	62	1						
	02:00	60	1						
	03:00	60	1						
	04:00	61	1						
	05:00	64	1						
	06:00	66	1						
	07:00	70	1						
	08:00	73	1						
	09:00	75	1						
	10:00	75	1						
	11:00	73	1						
	12:00	72	1						
	13:00	72	1						
	14:00	71	1						
	15:00	70	1						
	16:00	74	1						
	17:00	80	1						
	18:00	93	1			1			
	19:00	104	1			1			
	20:00	100	1			1			
	21:00	92	1			1			
	22:00	79	1						
	23:00	67	1						

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Πέμπτη, 12 Φεβρουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
01:00	64	1							
02:00	62	1							
03:00	61	1							
04:00	62	1							
05:00	64	1							
06:00	68	1							
07:00	71	1							
08:00	73	1							
09:00	75	1							
10:00	77	1							
11:00	78	1							
12:00	77	1							
13:00	75	1							
14:00	73	1							
15:00	73	1							
16:00	76	1							
17:00	82	1		1					
18:00	93	1		1					
19:00	103	1		1					
20:00	101	1		1					
21:00	90	1		1					
22:00	79	1							
23:00	67	1							

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Παρασκευή, 13 Φεβρουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 13 Φεβρουαρίου 2026	00:00	68	1						
	01:00	64	1						
	02:00	62	1						
	03:00	62	1						
	04:00	63	1						
	05:00	64	1						
	06:00	67	1						
	07:00	72	1						
	08:00	75	1						
	09:00	76	1						
	10:00	77	1						
	11:00	76	1						
	12:00	75	1						
	13:00	72	1						
	14:00	72	1						
	15:00	72	1						
	16:00	77	1						
	17:00	82	1		1				
	18:00	94	1		1				
	19:00	102	1		1				
	20:00	99	1		1				
	21:00	91	1		1				
	22:00	80	1						
	23:00	68	1						

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Σάββατο, 14 Φεβρουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ε Ρ Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
			Σάββατο, 14 Φεβρουαρίου 2026	00:00	69	1			
01:00	64	1							
02:00	61	1							
03:00	60	1							
04:00	60	1							
05:00	62	1							
06:00	66	1							
07:00	72	1							
08:00	72	1							
09:00	74	1							
10:00	75	1							
11:00	76	1							
12:00	75	1							
13:00	73	1							
14:00	71	1							
15:00	70	1							
16:00	71	1							
17:00	77	1							
18:00	91	1			1				
19:00	97	1			1				
20:00	94	1			1				
21:00	88	1			1				
22:00	79	1							
23:00	70	1							

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Κυριακή, 15 Φεβρουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 15 Φεβρουαρίου 2026	00:00	66	1						
	01:00	61	1						
	02:00	58	1						
	03:00	57	1						
	04:00	58	1						
	05:00	60	1						
	06:00	64	1						
	07:00	68	1						
	08:00	70	1						
	09:00	73	1						
	10:00	76	1						
	11:00	76	1						
	12:00	75	1						
	13:00	73	1						
	14:00	72	1						
	15:00	72	1						
	16:00	72	1						
	17:00	76	1						
	18:00	87	1			1			
	19:00	95	1			1			
	20:00	94	1			1			
	21:00	88	1			1			
	22:00	82	1			1			
	23:00	74	1						

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Δευτέρα, 16 Φεβρουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ρ Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 16 Φεβρουαρίου 2026	00:00	66	1						
	01:00	63	1						
	02:00	62	1						
	03:00	62	1						
	04:00	64	1						
	05:00	67	1						
	06:00	70	1						
	07:00	74	1						
	08:00	78	1						
	09:00	79	1						
	10:00	80	1						
	11:00	79	1						
	12:00	78	1						
	13:00	77	1						
	14:00	75	1						
	15:00	75	1						
	16:00	76	1						
	17:00	82	1		1				
	18:00	94	1		1				
	19:00	104	1		1				
	20:00	102	1		1				
	21:00	97	1		1				
	22:00	87	1		1				
	23:00	75	1						

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Τρίτη, 17 Φεβρουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 17 Φεβρουαρίου 2026	00:00	70	1						
	01:00	66	1						
	02:00	65	1						
	03:00	65	1						
	04:00	66	1						
	05:00	69	1						
	06:00	74	1						
	07:00	77	1						
	08:00	81	1		1				
	09:00	83	1		1				
	10:00	84	1		1				
	11:00	82	1		1				
	12:00	80	1						
	13:00	79	1						
	14:00	78	1						
	15:00	78	1						
	16:00	82	1		1				
	17:00	91	1		1				
	18:00	105	1		1				
	19:00	115	1		1				
	20:00	114	1		1				
	21:00	108	1		1				
	22:00	97	1		1				
	23:00	82	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης