


ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Τετάρτη, 18 Φεβρουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 18 Φεβρουαρίου 2026	00:00	72	1						
	01:00	68	1						
	02:00	66	1						
	03:00	65	1						
	04:00	67	1						
	05:00	69	1						
	06:00	75	1						
	07:00	78	1		1				
	08:00	81	1		1				
	09:00	83	1		1				
	10:00	83	1		1				
	11:00	81	1		1				
	12:00	80	1		1				
	13:00	77	1		1				
	14:00	76	1		1				
	15:00	78	1		1				
	16:00	82	1		1				
	17:00	88	1		1				
	18:00	104	1		1				
	19:00	108	1		1				
	20:00	107	1		1				
	21:00	100	1		1				
	22:00	90	1		1				
	23:00	77	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Πέμπτη, 19 Φεβρουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
01:00	70	1							
02:00	68	1							
03:00	67	1							
04:00	67	1							
05:00	70	1							
06:00	74	1							
07:00	80	1		1					
08:00	83	1		1					
09:00	85	1		1					
10:00	84	1		1					
11:00	82	1		1					
12:00	79	1		1					
13:00	75	1		1					
14:00	75	1		1					
15:00	74	1		1					
16:00	78	1		1					
17:00	83	1		1					
18:00	103	1		1					
19:00	110	1		1					
20:00	111	1		1					
21:00	107	1		1					
22:00	95	1		1					
23:00	79	1		1					



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Παρασκευή, 20 Φεβρουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 20 Φεβρουαρίου 2026	00:00	75	1						
	01:00	70	1						
	02:00	66	1						
	03:00	65	1						
	04:00	66	1						
	05:00	69	1						
	06:00	73	1						
	07:00	77	1		1				
	08:00	79	1		1				
	09:00	80	1		1				
	10:00	81	1		1				
	11:00	80	1		1				
	12:00	79	1		1				
	13:00	77	1		1				
	14:00	77	1		1				
	15:00	76	1		1				
	16:00	78	1		1				
	17:00	85	1		1				
	18:00	101	1		1				
	19:00	108	1		1				
	20:00	107	1		1				
	21:00	102	1		1				
	22:00	90	1		1				
	23:00	75	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Σάββατο, 21 Φεβρουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ε Ρ Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 21 Φεβρουαρίου 2026	00:00	72	1						
	01:00	68	1						
	02:00	66	1						
	03:00	65	1						
	04:00	66	1						
	05:00	68	1						
	06:00	72	1						
	07:00	75	1						
	08:00	78	1		1				
	09:00	80	1		1				
	10:00	81	1		1				
	11:00	81	1		1				
	12:00	80	1		1				
	13:00	79	1		1				
	14:00	77	1		1				
	15:00	77	1		1				
	16:00	82	1		1				
	17:00	92	1		1				
	18:00	104	1		1				
	19:00	110	1		1				
	20:00	107	1		1				
	21:00	100	1		1				
	22:00	87	1		1				
	23:00	74	1						

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Κυριακή, 22 Φεβρουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
01:00	68	1							
02:00	65	1							
03:00	63	1							
04:00	63	1							
05:00	66	1							
06:00	71	1							
07:00	77	1		1					
08:00	82	1		1					
09:00	84	1		1					
10:00	86	1		1					
11:00	85	1		1					
12:00	85	1		1					
13:00	86	1		1					
14:00	87	1		1					
15:00	89	1		1					
16:00	95	1		1					
17:00	103	1		1					
18:00	116	1		1					
19:00	119	1		1					
20:00	117	1		1					
21:00	108	1		1					
22:00	95	1		1					
23:00	81	1		1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Δευτέρα, 23 Φεβρουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ρ Ε Τ Η Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 23 Φεβρουαρίου 2026	00:00	76	1						
	01:00	72	1						
	02:00	70	1						
	03:00	71	1						
	04:00	73	1						
	05:00	77	1		1				
	06:00	82	1		1				
	07:00	87	1		1				
	08:00	90	1		1				
	09:00	91	1		1				
	10:00	90	1		1				
	11:00	88	1		1				
	12:00	86	1		1				
	13:00	85	1		1				
	14:00	86	1		1				
	15:00	89	1		1				
	16:00	95	1		1				
	17:00	106	1		1				
	18:00	121	1		1				
	19:00	126	1		1				
	20:00	125	1		1				
	21:00	117	1		1				
	22:00	103	1		1				
	23:00	87	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Τρίτη, 24 Φεβρουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 24 Φεβρουαρίου 2026	00:00	81	1						
	01:00	77	1						
	02:00	75	1						
	03:00	75	1						
	04:00	77	1						
	05:00	80	1						
	06:00	84	1		1				
	07:00	88	1		1				
	08:00	90	1		1				
	09:00	91	1		1				
	10:00	91	1		1				
	11:00	90	1		1				
	12:00	90	1		1				
	13:00	88	1		1				
	14:00	87	1		1				
	15:00	88	1		1				
	16:00	92	1		1				
	17:00	101	1		1				
	18:00	119	1		1				
	19:00	129	1		1				
	20:00	128	1		1				
	21:00	120	1		1				
	22:00	105	1		1				
	23:00	87	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης