

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Τετάρτη, 25 Φεβρουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ε Ρ Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
01:00	67	1							
02:00	66	1							
03:00	65	1							
04:00	67	1							
05:00	70	1							
06:00	70	1							
07:00	76	1							
08:00	78	1							
09:00	80	1							
10:00	80	1							
11:00	80	1							
12:00	77	1							
13:00	75	1							
14:00	72	1							
15:00	74	1							
16:00	78	1							
17:00	85	1		1					
18:00	101	1		1					
19:00	105	1		1					
20:00	107	1		1					
21:00	102	1		1					
22:00	93	1		1					
23:00	79	1							

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Πέμπτη, 26 Φεβρουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 26 Φεβρουαρίου 2026	00:00	74	1						
	01:00	69	1						
	02:00	66	1						
	03:00	65	1						
	04:00	66	1						
	05:00	69	1						
	06:00	73	1						
	07:00	79	1						
	08:00	81	1						
	09:00	81	1						
	10:00	80	1						
	11:00	78	1						
	12:00	76	1						
	13:00	72	1						
	14:00	71	1						
	15:00	70	1						
	16:00	76	1						
	17:00	85	1		1				
	18:00	102	1		1				
	19:00	111	1		1				
	20:00	115	1		1				
	21:00	109	1		1				
	22:00	99	1		1				
	23:00	84	1		1				



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Παρασκευή, 27 Φεβρουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 27 Φεβρουαρίου 2026	00:00	79	1						
	01:00	73	1						
	02:00	68	1						
	03:00	66	1						
	04:00	67	1						
	05:00	70	1						
	06:00	74	1						
	07:00	80	1						
	08:00	84	1		1				
	09:00	85	1		1				
	10:00	85	1		1				
	11:00	82	1		1				
	12:00	79	1						
	13:00	77	1						
	14:00	78	1						
	15:00	80	1						
	16:00	86	1		1				
	17:00	97	1		1				
	18:00	111	1		1				
	19:00	120	1		1				
	20:00	121	1		1				
	21:00	115	1		1				
	22:00	102	1		1				
	23:00	85	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Σάββατο, 28 Φεβρουαρίου 2026				
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 28 Φεβρουαρίου 2026	00:00	81	1		1				
	01:00	74	1						
	02:00	70	1						
	03:00	68	1						
	04:00	68	1						
	05:00	71	1						
	06:00	75	1						
	07:00	81	1						
	08:00	85	1		1				
	09:00	88	1		1				
	10:00	88	1		1				
	11:00	86	1		1				
	12:00	84	1		1				
	13:00	83	1		1				
	14:00	84	1		1				
	15:00	87	1		1				
	16:00	94	1		1				
	17:00	104	1		1				
	18:00	117	1		1				
	19:00	125	1		1				
	20:00	124	1		1				
	21:00	116	1		1				
	22:00	102	1		1				
	23:00	85	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Κυριακή, 1 Μαρτίου 2026				
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
			Κυριακή, 1 Μαρτίου 2026	00:00	83	1		1	
	01:00	77	1						
	02:00	72	1						
	03:00	70	1						
	04:00	70	1						
	05:00	73	1						
	06:00	78	1						
	07:00	83	1		1				
	08:00	86	1		1				
	09:00	90	1		1				
	10:00	90	1		1				
	11:00	89	1		1				
	12:00	87	1		1				
	13:00	86	1		1				
	14:00	87	1		1				
	15:00	92	1		1				
	16:00	100	1		1				
	17:00	109	1		1				
	18:00	120	1		1				
	19:00	128	1		1				
	20:00	125	1		1				
	21:00	117	1		1				
	22:00	104	1		1				
	23:00	88	1		1				


Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Δευτέρα, 2 Μαρτίου 2026				
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 2 Μαρτίου 2026	00:00	80	1						
	01:00	76	1						
	02:00	74	1						
	03:00	75	1						
	04:00	77	1						
	05:00	81	1		1				
	06:00	86	1		1				
	07:00	91	1		1				
	08:00	94	1		1				
	09:00	95	1		1				
	10:00	95	1		1				
	11:00	93	1		1				
	12:00	91	1		1				
	13:00	89	1		1				
	14:00	89	1		1				
	15:00	93	1		1				
	16:00	100	1		1				
	17:00	112	1		1				
	18:00	126	1		1				
	19:00	133	1		1				
	20:00	132	1		1				
	21:00	124	1		1				
	22:00	110	1		1				
	23:00	94	1		1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Προτεινόμενος ΗΕΠ			Τρίτη, 3 Μαρτίου 2026				
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 3 Μαρτίου 2026	00:00	85	1		1				
	01:00	81	1		1				
	02:00	79	1						
	03:00	79	1						
	04:00	81	1						
	05:00	83	1		1				
	06:00	88	1		1				
	07:00	92	1		1				
	08:00	94	1		1				
	09:00	94	1		1				
	10:00	94	1		1				
	11:00	92	1		1				
	12:00	90	1		1				
	13:00	88	1		1				
	14:00	87	1		1				
	15:00	89	1		1				
	16:00	95	1		1				
	17:00	107	1		1				
	18:00	123	1		1				
	19:00	131	1		1				
	20:00	132	1		1				
	21:00	124	1		1				
	22:00	111	1		1				
	23:00	94	1		1				



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης