

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Τετάρτη, 18 Φεβρουαρίου 2026			
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
01:00	0,839	1						
02:00	0,835	1						
03:00	0,838	1						
04:00	0,874	1						
05:00	0,887	1						
06:00	0,926	1	1					
07:00	0,946	1	1					
08:00	0,932	1	1					
09:00	0,868	1						
10:00	0,829	1						
11:00	0,825	1						
12:00	0,819	1						
13:00	0,847	1						
14:00	0,854	1						
15:00	0,913	1						
16:00	1,000	1	1					
17:00	1,132	1	1					
18:00	1,273	1	1					
19:00	1,284	1	1					
20:00	1,272	1	1					
21:00	1,252	1	1					
22:00	1,197	1	1					
23:00	1,142	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Πέμπτη, 19 Φεβρουαρίου 2026			
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
01:00	0,863	1						
02:00	0,870	1						
03:00	0,878	1						
04:00	0,887	1						
05:00	0,911	1						
06:00	0,954	1	1					
07:00	0,963	1	1					
08:00	0,935	1	1					
09:00	0,887	1						
10:00	0,822	1						
11:00	0,810	1						
12:00	0,815	1						
13:00	0,835	1						
14:00	0,843	1						
15:00	0,885	1						
16:00	0,958	1	1					
17:00	1,098	1	1					
18:00	1,276	1	1					
19:00	1,301	1	1					
20:00	1,303	1	1					
21:00	1,303	1	1					
22:00	1,254	1	1					
23:00	1,206	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Παρασκευή, 20 Φεβρουαρίου 2026			
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
01:00	0,871	1						
02:00	0,880	1						
03:00	0,886	1						
04:00	0,897	1						
05:00	0,929	1	1					
06:00	0,959	1	1					
07:00	0,991	1	1					
08:00	0,985	1	1					
09:00	0,933	1	1					
10:00	0,918	1	1					
11:00	0,886	1						
12:00	0,854	1						
13:00	0,880	1						
14:00	0,873	1						
15:00	0,936	1	1					
16:00	0,964	1	1					
17:00	1,073	1	1					
18:00	1,247	1	1					
19:00	1,277	1	1					
20:00	1,287	1	1					
21:00	1,299	1	1					
22:00	1,245	1	1					
23:00	1,187	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Σάββατο, 21 Φεβρουαρίου 2026			
Αποδιδόμενη Ισχύς (ΜW)		1,100	1,100	1,100	1,100	0,460	0,460	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (ΜW)	G1	G2	G3	G5	G8	G9
01:00	0,874	1						
02:00	0,878	1						
03:00	0,889	1						
04:00	0,897	1						
05:00	0,909	1						
06:00	0,932	1	1					
07:00	0,954	1	1					
08:00	0,987	1	1					
09:00	0,995	1	1					
10:00	0,926	1	1					
11:00	0,901	1	1					
12:00	0,960	1	1					
13:00	0,972	1	1					
14:00	0,954	1	1					
15:00	1,049	1	1					
16:00	1,064	1	1					
17:00	1,145	1	1					
18:00	1,263	1	1					
19:00	1,296	1	1					
20:00	1,314	1	1					
21:00	1,317	1	1					
22:00	1,269	1	1					
23:00	1,225	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Κυριακή, 22 Φεβρουαρίου 2026			
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
01:00	0,888	1						
02:00	0,899	1						
03:00	0,920	1	1					
04:00	0,947	1	1					
05:00	0,961	1	1					
06:00	0,984	1	1					
07:00	1,008	1	1					
08:00	1,036	1	1					
09:00	1,066	1	1					
10:00	1,097	1	1					
11:00	1,126	1	1					
12:00	1,154	1	1					
13:00	1,050	1	1					
14:00	1,068	1	1					
15:00	1,118	1	1					
16:00	1,136	1	1					
17:00	1,208	1	1					
18:00	1,336	1	1					
19:00	1,361	1	1					
20:00	1,377	1	1					
21:00	1,356	1	1					
22:00	1,301	1	1					
23:00	1,261	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Δευτέρα, 23 Φεβρουαρίου 2026			
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
01:00	0,924	1	1					
02:00	0,930	1	1					
03:00	0,941	1	1					
04:00	0,973	1	1					
05:00	0,988	1	1					
06:00	1,031	1	1					
07:00	1,055	1	1					
08:00	1,027	1	1					
09:00	0,976	1	1					
10:00	0,935	1	1					
11:00	0,908	1						
12:00	0,900	1						
13:00	0,917	1	1					
14:00	0,907	1	1					
15:00	0,978	1	1					
16:00	1,057	1	1					
17:00	1,189	1	1					
18:00	1,361	1	1					
19:00	1,391	1	1					
20:00	1,409	1	1					
21:00	1,385	1	1					
22:00	1,332	1	1					
23:00	1,295	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Τρίτη, 24 Φεβρουαρίου 2026			
Αποδιδόμενη Ισχύς (ΜW)		1,100	1,100	1,100	1,100	0,460	0,460	
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (ΜW)	G1	G2	G3	G5	G8	G9
01:00	0,903	1						
02:00	0,914	1						
03:00	0,925	1	1					
04:00	0,957	1	1					
05:00	0,978	1	1					
06:00	1,023	1	1					
07:00	1,052	1	1					
08:00	1,013	1	1					
09:00	0,958	1	1					
10:00	0,920	1	1					
11:00	0,895	1						
12:00	0,887	1						
13:00	0,907	1						
14:00	0,906	1						
15:00	0,966	1	1					
16:00	1,044	1	1					
17:00	1,170	1	1					
18:00	1,338	1	1					
19:00	1,388	1	1					
20:00	1,412	1	1					
21:00	1,392	1	1					
22:00	1,349	1	1					
23:00	1,318	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης