

ΗΣ ΚΩ-ΚΑΛΥΜΝΟΥ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα								Κυριακή, 22 Φεβρουαρίου 2026												
Αποδιδόμενη Ισχύς (MW)						7,500	10,000	10,000	10,000	13,500	13,500	10,885	9,142	9,142	28,000	1,400	1,800	1,800	5,500	5,500	5,500	8,250
Η Ε Ρ Ε Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	Πρόβλεψη Θερμικής Παραγωγής (MW)	Πρόβλεψη Αιολικής Παραγωγής (MW)	Πρόγραμμα ΥΒΣ Τήλου (MW)	ΑΣΠ Κω										ΑΣΠ Καλύμνου						
						61	62	63	64	65	66	A/Σ 67	A/Σ 632	A/Σ 633	A/Σ 634	MTU 9-11	61	62	63	64	65	66
Κυριακή, 22 Φεβρουαρίου 2026	00:00	25,36	23,50	1,85	0,00					1	1								1			
	01:00	24,33	22,69	1,65	0,00					1	1								1			
	02:00	24,36	23,24	1,12	0,00					1	1	1							1			
	03:00	24,33	21,44	2,89	0,00					1	1								1			
	04:00	24,59	22,42	2,17	0,00					1	1								1			
	05:00	25,15	23,15	2,00	0,00					1	1	1							1			
	06:00	26,69	23,30	3,39	0,00					1	1								1			
	07:00	28,53	22,62	5,92	0,00					1	1								1			
	08:00	28,85	22,82	6,03	0,00					1	1	1							1			
	09:00	28,85	20,41	8,24	0,20					1	1	1							1			
	10:00	28,13	19,00	8,73	0,40					1	1								1			
	11:00	28,53	19,00	9,13	0,40					1	1								1			
	12:00	28,42	19,00	9,02	0,40					1	1	1							1			
	13:00	27,77	19,00	8,37	0,40					1	1								1			
	14:00	28,14	19,20	8,74	0,20					1	1	1							1			
	15:00	29,37	19,40	9,97	0,00					1	1	1							1			
	16:00	32,15	20,89	11,25	0,00					1	1	1							1			
	17:00	36,72	24,85	11,87	0,00				1	1	1								1			
	18:00	39,30	26,25	13,06	0,00				1	1	1	1							1			
	19:00	40,61	27,40	13,21	0,00				1	1	1	1							1			
	20:00	40,02	27,01	13,01	0,00				1	1	1	1							1			
	21:00	37,74	25,10	12,64	0,00				1	1	1	1							1			
	22:00	35,55	24,85	10,70	0,00				1	1	1	1							1			
	23:00	32,99	21,44	11,55	0,00				1		1	1							1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης