

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Προτεινόμενος ΗΕΠ		Πέμπτη, 5 Μαρτίου 2026					
Αποδιδόμενη Ισχύς (kW)		80	80	80	90	200	180	400	
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
			Πέμπτη, 5 Μαρτίου 2026	00:00	65				
01:00	64							1	
02:00	62							1	
03:00	62							1	
04:00	60							1	
05:00	63							1	
06:00	62							1	
07:00	63							1	
08:00	58							1	
09:00	61							1	
10:00	58							1	
11:00	56							1	
12:00	58							1	
13:00	58							1	
14:00	55							1	
15:00	55							1	
16:00	62							1	
17:00	64							1	
18:00	72							1	
19:00	86							1	
20:00	89							1	
21:00	84							1	
22:00	78							1	
23:00	71							1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Προτεινόμενος ΗΕΠ		Παρασκευή, 6 Μαρτίου 2026					
Αποδιδόμενη Ισχύς (kW)		80	80	80	90	200	180	400	
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 6 Μαρτίου 2026	00:00	65						1	
	01:00	64						1	
	02:00	61						1	
	03:00	63						1	
	04:00	62						1	
	05:00	62						1	
	06:00	62						1	
	07:00	64						1	
	08:00	57						1	
	09:00	61						1	
	10:00	57						1	
	11:00	55						1	
	12:00	57						1	
	13:00	58						1	
	14:00	54						1	
	15:00	53						1	
	16:00	58						1	
	17:00	63						1	
	18:00	69						1	
	19:00	86						1	
	20:00	89						1	
	21:00	84						1	
	22:00	78						1	
	23:00	72						1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ		Σάββατο, 7 Μαρτίου 2026				
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Σάββατο, 7 Μαρτίου 2026	00:00	64						1	
	01:00	64						1	
	02:00	61						1	
	03:00	62						1	
	04:00	60						1	
	05:00	61						1	
	06:00	62						1	
	07:00	63						1	
	08:00	60						1	
	09:00	60						1	
	10:00	56						1	
	11:00	55						1	
	12:00	56						1	
	13:00	57						1	
	14:00	55						1	
	15:00	56						1	
	16:00	57						1	
	17:00	63						1	
	18:00	67						1	
	19:00	84						1	
	20:00	87						1	
	21:00	81						1	
	22:00	76						1	
	23:00	71						1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Προτεινόμενος ΗΕΠ		Κυριακή, 8 Μαρτίου 2026					
Αποδιδόμενη Ισχύς (kW)		80	80	80	90	200	180	400	
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 8 Μαρτίου 2026	00:00	64						1	
	01:00	63						1	
	02:00	60						1	
	03:00	60						1	
	04:00	61						1	
	05:00	62						1	
	06:00	64						1	
	07:00	62						1	
	08:00	59						1	
	09:00	61						1	
	10:00	58						1	
	11:00	58						1	
	12:00	59						1	
	13:00	57						1	
	14:00	55						1	
	15:00	56						1	
	16:00	56						1	
	17:00	62						1	
	18:00	70						1	
	19:00	83						1	
	20:00	84						1	
	21:00	80						1	
	22:00	77						1	
	23:00	72						1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ		Δευτέρα, 9 Μαρτίου 2026				
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 9 Μαρτίου 2026	00:00	66						1	
	01:00	63						1	
	02:00	60						1	
	03:00	63						1	
	04:00	61						1	
	05:00	63						1	
	06:00	65						1	
	07:00	64						1	
	08:00	59						1	
	09:00	58						1	
	10:00	54						1	
	11:00	54						1	
	12:00	55						1	
	13:00	56						1	
	14:00	54						1	
	15:00	53						1	
	16:00	56						1	
	17:00	60						1	
	18:00	71						1	
	19:00	84						1	
	20:00	86						1	
	21:00	82						1	
	22:00	75						1	
	23:00	71						1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Προτεινόμενος ΗΕΠ		Τρίτη, 10 Μαρτίου 2026					
Αποδιδόμενη Ισχύς (kW)		80	80	80	90	200	180	400	
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
			Τρίτη, 10 Μαρτίου 2026	00:00	64				
01:00	60							1	
02:00	59							1	
03:00	61							1	
04:00	60							1	
05:00	61							1	
06:00	64							1	
07:00	63							1	
08:00	60							1	
09:00	61							1	
10:00	62							1	
11:00	58							1	
12:00	59							1	
13:00	58							1	
14:00	57							1	
15:00	56							1	
16:00	61							1	
17:00	65							1	
18:00	75							1	
19:00	87							1	
20:00	87							1	
21:00	83							1	
22:00	76							1	
23:00	71							1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ		Τετάρτη, 11 Μαρτίου 2026				
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
			Τετάρτη, 11 Μαρτίου 2026	00:00	64				
01:00	62							1	
02:00	62							1	
03:00	63							1	
04:00	61							1	
05:00	62							1	
06:00	59							1	
07:00	62							1	
08:00	59							1	
09:00	58							1	
10:00	56							1	
11:00	54							1	
12:00	53							1	
13:00	52							1	
14:00	51							1	
15:00	50							1	
16:00	54							1	
17:00	61							1	
18:00	71							1	
19:00	81							1	
20:00	82							1	
21:00	78							1	
22:00	72							1	
23:00	68							1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης