

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Προτεινόμενος ΗΕΠ		Πέμπτη, 12 Μαρτίου 2026					
Αποδιδόμενη Ισχύς (kW)		80	80	80	90	200	180	400	
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 12 Μαρτίου 2026	00:00	63				1			
	01:00	62				1			
	02:00	59				1			
	03:00	61				1			
	04:00	58				1			
	05:00	60				1			
	06:00	59				1			
	07:00	61				1			
	08:00	55				1			
	09:00	60				1			
	10:00	58				1			
	11:00	56				1			
	12:00	59				1			
	13:00	56				1			
	14:00	54				1			
	15:00	54				1			
	16:00	58				1			
	17:00	61				1			
	18:00	69				1			
	19:00	83							1
	20:00	85							1
	21:00	80							1
	22:00	74							1
	23:00	69							1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Προτεινόμενος ΗΕΠ		Παρασκευή, 13 Μαρτίου 2026					
Αποδιδόμενη Ισχύς (kW)		80	80	80	90	200	180	400	
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
01:00	62			1					
02:00	58			1					
03:00	61			1					
04:00	60			1					
05:00	60			1					
06:00	60			1					
07:00	61			1					
08:00	54			1					
09:00	60			1					
10:00	56			1					
11:00	54			1					
12:00	56			1					
13:00	57			1					
14:00	53			1					
15:00	52			1					
16:00	56			1					
17:00	60			1					
18:00	67			1					
19:00	83							1	
20:00	86							1	
21:00	81							1	
22:00	75							1	
23:00	70							1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Προτεινόμενος ΗΕΠ		Σάββατο, 14 Μαρτίου 2026					
Αποδιδόμενη Ισχύς (kW)		80	80	80	90	200	180	400	
Η Ε Ρ Ε Ι Κ ΟΥ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
			Σάββατο, 14 Μαρτίου 2026	00:00	62			1	
01:00	62				1				
02:00	59				1				
03:00	60				1				
04:00	58				1				
05:00	59				1				
06:00	60				1				
07:00	61				1				
08:00	57				1				
09:00	59				1				
10:00	55				1				
11:00	54				1				
12:00	55				1				
13:00	55				1				
14:00	54				1				
15:00	55				1				
16:00	56				1				
17:00	61				1				
18:00	65				1				
19:00	82							1	
20:00	85							1	
21:00	79							1	
22:00	74							1	
23:00	69							1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ		Κυριακή, 15 Μαρτίου 2026				
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 15 Μαρτίου 2026	00:00	62			1				
	01:00	61			1				
	02:00	58			1				
	03:00	59			1				
	04:00	59			1				
	05:00	60			1				
	06:00	62			1				
	07:00	60			1				
	08:00	57			1				
	09:00	59			1				
	10:00	56			1				
	11:00	55			1				
	12:00	56			1				
	13:00	55			1				
	14:00	53			1				
	15:00	54			1				
	16:00	56			1				
	17:00	60			1				
	18:00	68			1				
	19:00	81							1
	20:00	82							1
	21:00	78							1
	22:00	75							1
	23:00	70							1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ		Δευτέρα, 16 Μαρτίου 2026				
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Δευτέρα, 16 Μαρτίου 2026	00:00	64				1			
	01:00	61				1			
	02:00	58				1			
	03:00	62				1			
	04:00	59				1			
	05:00	61				1			
	06:00	63				1			
	07:00	62				1			
	08:00	57				1			
	09:00	56				1			
	10:00	53				1			
	11:00	52				1			
	12:00	53				1			
	13:00	54				1			
	14:00	52				1			
	15:00	51				1			
	16:00	55				1			
	17:00	59				1			
	18:00	70				1			
	19:00	82							1
	20:00	84							1
	21:00	80							1
	22:00	73							1
	23:00	69							1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Προτεινόμενος ΗΕΠ		Τρίτη, 17 Μαρτίου 2026					
Αποδιδόμενη Ισχύς (kW)		80	80	80	90	200	180	400	
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
			Τρίτη, 17 Μαρτίου 2026	00:00	62			1	
01:00	59				1				
02:00	57				1				
03:00	60				1				
04:00	58				1				
05:00	60				1				
06:00	63				1				
07:00	61				1				
08:00	59				1				
09:00	60				1				
10:00	58				1				
11:00	56				1				
12:00	57				1				
13:00	57				1				
14:00	56				1				
15:00	56				1				
16:00	60				1				
17:00	64				1				
18:00	75								1
19:00	85								1
20:00	86								1
21:00	81								1
22:00	74								1
23:00	70								1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ		Τετάρτη, 18 Μαρτίου 2026				
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
			Τετάρτη, 18 Μαρτίου 2026	00:00	62				1
01:00	61					1			
02:00	60					1			
03:00	61					1			
04:00	60					1			
05:00	61					1			
06:00	58					1			
07:00	60					1			
08:00	58					1			
09:00	57					1			
10:00	54					1			
11:00	53					1			
12:00	51					1			
13:00	50					1			
14:00	50					1			
15:00	49					1			
16:00	53					1			
17:00	60					1			
18:00	70					1			
19:00	79								1
20:00	80								1
21:00	76								1
22:00	71								1
23:00	67								1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης