

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Τετάρτη, 4 Μαρτίου 2026								
Αποδιδόμενη Ισχύς (MW)		1,000	1,000	0,400	0,400	0,400	0,400	0,400	1,000	1,000	1,000	
Ρ Ε Σ Ε	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
	Τετάρτη, 4 Μαρτίου 2026	00:00	1,001		1						1	
01:00		0,897		1						1		
02:00		0,886		1						1		
03:00		0,862		1						1		
04:00		0,885		1						1		
05:00		0,885		1						1		
06:00		1,000		1						1		
07:00		0,993		1						1		
08:00		0,881		1						1		
09:00		0,917		1						1		
10:00		0,894		1						1		
11:00		0,896		1						1		
12:00		0,976		1						1		
13:00		0,919		1						1		
14:00		1,006		1						1		
15:00		1,023		1						1		
16:00		1,179		1						1		
17:00		1,264		1							1	
18:00		1,405		1							1	
19:00		1,507		1							1	
20:00		1,518		1							1	
21:00		1,362		1							1	
22:00		1,208		1							1	
23:00		1,074		1							1	

Προγραμματισμένες εργασίες στο δίκτυο στο διάστημα από τις 8:11 έως τις 12:15.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης


ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Πέμπτη, 5 Μαρτίου 2026								
Αποδιδόμενη Ισχύς (MW)		1,000	1,000	0,400	0,400	0,400	0,400	0,400	1,000	1,000	1,000	
Ρ Ο Λ Ο Γ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
	Πέμπτη, 5 Μαρτίου 2026	00:00	0,962		1							1
01:00		0,883		1							1	
02:00		0,875		1							1	
03:00		0,850		1							1	
04:00		0,870		1							1	
05:00		0,869		1							1	
06:00		0,992		1							1	
07:00		0,929		1							1	
08:00		0,886		1							1	
09:00		0,844		1						1		
10:00		0,818		1								
11:00		0,807		1								
12:00		0,803		1								
13:00		0,816		1								
14:00		0,930		1							1	
15:00		0,933		1							1	
16:00		1,048		1							1	
17:00		1,093		1							1	
18:00		1,320		1							1	
19:00		1,457		1							1	
20:00		1,470		1							1	
21:00		1,338		1							1	
22:00		1,226		1							1	
23:00		1,057		1						1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Παρασκευή, 6 Μαρτίου 2026								
Αποδιδόμενη Ισχύς (MW)		1,000	1,000	0,400	0,400	0,400	0,400	0,400	1,000	1,000	1,000	
Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
	Παρασκευή, 6 Μαρτίου 2026	00:00	0,958		1						1	
01:00		0,866		1						1		
02:00		0,849		1						1		
03:00		0,827		1						1		
04:00		0,861		1						1		
05:00		0,864		1						1		
06:00		0,987		1						1		
07:00		0,929		1						1		
08:00		0,882		1						1		
09:00		0,910		1						1		
10:00		0,934		1						1		
11:00		0,914		1						1		
12:00		0,940		1						1		
13:00		0,907		1						1		
14:00		0,993		1						1		
15:00		1,008		1						1		
16:00		1,110		1						1		
17:00		1,221	1	1								
18:00		1,374	1	1								
19:00		1,509	1	1								
20:00		1,477	1	1								
21:00		1,379	1	1								
22:00		1,229	1	1								
23:00		1,085		1							1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης


ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Σάββατο, 7 Μαρτίου 2026								
Αποδιδόμενη Ισχύς (MW)		1,000	1,000	0,400	0,400	0,400	0,400	0,400	1,000	1,000	1,000	
Ρ Ο Λ Ο Γ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
	Σάββατο, 7 Μαρτίου 2026	00:00	1,001		1						1	
01:00		0,909		1						1		
02:00		0,899		1						1		
03:00		0,882		1						1		
04:00		0,906		1						1		
05:00		0,901		1						1		
06:00		0,980		1						1		
07:00		0,957		1						1		
08:00		0,893		1						1		
09:00		0,849		1						1		
10:00		0,876		1						1		
11:00		0,829		1						1		
12:00		0,883		1						1		
13:00		0,882		1						1		
14:00		0,918		1						1		
15:00		0,952		1						1		
16:00		1,122		1						1		
17:00		1,277	1	1								
18:00		1,512	1	1								
19:00		1,629	1	1								
20:00		1,608	1	1								
21:00		1,474	1	1								
22:00		1,336	1	1								
23:00		1,155		1							1	

 Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Κυριακή, 8 Μαρτίου 2026								
Αποδιδόμενη Ισχύς (MW)		1,000	1,000	0,400	0,400	0,400	0,400	0,400	1,000	1,000	1,000	
Ρ Ε Σ Ε	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
	Κυριακή, 8 Μαρτίου 2026	00:00	1,063		1						1	
01:00		0,958		1						1		
02:00		0,932		1						1		
03:00		0,895		1						1		
04:00		0,929		1						1		
05:00		0,916		1						1		
06:00		1,037		1						1		
07:00		0,953		1						1		
08:00		0,897		1						1		
09:00		0,850		1						1		
10:00		0,889		1						1		
11:00		0,885		1						1		
12:00		0,901		1						1		
13:00		0,914		1						1		
14:00		1,003		1						1		
15:00		1,010		1						1		
16:00		1,067		1						1		
17:00		1,175		1						1		
18:00		1,350	1	1								
19:00		1,426	1	1								
20:00		1,407	1	1								
21:00		1,269	1	1								
22:00		1,159	1	1								
23:00		1,083		1							1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Δευτέρα, 9 Μαρτίου 2026								
Αποδιδόμενη Ισχύς (MW)		1,000	1,000	0,400	0,400	0,400	0,400	0,400	1,000	1,000	1,000	
Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
	Δευτέρα, 9 Μαρτίου 2026	00:00	0,982		1						1	
01:00		0,892		1						1		
02:00		0,862		1						1		
03:00		0,849		1						1		
04:00		0,897		1						1		
05:00		0,871		1						1		
06:00		0,994		1						1		
07:00		0,947		1						1		
08:00		0,927		1						1		
09:00		0,912		1						1		
10:00		0,909		1						1		
11:00		0,856		1						1		
12:00		0,885		1						1		
13:00		0,871	1							1		
14:00		0,898	1							1		
15:00		0,892	1							1		
16:00		1,035	1							1		
17:00		1,248	1							1		
18:00		1,440	1							1		
19:00		1,507	1							1		
20:00		1,554	1							1		
21:00		1,479	1							1		
22:00		1,301	1							1		
23:00		1,128	1							1		

 Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Τρίτη, 10 Μαρτίου 2026								
Αποδιδόμενη Ισχύς (MW)		1,000	1,000	0,400	0,400	0,400	0,400	0,400	1,000	1,000	1,000	
Ρ Ε Σ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
	Τρίτη, 10 Μαρτίου 2026	00:00	0,998	1							1	
01:00		0,908	1							1		
02:00		0,881	1							1		
03:00		0,874	1							1		
04:00		0,902	1							1		
05:00		0,898	1							1		
06:00		1,025	1							1		
07:00		0,982	1							1		
08:00		0,919	1							1		
09:00		0,910	1							1		
10:00		0,892	1							1		
11:00		0,893	1							1		
12:00		0,875	1							1		
13:00		0,864	1							1		
14:00		0,903	1							1		
15:00		0,921	1							1		
16:00		1,045	1							1		
17:00		1,216	1							1		
18:00		1,444	1							1		
19:00		1,575	1							1		
20:00		1,545	1							1		
21:00		1,418	1							1		
22:00		1,264	1							1		
23:00		1,082	1							1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης