

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Τετάρτη, 18 Μαρτίου 2026								
Αποδιδόμενη Ισχύς (MW)		1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000		
Ρ Ο Λ Ο Γ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
	Τετάρτη, 18 Μαρτίου 2026	00:00	1,026	1							1	
01:00		0,943	1							1		
02:00		0,911	1							1		
03:00		0,902	1							1		
04:00		0,908	1							1		
05:00		0,938	1							1		
06:00		1,035	1							1		
07:00		0,994	1								1	
08:00		0,976	1								1	
09:00		1,042	1								1	
10:00		1,051	1								1	
11:00		1,227	1								1	
12:00		1,263	1								1	
13:00		1,285	1								1	
14:00		1,221	1								1	
15:00		1,233	1								1	
16:00		1,308	1								1	
17:00		1,450	1								1	
18:00		1,587	1								1	
19:00		1,640	1								1	
20:00		1,640	1								1	
21:00		1,540	1								1	
22:00		1,351	1								1	
23:00		1,184	1								1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Πέμπτη, 19 Μαρτίου 2026								
Αποδιδόμενη Ισχύς (MW)		1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000		
Ρ Ο Λ Ο Γ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
	Πέμπτη, 19 Μαρτίου 2026	00:00	1,083	1								1
01:00		0,973	1							1		
02:00		0,924	1							1		
03:00		0,935	1							1		
04:00		0,945	1							1		
05:00		0,956	1							1		
06:00		1,061	1							1		
07:00		1,040	1							1		
08:00		1,095	1							1		
09:00		1,098	1							1		
10:00		1,170	1							1		
11:00		1,240	1							1		
12:00		1,257	1							1		
13:00		1,280	1							1		
14:00		1,310	1							1		
15:00		1,307	1							1		
16:00		1,410	1							1		
17:00		1,568	1							1		
18:00		1,678	1							1	1	
19:00		1,677	1							1	1	
20:00		1,642	1							1	1	
21:00		1,510	1							1		
22:00		1,360	1							1		
23:00		1,210	1							1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Παρασκευή, 20 Μαρτίου 2026								
Αποδιδόμενη Ισχύς (MW)		1,000	1,000	0,400	0,400	0,400	0,400	0,400	1,000	1,000	1,000	
Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
	Παρασκευή, 20 Μαρτίου 2026	00:00	1,094	1							1	
01:00		0,993	1							1		
02:00		0,940								1	1	
03:00		0,991								1	1	
04:00		0,996								1	1	
05:00		0,983								1	1	
06:00		1,099		1						1		
07:00		1,118		1						1		
08:00		1,236		1						1		
09:00		1,367	1							1		
10:00		1,431	1							1		
11:00		1,496	1							1		
12:00		1,534	1							1		
13:00		1,489	1							1		
14:00		1,470	1							1		
15:00		1,439	1							1		
16:00		1,488	1							1		
17:00		1,570	1							1		
18:00		1,653	1							1		
19:00		1,659	1							1		
20:00		1,596	1							1		
21:00		1,518	1							1		
22:00		1,397	1							1		
23:00		1,235	1							1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Σάββατο, 21 Μαρτίου 2026								
Αποδιδόμενη Ισχύς (MW)		1,000	1,000	0,400	0,400	0,400	0,400	0,400	1,000	1,000	1,000	
Ρ Ο Λ Ο Γ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
	Σάββατο, 21 Μαρτίου 2026	00:00	1,125	1							1	
01:00		1,014	1							1		
02:00		0,973	1							1		
03:00		0,985	1							1		
04:00		0,999	1							1		
05:00		1,010	1							1		
06:00		1,104	1							1		
07:00		1,061	1							1		
08:00		1,073	1							1		
09:00		1,157	1							1		
10:00		1,244	1							1		
11:00		1,211	1							1		
12:00		1,247	1							1		
13:00		1,254	1							1		
14:00		1,238	1								1	
15:00		1,425	1								1	
16:00		1,468	1								1	
17:00		1,617	1								1	
18:00		1,755	1								1	
19:00		1,848	1	1							1	
20:00		1,745	1	1							1	
21:00		1,604	1								1	
22:00		1,506	1								1	
23:00		1,309	1								1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Κυριακή, 22 Μαρτίου 2026								
Αποδιδόμενη Ισχύς (MW)		1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000		
Ρ Ο Λ Ο Γ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
	Κυριακή, 22 Μαρτίου 2026	00:00	1,173	1								1
01:00		1,066	1								1	
02:00		1,015	1								1	
03:00		1,001	1								1	
04:00		1,019	1								1	
05:00		1,014	1								1	
06:00		1,057	1								1	
07:00		1,052	1								1	
08:00		1,076	1								1	
09:00		1,124	1								1	
10:00		1,249	1								1	
11:00		1,438	1								1	
12:00		1,628	1								1	
13:00		1,717	1							1	1	
14:00		1,684	1							1	1	
15:00		1,596	1								1	
16:00		1,524	1								1	
17:00		1,532	1								1	
18:00		1,644	1								1	
19:00		1,664	1								1	
20:00		1,597	1								1	
21:00		1,524	1								1	
22:00		1,388	1								1	
23:00		1,212	1								1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Δευτέρα, 23 Μαρτίου 2026								
Αποδιδόμενη Ισχύς (MW)		1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000		
Ρ Ο Λ Ο Γ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
	Δευτέρα, 23 Μαρτίου 2026	00:00	1,103	1								1
01:00		0,976	1								1	
02:00		0,908	1								1	
03:00		0,925	1								1	
04:00		0,926	1								1	
05:00		0,949	1								1	
06:00		1,098	1								1	
07:00		1,118	1								1	
08:00		1,070	1								1	
09:00		1,035	1								1	
10:00		1,026	1								1	
11:00		1,035	1								1	
12:00		1,000	1								1	
13:00		0,997	1								1	
14:00		1,042	1								1	
15:00		1,030	1								1	
16:00		1,135	1								1	
17:00		1,323	1								1	
18:00		1,490	1								1	
19:00		1,685	1								1	
20:00		1,707	1								1	
21:00		1,629	1								1	
22:00		1,460	1								1	
23:00		1,226	1								1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Τρίτη, 24 Μαρτίου 2026								
Αποδιδόμενη Ισχύς (MW)		1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000		
Ρ Ο Λ Ο Γ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
	Τρίτη, 24 Μαρτίου 2026	00:00	1,079	1								1
01:00		0,981	1								1	
02:00		0,929	1								1	
03:00		0,934	1								1	
04:00		0,925	1								1	
05:00		0,927	1								1	
06:00		1,066	1								1	
07:00		1,087		1							1	
08:00		1,105		1							1	
09:00		1,063		1							1	
10:00		1,114	1								1	
11:00		1,168	1							1		
12:00		1,285	1							1		
13:00		1,369	1							1		
14:00		1,519	1							1		
15:00		1,587	1							1		
16:00		1,632	1							1		
17:00		1,709	1							1		
18:00		1,761	1							1	1	
19:00		1,841	1							1	1	
20:00		1,726	1							1	1	
21:00		1,593	1							1	1	
22:00		1,455	1								1	
23:00		1,268	1								1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης