

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Τετάρτη, 25 Φεβρουαρίου 2026								
Αποδιδόμενη Ισχύς (MW)		1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000		
Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
	Τετάρτη, 25 Φεβρουαρίου 2026	00:00	0,935		1							1
01:00		0,817		1								
02:00		0,798		1								
03:00		0,783		1								
04:00		0,820		1								
05:00		0,817		1								
06:00		0,941		1						1		
07:00		0,920		1						1		
08:00		0,895		1						1		
09:00		0,957		1						1		
10:00		0,979		1						1		
11:00		1,006		1						1		
12:00		1,040		1						1		
13:00		1,047		1						1		
14:00		1,066		1						1		
15:00		1,005		1						1		
16:00		1,109		1						1		
17:00		1,234		1						1		
18:00		1,409		1							1	
19:00		1,466		1							1	
20:00		1,469		1							1	
21:00		1,341		1							1	
22:00		1,215		1							1	
23:00		1,071		1							1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Πέμπτη, 26 Φεβρουαρίου 2026								
Αποδιδόμενη Ισχύς (MW)		1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000		
Ρ Ο Λ Ο Γ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
	Πέμπτη, 26 Φεβρουαρίου 2026	00:00	0,980		1							1
01:00		0,883		1								
02:00		0,852		1								
03:00		0,856		1								
04:00		0,896		1								
05:00		0,871		1								
06:00		0,984		1						1		
07:00		0,936		1						1		
08:00		0,936		1						1		
09:00		0,904		1						1		
10:00		0,941		1						1		
11:00		0,931		1						1		
12:00		1,051	1	1								
13:00		1,033	1	1								
14:00		1,050		1						1		
15:00		1,082		1						1		
16:00		1,213		1						1		
17:00		1,323		1						1		
18:00		1,448		1							1	
19:00		1,509		1							1	
20:00		1,450		1							1	
21:00		1,323		1							1	
22:00		1,205		1							1	
23:00		1,074		1							1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Παρασκευή, 27 Φεβρουαρίου 2026								
Αποδιδόμενη Ισχύς (MW)		1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000		
Ρ Ο Λ Ο Γ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
	Παρασκευή, 27 Φεβρουαρίου 2026	00:00	0,956		1							1
01:00		0,868		1								
02:00		0,833		1								
03:00		0,831		1								
04:00		0,856		1								
05:00		0,860		1								
06:00		0,993		1						1		
07:00		0,964		1						1		
08:00		0,907		1						1		
09:00		0,912		1						1		
10:00		0,965		1						1		
11:00		0,988		1						1		
12:00		1,019		1						1		
13:00		1,007		1						1		
14:00		1,006		1						1		
15:00		1,043		1						1		
16:00		1,164		1						1		
17:00		1,326		1						1		
18:00		1,538		1							1	
19:00		1,619		1							1	
20:00		1,550		1							1	
21:00		1,452		1							1	
22:00		1,284		1							1	
23:00		1,141		1							1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Σάββατο, 28 Φεβρουαρίου 2026								
Αποδιδόμενη Ισχύς (MW)		1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000		
Ρ Ο Λ Ο Γ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
	Σάββατο, 28 Φεβρουαρίου 2026	00:00	1,041		1							1
01:00		0,945		1							1	
02:00		0,917		1						1		
03:00		0,958		1						1		
04:00		0,982		1						1		
05:00		0,981		1						1		
06:00		1,085	1								1	
07:00		1,024	1								1	
08:00		1,031	1								1	
09:00		1,046		1						1		
10:00		1,067		1						1		
11:00		1,043		1						1		
12:00		1,083		1						1		
13:00		1,074		1						1		
14:00		1,121		1						1		
15:00		1,138		1						1		
16:00		1,336		1						1		
17:00		1,374		1							1	
18:00		1,559		1							1	
19:00		1,627		1							1	
20:00		1,570		1							1	
21:00		1,448		1							1	
22:00		1,335		1							1	
23:00		1,190		1							1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Κυριακή, 1 Μαρτίου 2026								
Αποδιδόμενη Ισχύς (MW)		1,000	1,000	0,400	0,400	0,400	0,400	1,000	1,000	1,000		
Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
	Κυριακή, 1 Μαρτίου 2026	00:00	1,091		1							1
01:00		0,969		1							1	
02:00		0,935		1							1	
03:00		0,902		1							1	
04:00		0,914		1							1	
05:00		0,917		1							1	
06:00		0,980		1							1	
07:00		1,006		1							1	
08:00		1,030		1							1	
09:00		1,101		1							1	
10:00		1,149		1							1	
11:00		1,178		1							1	
12:00		1,327		1							1	
13:00		1,285		1							1	
14:00		1,264		1							1	
15:00		1,230		1							1	
16:00		1,281		1							1	
17:00		1,383		1							1	
18:00		1,478		1							1	
19:00		1,493		1							1	
20:00		1,444		1							1	
21:00		1,378		1							1	
22:00		1,234		1							1	
23:00		1,106		1							1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Δευτέρα, 2 Μαρτίου 2026								
Αποδιδόμενη Ισχύς (MW)		1,000	1,000	0,400	0,400	0,400	0,400	0,400	1,000	1,000	1,000	
Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
	Δευτέρα, 2 Μαρτίου 2026	00:00	1,008		1							1
01:00		0,884		1							1	
02:00		0,887		1							1	
03:00		0,879		1							1	
04:00		0,909		1							1	
05:00		0,884		1							1	
06:00		0,993		1						1		
07:00		0,987		1						1		
08:00		0,950		1						1		
09:00		0,898		1						1		
10:00		0,863		1							1	
11:00		0,819		1							1	
12:00		0,803		1							1	
13:00		0,839		1							1	
14:00		0,902		1							1	
15:00		0,927		1						1		
16:00		1,044		1						1		
17:00		1,167		1						1		
18:00		1,333		1						1		
19:00		1,423	1							1		
20:00		1,507	1								1	
21:00		1,420	1								1	
22:00		1,288	1								1	
23:00		1,116	1								1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΚΥΘΟΝΟΥ		Απολογισμός Λειτουργίας		Τρίτη, 3 Μαρτίου 2026								
Αποδιδόμενη Ισχύς (MW)		1,000	1,000	0,400	0,400	0,400	0,400	0,400	1,000	1,000	1,000	
Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	
			Τρίτη, 3 Μαρτίου 2026	00:00	1,026	1						
01:00	0,914	1									1	
02:00	0,882	1									1	
03:00	0,882	1									1	
04:00	0,888	1									1	
05:00	0,860	1									1	
06:00	0,976	1								1		
07:00	0,951	1								1		
08:00	0,948	1								1		
09:00	0,940	1								1		
10:00	0,900	1								1		
11:00	0,905	1								1		
12:00	0,912	1								1		
13:00	0,872	1								1		
14:00	0,940			1						1		
15:00	0,960			1						1		
16:00	1,048			1						1		
17:00	1,159			1						1		
18:00	1,368			1							1	
19:00	1,497			1							1	
20:00	1,499			1							1	
21:00	1,405			1							1	
22:00	1,247			1							1	
23:00	1,093			1						1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης