


ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 3 Μαρτίου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
			Τρίτη, 3 Μαρτίου 2026	00:00	1,037				1	1	
01:00	0,917					1	1				
02:00	0,857					1	1				
03:00	0,833						1				
04:00	0,847						1				
05:00	0,870						1				
06:00	0,968					1	1				
07:00	1,129					1	1				
08:00	1,280					1	1				
09:00	1,348						1				1
10:00	1,321						1				1
11:00	1,368						1				1
12:00	1,402						1				1
13:00	1,387						1				1
14:00	1,434						1				1
15:00	1,412						1				1
16:00	1,469						1				1
17:00	1,581						1				1
18:00	1,758						1		1		1
19:00	1,923						1		1		1
20:00	1,909						1		1		1
21:00	1,839						1		1		1
22:00	1,394						1		1		
23:00	1,096					1	1				

 Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 4 Μαρτίου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Ρ Ο Λ Ο Γ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
			Τετάρτη, 4 Μαρτίου 2026	00:00	0,972				1	1	
01:00	0,867					1	1				
02:00	0,801						1				
03:00	0,794						1				
04:00	0,825						1				
05:00	0,816						1				
06:00	0,913						1				
07:00	1,082					1	1				
08:00	1,286					1	1				
09:00	1,371						1				1
10:00	1,352						1				1
11:00	1,312						1				1
12:00	1,324						1				1
13:00	1,288						1				1
14:00	1,134						1				1
15:00	0,964						1				1
16:00	1,014						1				1
17:00	1,093						1				1
18:00	1,312						1				1
19:00	1,440						1				1
20:00	1,451						1				1
21:00	1,416						1				1
22:00	1,311						1				1
23:00	1,122					1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 5 Μαρτίου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Ρ Ε Ξ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
			Πέμπτη, 5 Μαρτίου 2026	00:00	0,956				1	1	
01:00	0,871					1	1				
02:00	0,807						1				
03:00	0,797						1				
04:00	0,829						1				
05:00	0,840						1				
06:00	0,909						1		1		
07:00	1,015						1		1		
08:00	1,251						1				1
09:00	1,441						1				1
10:00	1,397						1				1
11:00	1,351						1				1
12:00	1,379						1				1
13:00	1,364						1				1
14:00	1,405						1				1
15:00	1,352						1				1
16:00	1,316						1				1
17:00	1,430						1				1
18:00	1,589						1				1
19:00	1,768						1				1
20:00	1,775						1		1		1
21:00	1,373						1				1
22:00	1,238						1				1
23:00	1,066					1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 6 Μαρτίου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
			Παρασκευή, 6 Μαρτίου 2026	00:00	0,930				1	1	
01:00	0,829						1				
02:00	0,776						1				
03:00	0,758						1				
04:00	0,778						1				
05:00	0,792						1				
06:00	0,868						1				
07:00	0,983						1				1
08:00	1,183						1				1
09:00	1,345						1				1
10:00	1,343						1				1
11:00	1,288						1				1
12:00	1,123						1				1
13:00	1,119						1				1
14:00	1,036						1				1
15:00	0,954						1		1		
16:00	0,985						1		1		
17:00	1,104						1		1		
18:00	1,244						1		1		
19:00	1,306						1		1		
20:00	1,333						1		1		
21:00	1,271						1		1		
22:00	1,155						1		1		
23:00	1,028						1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 7 Μαρτίου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
			Σάββατο, 7 Μαρτίου 2026	00:00	0,905					1	
01:00	0,832						1		1		
02:00	0,776						1				
03:00	0,768						1				
04:00	0,786						1				
05:00	0,802						1				
06:00	0,857						1				
07:00	0,916						1				
08:00	1,298						1				1
09:00	1,332						1				1
10:00	1,310						1				1
11:00	1,264						1				1
12:00	1,283						1				1
13:00	1,249						1				1
14:00	1,309						1				1
15:00	1,293						1				1
16:00	1,393						1				1
17:00	1,459						1				1
18:00	1,587						1				1
19:00	1,357						1				1
20:00	1,395						1				1
21:00	1,316						1				1
22:00	1,200						1				1
23:00	1,052						1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 8 Μαρτίου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
			Κυριακή, 8 Μαρτίου 2026	00:00	0,925					1	
01:00	0,850						1		1		
02:00	0,795						1				
03:00	0,770						1				
04:00	0,774						1				
05:00	0,790						1				
06:00	0,862						1				
07:00	0,888						1				
08:00	1,192						1				1
09:00	1,218						1				1
10:00	1,223						1				1
11:00	1,272						1				1
12:00	1,262						1				1
13:00	1,209						1				1
14:00	1,228						1				1
15:00	0,923						1		1		
16:00	0,953						1		1		
17:00	1,023						1		1		
18:00	1,206						1		1		
19:00	1,350						1		1		
20:00	1,406						1		1		
21:00	1,338						1		1		
22:00	1,210						1		1		
23:00	1,016						1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 9 Μαρτίου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
			Δευτέρα, 9 Μαρτίου 2026	00:00	0,881					1	
01:00	0,803						1				
02:00	0,792						1				
03:00	0,773						1				
04:00	0,777						1				
05:00	0,817						1				
06:00	0,884						1				
07:00	0,987						1				
08:00	1,118					1	1				
09:00	1,288					1	1				
10:00	1,276					1	1				
11:00	1,297					1	1				
12:00	1,276					1	1				
13:00	1,147					1	1				
14:00	1,220					1	1				
15:00	1,207						1		1		
16:00	1,248						1		1		
17:00	1,378						1		1		
18:00	1,580						1		1		
19:00	1,682						1		1		
20:00	1,741						1		1		
21:00	1,658						1		1		
22:00	1,234						1		1		
23:00	1,074						1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης