



ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 17 Μαρτίου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Ρ Ε Ξ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
			Τρίτη, 17 Μαρτίου 2026	00:00	0,904					1	
01:00	0,808						1				
02:00	0,773						1				
03:00	0,757						1				
04:00	0,773						1				
05:00	0,802						1				
06:00	0,890						1				
07:00	0,990						1				1
08:00	1,170						1				1
09:00	1,320						1				1
10:00	1,373						1				1
11:00	1,397						1				1
12:00	1,384						1				1
13:00	1,465						1				1
14:00	1,422						1				1
15:00	1,498						1				1
16:00	1,493						1				1
17:00	1,544						1				1
18:00	1,781						1				1
19:00	1,865						1	1			1
20:00	1,772						1	1			1
21:00	1,781						1	1			1
22:00	1,507						1				1
23:00	1,056						1				1

 Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 18 Μαρτίου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Ρ Ε Ξ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
			Τετάρτη, 18 Μαρτίου 2026	00:00	0,909					1	
01:00	0,817						1				
02:00	0,775						1				
03:00	0,764						1				
04:00	0,804						1				
05:00	0,848						1				
06:00	0,868						1				
07:00	0,971						1				1
08:00	1,218						1				1
09:00	1,494						1				1
10:00	1,468						1				1
11:00	1,594						1				1
12:00	1,677						1				1
13:00	1,659						1				1
14:00	1,699						1				1
15:00	1,772					1	1				1
16:00	1,680						1				1
17:00	1,738						1				1
18:00	1,900					1	1				1
19:00	2,047					1	1				1
20:00	2,040					1	1				1
21:00	1,870					1	1				1
22:00	1,671					1	1				1
23:00	1,086					1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 19 Μαρτίου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Ρ Ε Τ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
			Πέμπτη, 19 Μαρτίου 2026	00:00	0,941					1	
01:00	0,849						1				
02:00	0,787						1				
03:00	0,763						1				
04:00	0,784						1				
05:00	0,818						1				
06:00	0,897						1				
07:00	1,016						1				1
08:00	1,235						1				1
09:00	1,425						1				1
10:00	1,408						1				1
11:00	1,293						1				1
12:00	1,362						1				1
13:00	1,363						1				1
14:00	1,368						1				1
15:00	1,352						1				1
16:00	1,340						1				1
17:00	1,416						1				1
18:00	1,620						1				1
19:00	1,745						1				1
20:00	1,804						1	1			1
21:00	1,771						1	1			1
22:00	1,666						1				1
23:00	1,100						1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 20 Μαρτίου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Ρ Ε Ξ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
			Παρασκευή, 20 Μαρτίου 2026	00:00	0,908					1	
01:00	0,828						1				
02:00	0,791						1				
03:00	0,765						1				
04:00	0,791						1				
05:00	0,827						1				
06:00	0,911						1				
07:00	0,945						1				1
08:00	1,241						1				1
09:00	1,451						1				1
10:00	1,390						1				1
11:00	1,381						1				1
12:00	1,272						1				1
13:00	1,293						1				1
14:00	1,199						1				1
15:00	1,163						1				1
16:00	1,117						1				1
17:00	1,157						1				1
18:00	1,293						1				1
19:00	1,376						1				1
20:00	1,492						1				1
21:00	1,524						1				1
22:00	1,389						1				1
23:00	1,195						1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 21 Μαρτίου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
			Σάββατο, 21 Μαρτίου 2026	00:00	0,982					1	
01:00	0,901						1				
02:00	0,876						1				
03:00	0,836						1				
04:00	0,837						1				
05:00	0,872						1				
06:00	0,910						1				
07:00	0,993						1				1
08:00	1,435						1				1
09:00	1,518						1				1
10:00	1,596						1				1
11:00	1,607						1				1
12:00	1,573						1				1
13:00	1,517						1				1
14:00	1,466						1				1
15:00	1,490						1				1
16:00	1,494						1				1
17:00	1,624						1				1
18:00	1,914						1	1			1
19:00	1,990						1	1			1
20:00	1,986						1	1			1
21:00	1,860						1	1			1
22:00	1,617						1	1			1
23:00	1,206						1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 22 Μαρτίου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Α Ρ Θ Ε Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
			Κυριακή, 22 Μαρτίου 2026	00:00	1,050					1	1
01:00	0,925						1	1			
02:00	0,857						1				
03:00	0,821						1				
04:00	0,822						1				
05:00	0,869						1				
06:00	0,897						1				
07:00	0,939						1				1
08:00	1,067						1				1
09:00	1,158						1				1
10:00	1,309						1				1
11:00	1,296						1				1
12:00	1,348						1				1
13:00	1,353						1				1
14:00	1,326						1				1
15:00	1,293						1				1
16:00	1,291						1				1
17:00	1,411						1				1
18:00	1,517						1				1
19:00	1,744						1				1
20:00	1,797					1	1				1
21:00	1,735					1	1				1
22:00	1,524						1				1
23:00	1,090						1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 23 Μαρτίου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Α Ρ Θ Ε Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
	Δευτέρα, 23 Μαρτίου 2026	00:00	0,946					1			
01:00		0,838					1				
02:00		0,794					1				
03:00		0,770					1				
04:00		0,787					1				
05:00		0,815					1				
06:00		0,868					1				
07:00		0,952					1				
08:00		1,074					1				1
09:00		1,149					1				1
10:00		1,179					1				1
11:00		1,265					1				1
12:00		1,364					1				1
13:00		1,348					1				1
14:00		1,293					1				1
15:00		1,230					1				1
16:00		1,276					1				1
17:00		1,358					1				1
18:00		1,543					1				1
19:00		1,700					1				1
20:00		1,743					1				1
21:00		1,417					1				1
22:00		1,285					1				1
23:00	1,131					1				1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης