


ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 24 Φεβρουαρίου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Ρ Ο Λ Ο Γ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
			Τρίτη, 24 Φεβρουαρίου 2026	00:00	1,030					1	
01:00	0,944						1				1
02:00	0,888						1				
03:00	0,842						1				
04:00	0,863						1				
05:00	0,892						1				
06:00	0,961					1	1				
07:00	1,088					1	1				
08:00	1,171					1	1				
09:00	1,258						1				1
10:00	1,359						1				1
11:00	1,297						1				1
12:00	1,331						1				1
13:00	1,306						1				1
14:00	1,294						1				1
15:00	1,362						1				1
16:00	1,372						1				1
17:00	1,539						1				1
18:00	1,704						1				1
19:00	1,809						1			1	1
20:00	1,803						1			1	1
21:00	1,502						1				1
22:00	1,299						1				1
23:00	1,113						1				1

 Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 25 Φεβρουαρίου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Ρ Ο Λ Ο Γ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
			Τετάρτη, 25 Φεβρουαρίου 2026	00:00	0,967					1	
01:00	0,880						1				
02:00	0,818						1				
03:00	0,791						1				
04:00	0,824						1				
05:00	0,823						1				
06:00	0,892						1				
07:00	1,004						1				1
08:00	1,193						1				1
09:00	1,389						1				1
10:00	1,401						1				1
11:00	1,396						1				1
12:00	1,413						1				1
13:00	1,385						1				1
14:00	1,401						1				1
15:00	1,425						1				1
16:00	1,460						1				1
17:00	1,586						1				1
18:00	1,802						1			1	1
19:00	1,903						1			1	1
20:00	1,956						1			1	1
21:00	1,553						1				1
22:00	1,376						1				1
23:00	1,182						1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 26 Φεβρουαρίου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Ρ Ε Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
			Πέμπτη, 26 Φεβρουαρίου 2026	00:00	0,995					1	
01:00	0,902						1				
02:00	0,874						1				
03:00	0,843						1				
04:00	0,865						1				
05:00	0,892					1					1
06:00	0,972					1					1
07:00	1,128					1					1
08:00	1,247					1					1
09:00	1,398					1					1
10:00	1,521						1				1
11:00	1,679						1				1
12:00	1,590						1				1
13:00	1,538						1				1
14:00	1,565						1				1
15:00	1,711						1				1
16:00	1,762						1		1		1
17:00	1,879						1		1		1
18:00	2,045						1		1		1
19:00	2,081						1		1		1
20:00	2,086						1		1		1
21:00	1,679						1				1
22:00	1,506						1				1
23:00	1,299						1				1

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 27 Φεβρουαρίου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Ρ Ο Λ Ο Γ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
			Παρασκευή, 27 Φεβρουαρίου 2026	00:00	1,082					1	
01:00	0,959						1				1
02:00	0,905						1				
03:00	0,873						1				
04:00	0,895						1				
05:00	0,915						1				
06:00	1,083					1	1				
07:00	1,150					1	1				
08:00	1,173						1		1		
09:00	1,359						1		1		
10:00	1,371						1		1		
11:00	1,319						1		1		
12:00	1,314						1		1		
13:00	1,313						1		1		
14:00	1,382						1		1		
15:00	1,616						1		1		
16:00	1,608						1		1		
17:00	1,706						1		1		
18:00	1,878					1	1		1		
19:00	1,902					1	1		1		
20:00	2,053					1	1		1		
21:00	1,713					1	1		1		
22:00	1,514					1	1				
23:00	1,324					1	1				

Το διάστημα 08:20 με 14:55 πραγματοποιήθηκαν προγραμματισμένες εργασίες στο δίκτυο.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 28 Φεβρουαρίου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Ρ Ο Λ Ο Γ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
	Σάββατο, 28 Φεβρουαρίου 2026	00:00	1,128				1	1			
01:00		1,024				1	1				
02:00		0,949				1	1				
03:00		0,917				1	1				
04:00		0,933				1	1				
05:00		0,971				1	1				
06:00		1,058				1	1				
07:00		1,139				1	1				
08:00		0,950				1	1				
09:00		0,879				1	1				
10:00		0,838				1	1				
11:00		0,830					1				
12:00		0,866					1				
13:00		0,910					1		1		
14:00		0,895					1		1		
15:00		0,938					1		1		
16:00		1,091					1		1		
17:00		1,800					1		1		
18:00		1,962				1	1				
19:00		2,073				1	1				1
20:00		2,044				1	1				1
21:00		1,973				1	1				1
22:00		1,797				1	1				1
23:00		1,366				1	1				

Το διάστημα 08:10 με 14:55 πραγματοποιήθηκαν προγραμματισμένες εργασίες στο δίκτυο.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 1 Μαρτίου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
			Κυριακή, 1 Μαρτίου 2026	00:00	1,106				1	1	
01:00	1,008					1	1				
02:00	0,921					1	1				
03:00	0,894					1	1				
04:00	0,918					1	1				
05:00	0,941					1	1				
06:00	0,987					1	1				
07:00	1,083					1	1				
08:00	1,411					1	1				
09:00	1,318						1				1
10:00	1,300						1				1
11:00	1,325						1				1
12:00	1,396						1				1
13:00	1,405						1				1
14:00	1,331						1				1
15:00	1,354						1				1
16:00	1,406						1				1
17:00	1,555						1				1
18:00	1,762						1				1
19:00	1,589						1				1
20:00	1,608						1				1
21:00	1,507						1				1
22:00	1,395						1				1
23:00	1,210					1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 2 Μαρτίου 2026						
Αποδιδόμενη Ισχύς (MW)		1,100	0,000	0,000	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9
			Δευτέρα, 2 Μαρτίου 2026	00:00	0,996				1	1	
01:00	0,911					1	1				
02:00	0,868					1	1				
03:00	0,844					1	1				
04:00	0,848						1				
05:00	0,863						1				
06:00	0,935						1				
07:00	1,085					1	1				
08:00	1,232					1	1				
09:00	1,449					1	1				
10:00	1,431					1	1				
11:00	1,266					1	1				
12:00	1,385						1				1
13:00	1,335						1				1
14:00	1,326						1				1
15:00	1,359						1				1
16:00	1,432						1				1
17:00	1,498						1				1
18:00	1,802						1		1		1
19:00	1,912						1		1		1
20:00	1,908						1		1		1
21:00	1,806						1		1		1
22:00	1,635					1	1		1		
23:00	1,234					1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης