

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 24 Μαρτίου 2026					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
	Τρίτη, 24 Μαρτίου 2026	00:00	1,161		1	1		
01:00		1,077		1	1			
02:00		1,033		1	1	1		
03:00		1,020			1	1		
04:00		0,987			1	1		
05:00		0,919			1			
06:00		0,957			1			
07:00		1,055			1			
08:00		1,101		1	1			
09:00		1,058		1	1			
10:00		1,018		1	1			
11:00		0,989		1	1			
12:00		0,961		1	1			
13:00		0,975		1	1			
14:00		1,048		1	1			
15:00		1,132		1	1			
16:00		1,177		1	1			
17:00		1,295		1	1			
18:00		1,478		1	1			
19:00		1,627		1	1			
20:00		1,590		1	1			
21:00		1,488		1	1			
22:00		1,330		1	1			
23:00		1,250		1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 25 Μαρτίου 2026					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
	Τετάρτη, 25 Μαρτίου 2026	00:00	1,191		1	1		
01:00		1,082		1	1			
02:00		1,034		1	1			
03:00		1,006		1	1			
04:00		1,044		1	1			
05:00		1,040		1	1			
06:00		1,058		1	1			
07:00		1,097		1	1			
08:00		1,128		1	1			
09:00		1,154		1	1			
10:00		1,090		1	1			
11:00		1,105		1	1			
12:00		1,165		1	1			
13:00		1,160		1	1			
14:00		1,062		1	1			
15:00		0,973		1	1			
16:00		1,040		1	1			
17:00		1,129		1	1			
18:00		1,261		1	1			
19:00		1,402		1	1			
20:00		1,425		1	1			
21:00		1,386		1	1			
22:00		1,294		1	1			
23:00		1,133		1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 26 Μαρτίου 2026					
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
	Πέμπτη, 26 Μαρτίου 2026	00:00	0,991		1	1		
01:00		0,932		1	1			
02:00		0,886		1				
03:00		0,877		1				
04:00		0,886		1				
05:00		0,898		1				
06:00		0,911		1				
07:00		0,931		1				
08:00		0,854		1				
09:00		0,821		1				
10:00		0,851		1				
11:00		0,835		1				
12:00		0,817		1		1		
13:00		0,828		1		1		
14:00		0,795		1				
15:00		0,836		1				
16:00		0,897		1				
17:00		1,044		1				
18:00		1,242		1	1			
19:00		1,399		1	1			
20:00	1,421		1	1				
21:00	1,278		1	1				
22:00	1,156		1	1				
23:00	1,038		1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 27 Μαρτίου 2026					
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
	Παρασκευή, 27 Μαρτίου 2026	00:00	0,900		1			
01:00		0,829		1				
02:00		0,818		1				
03:00		0,843		1				
04:00		0,819		1				
05:00		0,820		1				
06:00		0,847		1				
07:00		0,928		1				
08:00		0,975		1				
09:00		1,017		1				
10:00		0,995		1		1		
11:00		0,998		1		1		
12:00		1,006		1				
13:00		1,187		1	1			
14:00		1,162		1	1			
15:00		1,123		1	1			
16:00		1,223		1	1			
17:00		1,318		1	1			
18:00		1,348		1	1			
19:00		1,404		1	1			
20:00	1,383		1	1				
21:00	1,412		1	1				
22:00	1,265		1	1				
23:00	1,144		1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 28 Μαρτίου 2026					
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
	Σάββατο, 28 Μαρτίου 2026	00:00	1,037		1	1		
01:00		0,919		1				
02:00		0,851		1				
03:00		0,836		1				
04:00		0,792		1				
05:00		0,792		1				
06:00		0,821		1				
07:00		0,914		1				
08:00		1,009		1				
09:00		1,063		1	1			
10:00		1,153		1	1			
11:00		1,255		1	1			
12:00		1,422		1	1			
13:00		1,492		1	1			
14:00		1,456		1	1			
15:00		1,438		1	1			
16:00		1,464		1	1			
17:00		1,459		1	1			
18:00		1,537		1	1			
19:00		1,634		1	1			
20:00		1,587		1	1			
21:00		1,529		1	1			
22:00		1,389		1	1			
23:00		1,183		1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 29 Μαρτίου 2026					
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
	Κυριακή, 29 Μαρτίου 2026	00:00	1,084		1	1		
01:00		1,052		1	1			
02:00		0,958		1				
03:00		0,000						
04:00		0,934		1				
05:00		0,941		1				
06:00		0,957		1				
07:00		0,949		1				
08:00		0,913		1				
09:00		0,874		1				
10:00		0,875		1				
11:00		0,920		1				
12:00		0,983		1				
13:00		0,954		1				
14:00		0,972		1				
15:00		1,019		1				
16:00		1,109		1	1			
17:00		1,176		1	1			
18:00		1,198		1	1			
19:00		1,355		1	1			
20:00	1,522		1	1				
21:00	1,448		1	1				
22:00	1,315		1	1				
23:00	1,180		1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 30 Μαρτίου 2026					
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
	Δευτέρα, 30 Μαρτίου 2026	00:00	1,054		1	1		
01:00		0,951		1				
02:00		0,914		1				
03:00		0,884		1				
04:00		0,884		1				
05:00		0,889		1				
06:00		0,931		1				
07:00		0,971		1				
08:00		1,030		1				
09:00		1,006		1				
10:00		1,086		1	1			
11:00		1,073		1	1			
12:00		0,991		1	1			
13:00		0,953		1				
14:00		0,996		1				
15:00		0,990		1				
16:00		0,919		1	1			
17:00		0,884		1	1			
18:00		0,988		1	1			
19:00		1,102		1	1			
20:00		1,321		1	1			
21:00		1,370		1	1			
22:00		1,298		1	1			
23:00		1,143		1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης