

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 31 Μαρτίου 2026					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
	Τρίτη, 31 Μαρτίου 2026	00:00	0,994		1	1		
01:00		0,914		1				
02:00		0,879		1				
03:00		0,857		1				
04:00		0,852		1				
05:00		0,840		1				
06:00		0,878		1				
07:00		0,937		1				
08:00		1,046		1				
09:00		1,059		1	1			
10:00		1,060		1	1			
11:00		1,015		1	1			
12:00		0,967		1	1			
13:00		1,025		1				
14:00		1,015		1				
15:00		1,020		1	1			
16:00		1,146		1	1			
17:00		1,226		1	1			
18:00		1,245		1	1			
19:00		1,379		1	1			
20:00	1,492		1	1				
21:00	1,544		1	1				
22:00	1,438		1	1				
23:00	1,245		1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 1 Απριλίου 2026					
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
	Τετάρτη, 1 Απριλίου 2026	00:00	1,128		1	1		
01:00		1,077		1	1			
02:00		0,988		1				
03:00		0,964		1				
04:00		0,880		1				
05:00		0,880		1				
06:00		0,935		1				
07:00		0,953		1				
08:00		1,036		1				
09:00		1,092		1	1			
10:00		1,225		1	1			
11:00		1,266		1	1			
12:00		1,215		1	1			
13:00		1,201		1	1			
14:00		1,200		1	1			
15:00		1,180		1	1			
16:00		1,304		1	1			
17:00		1,396		1	1			
18:00		1,348		1	1			
19:00		1,419		1	1			
20:00		1,384		1	1			
21:00		1,371		1	1			
22:00		1,191		1	1			
23:00		1,014		1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 2 Απριλίου 2026					
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
	Πέμπτη, 2 Απριλίου 2026	00:00	0,903		1	1		
01:00		0,859		1				
02:00		0,815		1				
03:00		0,792		1				
04:00		0,791		1				
05:00		0,804		1				
06:00		0,832		1				
07:00		0,899		1				
08:00		1,007		1	1			
09:00		1,092		1	1			
10:00		1,108		1	1			
11:00		1,050		1	1			
12:00		0,975		1	1			
13:00		1,067		1	1			
14:00		1,205		1	1			
15:00		1,121		1	1			
16:00		1,021		1	1			
17:00		1,209		1	1			
18:00		1,371		1	1			
19:00		1,437		1	1			
20:00		1,574		1	1			
21:00		1,545		1	1			
22:00		1,420		1	1			
23:00		1,209		1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 3 Απριλίου 2026					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Ρ Ε Σ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
01:00	0,921		1	1				
02:00	0,870		1					
03:00	0,861		1					
04:00	0,865		1					
05:00	0,884		1					
06:00	0,949		1					
07:00	1,037		1	1				
08:00	1,049		1	1				
09:00	1,129		1	1				
10:00	1,165		1	1				
11:00	1,246		1	1				
12:00	1,100		1	1				
13:00	1,089		1	1				
14:00	1,184		1	1				
15:00	1,148		1	1				
16:00	1,157		1	1				
17:00	1,185		1	1				
18:00	1,257		1	1				
19:00	1,357		1	1				
20:00	1,501		1	1				
21:00	1,505		1	1				
22:00	1,355		1	1				
23:00	1,237		1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 4 Απριλίου 2026					
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
	Σάββατο, 4 Απριλίου 2026	00:00	1,113		1	1		
01:00		0,999		1	1			
02:00		0,976		1	1			
03:00		0,955			1			
04:00		0,970			1			
05:00		0,963			1			
06:00		1,032	1		1			
07:00		1,059	1		1			
08:00		1,098	1		1			
09:00		1,270	1		1			
10:00		1,385		1	1			
11:00		1,190		1	1			
12:00		1,179		1	1			
13:00		1,190		1	1			
14:00		1,124		1	1			
15:00		0,995		1	1			
16:00		1,173		1	1			
17:00		1,227		1	1			
18:00		1,229		1	1			
19:00		1,447		1	1			
20:00		1,483		1	1			
21:00		1,398		1	1			
22:00		1,271		1	1			
23:00		1,098		1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 5 Απριλίου 2026					
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
	Κυριακή, 5 Απριλίου 2026	00:00	0,986		1	1		
01:00		0,923		1	1			
02:00		0,870		1				
03:00		0,848		1				
04:00		0,842		1				
05:00		0,842		1				
06:00		0,859		1				
07:00		0,887		1				
08:00		0,942		1				
09:00		0,904		1				
10:00		0,959		1				
11:00		1,028		1	1			
12:00		1,030		1	1			
13:00		1,105		1	1			
14:00		1,003		1	1			
15:00		0,947		1	1			
16:00		0,906		1				
17:00		1,000		1				
18:00		1,116		1	1			
19:00		1,230		1	1			
20:00		1,390		1	1			
21:00		1,378		1	1			
22:00		1,204		1	1			
23:00		1,063		1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 6 Απριλίου 2026					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
01:00	0,933		1					
02:00	0,850		1					
03:00	0,833		1					
04:00	0,830		1					
05:00	0,867		1					
06:00	0,882		1					
07:00	0,885		1					
08:00	0,943		1					
09:00	0,983		1					
10:00	0,929		1					
11:00	0,959		1					
12:00	0,985		1					
13:00	0,962		1					
14:00	1,001		1					
15:00	1,017		1					
16:00	1,035		1					
17:00	1,075		1	1				
18:00	1,154		1	1				
19:00	1,314		1	1				
20:00	1,560		1	1				
21:00	1,559		1	1				
22:00	1,464		1	1				
23:00	1,325		1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης