

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Τετάρτη, 22 Απριλίου 2026			
Αποδιδόμενη Ισχύς (ΜW)		1,100	1,100	1,100	1,100	0,460	0,460	
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (ΜW)	G1	G2	G3	G5	G8	G9
01:00	0,985	1			1			
02:00	0,925	1						
03:00	0,910	1						
04:00	0,916	1						
05:00	0,929	1						
06:00	0,970	1				1		
07:00	1,026	1				1		
08:00	1,107	1				1		
09:00	1,171	1				1		
10:00	1,186	1				1		
11:00	1,159	1				1		
12:00	1,080	1				1		
13:00	1,030	1				1		
14:00	0,989	1				1		
15:00	0,964	1				1		
16:00	0,978	1				1		
17:00	1,034	1				1		
18:00	1,126	1				1		
19:00	1,222	1				1		
20:00	1,345	1				1		
21:00	1,366	1				1		
22:00	1,264	1				1		
23:00	1,124	1				1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Πέμπτη, 23 Απριλίου 2026			
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
01:00	1,013	1			1			
02:00	0,953	1						
03:00	0,932	1						
04:00	0,921	1						
05:00	0,907	1						
06:00	0,930	1						
07:00	0,987	1				1		
08:00	1,088	1				1		
09:00	1,134	1				1		
10:00	1,086	1				1		
11:00	1,067	1				1		
12:00	1,068	1				1		
13:00	1,060	1				1		
14:00	1,052	1				1		
15:00	1,105	1				1		
16:00	1,202	1				1		
17:00	1,221	1				1		
18:00	1,257	1				1		
19:00	1,298	1				1		
20:00	1,374	1				1		
21:00	1,384	1				1		
22:00	1,288	1				1		
23:00	1,158	1				1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Παρασκευή, 24 Απριλίου 2026			
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
01:00	1,038	1			1			
02:00	0,992	1			1			
03:00	0,971	1			1			
04:00	0,953	1						
05:00	0,942	1						
06:00	0,954	1						
07:00	1,025	1				1		
08:00	1,045	1				1		
09:00	1,074	1				1		
10:00	1,053	1				1		
11:00	0,990	1				1		
12:00	0,917	1						
13:00	0,849	1						
14:00	0,797	1						
15:00	0,766	1						
16:00	0,791	1						
17:00	0,870	1						
18:00	0,981	1				1		
19:00	1,156	1				1		
20:00	1,413	1				1		
21:00	1,484	1				1		
22:00	1,388	1				1		
23:00	1,222	1				1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Σάββατο, 25 Απριλίου 2026			
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Η Ε Ρ Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
01:00	1,089	1			1			
02:00	0,999	1			1			
03:00	0,962	1			1			
04:00	0,950	1						
05:00	0,955	1						
06:00	0,962	1			1			
07:00	0,992	1			1			
08:00	1,006	1			1			
09:00	1,043	1			1			
10:00	1,042	1			1			
11:00	1,005	1			1			
12:00	0,955	1						
13:00	0,895	1						
14:00	0,838	1						
15:00	0,807	1						
16:00	0,833	1						
17:00	0,923	1						
18:00	1,058	1			1			
19:00	1,252	1			1			
20:00	1,516	1			1			
21:00	1,598	1			1			
22:00	1,482	1			1			
23:00	1,255	1			1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Κυριακή, 26 Απριλίου 2026			
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
01:00	1,095	1			1			
02:00	1,012	1			1			
03:00	0,975	1			1			
04:00	0,958	1			1			
05:00	0,956	1			1			
06:00	0,975	1			1			
07:00	1,018	1			1			
08:00	1,037	1			1			
09:00	1,045	1			1			
10:00	1,032	1			1			
11:00	0,999	1			1			
12:00	0,959	1			1			
13:00	0,913	1						
14:00	0,862	1						
15:00	0,834	1						
16:00	0,864	1						
17:00	0,964	1				1		
18:00	1,111	1				1		
19:00	1,301	1				1		
20:00	1,557	1				1		
21:00	1,604	1				1		
22:00	1,492	1				1		
23:00	1,259	1				1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Δευτέρα, 27 Απριλίου 2026			
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
	01:00	1,092	1			1		
	02:00	1,009	1			1		
	03:00	0,977	1			1		
	04:00	0,967	1			1		
	05:00	0,958	1			1		
	06:00	0,974	1			1		
	07:00	1,014	1			1		
	08:00	1,050	1			1		
	09:00	1,063	1			1		
	10:00	1,038	1			1		
	11:00	1,001	1			1		
	12:00	0,963	1			1		
	13:00	0,920	1					
	14:00	0,875	1					
	15:00	0,846	1					
	16:00	0,866	1					
	17:00	0,939	1					
	18:00	1,062	1			1		
	19:00	1,229	1			1		
	20:00	1,475	1			1		
	21:00	1,535	1			1		
	22:00	1,440	1			1		
	23:00	1,228	1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Τρίτη, 28 Απριλίου 2026			
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
01:00	1,042	1			1			
02:00	0,992	1			1			
03:00	0,979	1			1			
04:00	0,976	1			1			
05:00	0,978	1			1			
06:00	0,998	1			1			
07:00	1,037	1			1			
08:00	1,069	1			1			
09:00	1,087	1			1			
10:00	1,065	1			1			
11:00	1,036	1			1			
12:00	1,019	1			1			
13:00	1,003	1			1			
14:00	0,975	1			1			
15:00	0,941	1						
16:00	0,939	1						
17:00	0,985	1				1		
18:00	1,083	1				1		
19:00	1,230	1				1		
20:00	1,451	1				1		
21:00	1,496	1				1		
22:00	1,371	1				1		
23:00	1,151	1				1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης