

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Προτεινόμενος ΗΕΠ		Πέμπτη, 9 Απριλίου 2026					
Αποδιδόμενη Ισχύς (kW)		80	80	80	90	200	180	400	
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Πέμπτη, 9 Απριλίου 2026	00:00	68					1		
	01:00	62					1		
	02:00	59					1		
	03:00	58					1		
	04:00	58					1		
	05:00	57					1		
	06:00	59					1		
	07:00	56					1		
	08:00	54					1		
	09:00	56					1		
	10:00	59					1		
	11:00	61					1		
	12:00	59					1		
	13:00	58					1		
	14:00	56					1		
	15:00	56					1		
	16:00	56					1		
	17:00	58					1		
	18:00	61					1		
	19:00	67					1		
	20:00	87					1		
	21:00	84					1		
	22:00	80					1		
	23:00	70					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Προτεινόμενος ΗΕΠ		Παρασκευή, 10 Απριλίου 2026					
Αποδιδόμενη Ισχύς (kW)		80	80	80	90	200	180	400	
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
01:00	62					1			
02:00	59					1			
03:00	58					1			
04:00	57					1			
05:00	57					1			
06:00	56					1			
07:00	54					1			
08:00	55					1			
09:00	55					1			
10:00	58					1			
11:00	59					1			
12:00	60					1			
13:00	58					1			
14:00	59					1			
15:00	56					1			
16:00	54					1			
17:00	56					1			
18:00	59					1			
19:00	65					1			
20:00	87					1			
21:00	85					1			
22:00	81					1			
23:00	71					1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Προτεινόμενος ΗΕΠ		Σάββατο, 11 Απριλίου 2026					
Αποδιδόμενη Ισχύς (kW)		80	80	80	90	200	180	400	
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
01:00	65					1			
02:00	63					1			
03:00	62					1			
04:00	61					1			
05:00	61					1			
06:00	59					1			
07:00	56					1			
08:00	55					1			
09:00	54					1			
10:00	55					1			
11:00	55					1			
12:00	55					1			
13:00	55					1			
14:00	53					1			
15:00	52					1			
16:00	52					1			
17:00	55					1			
18:00	59					1			
19:00	66					1			
20:00	86					1			
21:00	85					1			
22:00	81					1			
23:00	72					1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ		Κυριακή, 12 Απριλίου 2026				
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ρ Ε Ι Κ ΟΥ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Κυριακή, 12 Απριλίου 2026	00:00	66					1		
	01:00	64					1		
	02:00	62					1		
	03:00	62					1		
	04:00	61					1		
	05:00	60					1		
	06:00	59					1		
	07:00	57					1		
	08:00	57					1		
	09:00	57					1		
	10:00	58					1		
	11:00	60					1		
	12:00	60					1		
	13:00	60					1		
	14:00	57					1		
	15:00	55					1		
	16:00	53					1		
	17:00	55					1		
	18:00	58					1		
	19:00	63					1		
	20:00	82					1		
	21:00	81					1		
	22:00	76					1		
	23:00	69					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Προτεινόμενος ΗΕΠ		Δευτέρα, 13 Απριλίου 2026					
Αποδιδόμενη Ισχύς (kW)		80	80	80	90	200	180	400	
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
01:00	61					1			
02:00	60					1			
03:00	59					1			
04:00	58					1			
05:00	57					1			
06:00	57					1			
07:00	56					1			
08:00	57					1			
09:00	58					1			
10:00	58					1			
11:00	59					1			
12:00	58					1			
13:00	57					1			
14:00	53					1			
15:00	52					1			
16:00	51					1			
17:00	52					1			
18:00	54					1			
19:00	59					1			
20:00	77					1			
21:00	77					1			
22:00	71					1			
23:00	64					1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ		Τρίτη, 14 Απριλίου 2026				
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τρίτη, 14 Απριλίου 2026	00:00	62					1		
	01:00	60					1		
	02:00	58					1		
	03:00	59					1		
	04:00	58					1		
	05:00	56					1		
	06:00	56					1		
	07:00	55					1		
	08:00	55					1		
	09:00	56					1		
	10:00	56					1		
	11:00	57					1		
	12:00	58					1		
	13:00	55					1		
	14:00	53					1		
	15:00	51					1		
	16:00	51					1		
	17:00	52					1		
	18:00	54					1		
	19:00	58					1		
	20:00	76					1		
	21:00	76					1		
	22:00	71					1		
	23:00	64					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ			Προτεινόμενος ΗΕΠ		Τετάρτη, 15 Απριλίου 2026				
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Τετάρτη, 15 Απριλίου 2026	00:00	62					1		
	01:00	59					1		
	02:00	58					1		
	03:00	59					1		
	04:00	58					1		
	05:00	57					1		
	06:00	56					1		
	07:00	55					1		
	08:00	53					1		
	09:00	53					1		
	10:00	52					1		
	11:00	51					1		
	12:00	52					1		
	13:00	51					1		
	14:00	51					1		
	15:00	51					1		
	16:00	51					1		
	17:00	53					1		
	18:00	56					1		
	19:00	60					1		
	20:00	79					1		
	21:00	79					1		
	22:00	72					1		
	23:00	64					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης