

ΗΣ ΜΕΓΙΣΤΗΣ		Προτεινόμενος ΗΕΠ				Παρασκευή, 24 Απριλίου 2026				
Αποδιδόμενη Ισχύς (MW)		0,380	0,380	0,400	0,220	0,180	0,220	0,220	0,400	
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
01:00	0,304		1				1			
02:00	0,286		1							
03:00	0,278		1							
04:00	0,279		1							
05:00	0,292		1							
06:00	0,311		1				1			
07:00	0,334		1				1			
08:00	0,362		1				1			
09:00	0,377		1				1			
10:00	0,369		1				1			
11:00	0,355		1				1			
12:00	0,363		1				1			
13:00	0,381		1				1			
14:00	0,386		1				1			
15:00	0,387		1				1			
16:00	0,380		1				1			
17:00	0,383		1				1			
18:00	0,401		1				1			
19:00	0,432		1				1			
20:00	0,458		1				1			
21:00	0,435		1				1			
22:00	0,387		1				1			
23:00	0,340		1				1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Προτεινόμενος ΗΕΠ				Σάββατο, 25 Απριλίου 2026				
Αποδιδόμενη Ισχύς (MW)		0,380	0,380	0,400	0,220	0,180	0,220	0,220	0,400	
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
			Σάββατο, 25 Απριλίου 2026	00:00	0,366		1			
01:00	0,333			1				1		
02:00	0,314			1				1		
03:00	0,304			1						
04:00	0,297			1						
05:00	0,293			1						
06:00	0,299			1				1		
07:00	0,320			1				1		
08:00	0,354			1				1		
09:00	0,382			1				1		
10:00	0,388			1				1		
11:00	0,389			1				1		
12:00	0,396			1				1		
13:00	0,403			1				1		
14:00	0,405			1				1		
15:00	0,399			1				1		
16:00	0,391			1				1		
17:00	0,399			1				1		
18:00	0,425			1				1		
19:00	0,456			1				1		
20:00	0,475			1				1		
21:00	0,456			1				1		
22:00	0,414			1				1		
23:00	0,370			1				1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Προτεινόμενος ΗΕΠ				Κυριακή, 26 Απριλίου 2026				
Αποδιδόμενη Ισχύς (MW)		0,380	0,380	0,400	0,220	0,180	0,220	0,220	0,400	
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
01:00	0,337		1				1			
02:00	0,326		1				1			
03:00	0,326		1				1			
04:00	0,327		1				1			
05:00	0,330		1				1			
06:00	0,338		1				1			
07:00	0,360		1				1			
08:00	0,385		1				1			
09:00	0,401		1				1			
10:00	0,408		1				1			
11:00	0,417		1				1			
12:00	0,421		1				1			
13:00	0,426		1				1			
14:00	0,422		1				1			
15:00	0,409		1				1			
16:00	0,394		1				1			
17:00	0,394		1				1			
18:00	0,413		1				1			
19:00	0,442		1				1			
20:00	0,458		1				1			
21:00	0,440		1				1			
22:00	0,403		1				1			
23:00	0,366		1				1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Δευτέρα, 27 Απριλίου 2026			
Αποδιδόμενη Ισχύς (MW)			0,380	0,380	0,400	0,220	0,180	0,220	0,220	0,400
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)								
			G1	G2	G3	G4	G5	G6	G7	G8
Δευτέρα, 27 Απριλίου 2026	00:00	0,366		1					1	
	01:00	0,343		1					1	
	02:00	0,334		1					1	
	03:00	0,334		1					1	
	04:00	0,338		1					1	
	05:00	0,346		1					1	
	06:00	0,356		1					1	
	07:00	0,373		1					1	
	08:00	0,397		1					1	
	09:00	0,404		1					1	
	10:00	0,403		1					1	
	11:00	0,405		1					1	
	12:00	0,423		1					1	
	13:00	0,432		1					1	
	14:00	0,430		1					1	
	15:00	0,416		1					1	
	16:00	0,401		1					1	
	17:00	0,402		1					1	
	18:00	0,421		1					1	
	19:00	0,450		1					1	
	20:00	0,465		1					1	
	21:00	0,447		1					1	
	22:00	0,409		1					1	
	23:00	0,371		1					1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Προτεινόμενος ΗΕΠ				Τρίτη, 28 Απριλίου 2026				
Αποδιδόμενη Ισχύς (MW)		0,380	0,380	0,400	0,220	0,180	0,220	0,220	0,400	
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)								
			G1	G2	G3	G4	G5	G6	G7	G8
Τρίτη, 28 Απριλίου 2026	00:00	0,373		1				1		
	01:00	0,340		1				1		
	02:00	0,326		1				1		
	03:00	0,327		1				1		
	04:00	0,333		1				1		
	05:00	0,343		1				1		
	06:00	0,356		1				1		
	07:00	0,378		1				1		
	08:00	0,412		1				1		
	09:00	0,435		1				1		
	10:00	0,435		1				1		
	11:00	0,439		1				1		
	12:00	0,448		1				1		
	13:00	0,462		1				1		
	14:00	0,463		1				1		
	15:00	0,443		1				1		
	16:00	0,418		1				1		
	17:00	0,410		1				1		
	18:00	0,429		1				1		
	19:00	0,462		1				1		
	20:00	0,477		1				1		
	21:00	0,459		1				1		
	22:00	0,418		1				1		
	23:00	0,372		1				1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ			Προτεινόμενος ΗΕΠ				Τετάρτη, 29 Απριλίου 2026			
Αποδιδόμενη Ισχύς (MW)			0,380	0,380	0,400	0,220	0,180	0,220	0,220	0,400
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
01:00	0,349		1				1			
02:00	0,337		1				1			
03:00	0,334		1				1			
04:00	0,333		1				1			
05:00	0,336		1				1			
06:00	0,348		1				1			
07:00	0,370		1				1			
08:00	0,399		1				1			
09:00	0,415		1				1			
10:00	0,413		1				1			
11:00	0,407		1				1			
12:00	0,415		1				1			
13:00	0,430		1				1			
14:00	0,432		1				1			
15:00	0,419		1				1			
16:00	0,405		1				1			
17:00	0,404		1				1			
18:00	0,425		1				1			
19:00	0,454		1				1			
20:00	0,465		1				1			
21:00	0,445		1				1			
22:00	0,411		1				1			
23:00	0,374		1				1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Προτεινόμενος ΗΕΠ				Πέμπτη, 30 Απριλίου 2026				
Αποδιδόμενη Ισχύς (MW)		0,380	0,380	0,400	0,220	0,180	0,220	0,220	0,400	
Η Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
01:00	0,335		1				1			
02:00	0,316		1				1			
03:00	0,310		1				1			
04:00	0,312		1				1			
05:00	0,322		1				1			
06:00	0,342		1				1			
07:00	0,368		1				1			
08:00	0,394		1				1			
09:00	0,410		1				1			
10:00	0,411		1				1			
11:00	0,415		1				1			
12:00	0,431		1				1			
13:00	0,448		1				1			
14:00	0,454		1				1			
15:00	0,444		1				1			
16:00	0,433		1				1			
17:00	0,434		1				1			
18:00	0,453		1				1			
19:00	0,480		1			1	1			
20:00	0,491		1			1	1			
21:00	0,470		1				1			
22:00	0,424		1				1			
23:00	0,373		1				1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης