

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 19 Μαΐου 2026						
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6	G7
	Τρίτη, 19 Μαΐου 2026	00:00	55			1			
01:00		55			1				
02:00		51			1				
03:00		50			1				
04:00		50			1				
05:00		48			1				
06:00		47			1				
07:00		53					1		
08:00		54					1		
09:00		65					1		
10:00		68					1		
11:00		65					1		
12:00		63					1		
13:00		64					1		
14:00		59					1		
15:00		57					1		
16:00		65			1				
17:00		58			1				
18:00		49			1				
19:00		54			1				
20:00		64			1				
21:00		69			1				
22:00		61			1				
23:00		58			1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 20 Μαΐου 2026						
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6	G7
	Τετάρτη, 20 Μαΐου 2026	00:00	54			1			
01:00		57			1				
02:00		48			1				
03:00		47			1				
04:00		48			1				
05:00		48			1				
06:00		45			1				
07:00		52			1				
08:00		54			1				
09:00		69			1				
10:00		63			1				
11:00		68			1				
12:00		65			1				
13:00		63			1				
14:00		57			1				
15:00		56			1				
16:00		49			1				
17:00		49			1				
18:00		54			1				
19:00		60			1				
20:00		70			1				
21:00		69			1				
22:00		64			1				
23:00		59			1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 21 Μαΐου 2026						
Αποδιδόμενη Ισχύς (kW)		90	90	90	80	85	85	180	
α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6	G7
	Πέμπτη, 21 Μαΐου 2026	00:00	54			1			
01:00		53			1				
02:00		50			1				
03:00		49			1				
04:00		50			1				
05:00		49			1				
06:00		52			1				
07:00		57			1				
08:00		71			1				
09:00		71			1				
10:00		77			1				
11:00		82			1				
12:00		82			1				
13:00		66			1				
14:00		66			1				
15:00		55			1				
16:00		56			1				
17:00		55			1				
18:00		61			1				
19:00		57			1				
20:00		67			1				
21:00		73			1				
22:00		59			1				
23:00		54			1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 22 Μαΐου 2026						
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Ρ Ο Λ Ο Γ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6	G7
	Παρασκευή, 22 Μαΐου 2026	00:00	53			1			
01:00		52			1				
02:00		48			1				
03:00		48			1				
04:00		48			1				
05:00		48			1				
06:00		48			1				
07:00		54		1					
08:00		79		1					
09:00		84		1					
10:00		69		1					
11:00		63		1					
12:00		65		1					
13:00		60		1					
14:00		55		1					
15:00		55		1					
16:00		49		1					
17:00		57		1					
18:00		59		1					
19:00		59		1					
20:00		65		1					
21:00		69		1					
22:00		62		1					
23:00		59		1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 23 Μαΐου 2026						
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6	G7
	Σάββατο, 23 Μαΐου 2026	00:00	54		1				
01:00		55		1					
02:00		52		1					
03:00		50		1					
04:00		48		1					
05:00		46		1					
06:00		40		1					
07:00		49		1					
08:00		50		1					
09:00		63		1					
10:00		69		1					
11:00		67		1					
12:00		74		1					
13:00		65		1					
14:00		55		1					
15:00		51		1					
16:00		49		1					
17:00		51		1					
18:00		53		1					
19:00		56		1					
20:00		62		1					
21:00		72		1					
22:00		62		1					
23:00		60		1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 24 Μαΐου 2026						
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6	G7
	Κυριακή, 24 Μαΐου 2026	00:00	56		1				
01:00		54		1					
02:00		53		1					
03:00		49		1					
04:00		49		1					
05:00		51		1					
06:00		47		1					
07:00		52		1					
08:00		57		1					
09:00		68	1	1					
10:00		73		1					
11:00		68		1					
12:00		68		1					
13:00		68		1					
14:00		66		1					
15:00		52		1					
16:00		53		1					
17:00		56		1					
18:00		63		1					
19:00		59		1					
20:00		60		1					
21:00		70		1					
22:00		63		1					
23:00		62		1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΓΑΘΟΝΗΣΙΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 25 Μαΐου 2026						
Αποδιδόμενη Ισχύς (kW)			90	90	90	80	85	85	180
Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6	G7
	Δευτέρα, 25 Μαΐου 2026	00:00	54		1				
01:00		54		1					
02:00		51		1					
03:00		53		1					
04:00		49		1					
05:00		48		1					
06:00		55		1					
07:00		55		1					
08:00		62					1		
09:00		68					1		
10:00		66					1		
11:00		67					1		
12:00		68					1		
13:00		70		1					
14:00		61		1					
15:00		50		1					
16:00		56		1					
17:00		59		1					
18:00		60		1					
19:00		59		1					
20:00		57		1					
21:00		74		1					
22:00		62		1					
23:00		59		1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης