

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 5 Μαΐου 2026					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
	Τρίτη, 5 Μαΐου 2026	00:00	1,181		1	1		
01:00		1,092		1	1			
02:00		1,023		1	1			
03:00		1,005		1	1			
04:00		1,009		1	1			
05:00		1,072		1	1			
06:00		1,127		1	1			
07:00		1,194		1	1			
08:00		1,153		1	1			
09:00		1,153		1	1			
10:00		1,142		1	1			
11:00		1,212		1	1			
12:00		1,204		1	1			
13:00		1,171		1	1			
14:00		1,135		1	1			
15:00		1,024		1	1			
16:00		1,060		1	1			
17:00		1,121		1	1			
18:00		1,248		1	1			
19:00		1,330		1	1			
20:00		1,494		1	1			
21:00		1,571		1	1			
22:00		1,437		1	1			
23:00		1,290		1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 6 Μαΐου 2026					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
01:00	1,007		1	1				
02:00	0,990		1	1				
03:00	0,954		1	1				
04:00	0,925			1				
05:00	0,942			1				
06:00	0,920			1				
07:00	1,016			1				
08:00	1,048			1				
09:00	1,133		1	1				
10:00	1,147		1	1				
11:00	1,085		1	1				
12:00	1,152		1	1				
13:00	1,178		1	1				
14:00	1,132		1	1				
15:00	1,055		1	1				
16:00	1,111		1	1				
17:00	1,132		1	1				
18:00	1,236		1	1				
19:00	1,299		1	1				
20:00	1,455		1	1				
21:00	1,529		1	1				
22:00	1,401		1	1				
23:00	1,252		1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 7 Μαΐου 2026					
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Ρ Ε Ρ Ε Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
	Πέμπτη, 7 Μαΐου 2026	00:00	1,117		1	1		
01:00		1,028		1	1			
02:00		0,896		1	1			
03:00		0,879		1				
04:00		0,925		1				
05:00		0,922		1				
06:00		0,950		1				
07:00		1,021		1				
08:00		1,077		1	1			
09:00		1,139		1	1			
10:00		1,050		1	1			
11:00		1,055		1	1	1		
12:00		1,138		1	1			
13:00		1,219		1	1	1		
14:00		1,192		1	1	1		
15:00		1,102		1	1			
16:00		1,090		1	1			
17:00		1,192		1	1			
18:00		1,223		1	1			
19:00		1,338		1	1			
20:00		1,452		1	1			
21:00		1,466		1	1			
22:00		1,342		1	1			
23:00		1,214		1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 8 Μαΐου 2026					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
01:00	1,008		1	1				
02:00	0,977		1	1				
03:00	0,978		1					
04:00	0,991		1					
05:00	1,003		1					
06:00	1,027		1					
07:00	1,123		1	1				
08:00	1,205		1	1				
09:00	1,328		1	1				
10:00	1,272		1	1				
11:00	1,283		1	1				
12:00	1,280		1	1				
13:00	1,252		1	1				
14:00	1,324		1	1				
15:00	1,287		1	1				
16:00	1,250		1	1				
17:00	1,314		1	1				
18:00	1,299		1	1				
19:00	1,339		1	1				
20:00	1,469		1	1				
21:00	1,484		1	1				
22:00	1,370		1	1				
23:00	1,204		1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 9 Μαΐου 2026					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
01:00	0,994		1	1				
02:00	0,980			1				
03:00	0,973			1				
04:00	0,974			1				
05:00	0,999			1				
06:00	1,028			1				
07:00	1,190		1	1				
08:00	1,141		1	1				
09:00	1,077		1	1				
10:00	1,091		1	1				
11:00	1,046		1	1				
12:00	1,110		1	1				
13:00	1,098		1	1				
14:00	1,061		1	1				
15:00	1,017		1	1				
16:00	1,012		1	1				
17:00	1,097		1	1				
18:00	1,161		1	1				
19:00	1,351		1	1				
20:00	1,467		1	1				
21:00	1,452		1	1				
22:00	1,341		1	1				
23:00	1,196		1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 10 Μαΐου 2026					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Ρ Ε Ρ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
	Κυριακή, 10 Μαΐου 2026	00:00	1,093		1	1		
01:00		0,998		1	1			
02:00		0,965		1	1			
03:00		0,947		1				
04:00		0,936		1				
05:00		0,938		1				
06:00		0,962		1				
07:00		1,042		1				
08:00		1,091		1	1			
09:00		1,152		1	1			
10:00		0,964		1	1			
11:00		1,221		1	1			
12:00		1,163	1	1	1			
13:00		1,111	1	1		1		
14:00		1,092	1	1		1		
15:00		1,099	1	1				
16:00		1,124	1	1				
17:00		1,069	1	1				
18:00		1,192	1	1				
19:00		1,296	1	1				
20:00	1,485	1	1					
21:00	1,429	1	1					
22:00	1,294	1	1					
23:00	1,178	1	1					

Στις 10:10 σημειώθηκε γενική διακοπή λόγω βλάβης στο δίκτυο.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 11 Μαΐου 2026					
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	0,460	0,460
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G5	G8	G9
	Δευτέρα, 11 Μαΐου 2026	00:00	1,064	1	1			
01:00		1,011	1	1				
02:00		0,958	1	1				
03:00		0,997	1					
04:00		0,993	1					
05:00		0,991	1					
06:00		0,927	1	1				
07:00		1,029		1				
08:00		1,201		1	1			
09:00		1,251		1	1			
10:00		1,169		1	1			
11:00		1,180		1	1			
12:00		1,182		1	1			
13:00		1,211		1	1			
14:00		1,186		1	1			
15:00		1,131		1	1			
16:00		1,147		1	1			
17:00		1,158		1	1			
18:00		1,256		1	1			
19:00		1,385		1	1			
20:00	1,444		1	1				
21:00	1,485		1	1				
22:00	1,311		1	1				
23:00	1,160		1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης