

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Κυριακή, 1 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
Ρ Ε Τ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
	Κυριακή, 1 Φεβρουάριος 2026	00:00	13,61	1		1			1			1	
01:00		12,96	1		1			1			1		
02:00		12,78	1		1			1			1		
03:00		12,63	1		1			1			1		
04:00		12,38	1		1			1			1		
05:00		12,35	1		1			1			1		
06:00		12,81	1		1			1			1		
07:00		13,61	1		1			1			1		
08:00		14,22	1		1			1			1		
09:00		16,08	1		1			1			1		
10:00		17,41	1		1			1			1		
11:00		18,53	1		1			1			1		
12:00		18,88	1		1			1			1		
13:00		18,09	1		1			1			1		
14:00		17,33	1		1			1			1		
15:00		17,00	1		1			1			1		
16:00		17,54	1		1			1			1		
17:00		18,93	1		1			1			1		
18:00		20,04	1		1			1			1		
19:00		19,40	1		1			1			1		
20:00		18,93	1		1			1			1		
21:00		17,84	1		1			1			1		
22:00		16,20	1		1			1			1		
23:00		14,34	1		1			1			1		

Δέκα φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Δευτέρα, 2 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
Ρ Ε Ρ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
	Δευτέρα, 2 Φεβρουάριος 2026	00:00	13,41	1		1			1				1
01:00		12,92	1		1			1				1	
02:00		12,86	1		1			1				1	
03:00		12,49	1		1			1				1	
04:00		12,55	1		1			1				1	
05:00		12,61	1		1			1				1	
06:00		13,34	1		1			1				1	
07:00		15,09	1		1			1				1	
08:00		15,42	1		1			1				1	
09:00		16,55	1		1			1				1	
10:00		16,70	1		1			1				1	
11:00		16,82	1		1			1				1	
12:00		16,85	1		1			1				1	
13:00		17,08	1		1			1				1	
14:00		16,98	1		1			1				1	
15:00		16,90	1		1			1				1	
16:00		17,35	1		1			1				1	
17:00		18,47	1		1			1				1	
18:00		20,17	1		1			1				1	
19:00		20,27	1		1			1				1	
20:00		19,61	1		1			1				1	
21:00		17,94	1		1			1				1	
22:00		16,76	1		1			1				1	
23:00		15,06	1		1			1				1	

Δέκα φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τρίτη, 3 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
Ρ Ε Ρ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
	Τρίτη, 3 Φεβρουάριος 2026	00:00	13,85	1		1			1				1
01:00		13,13	1		1			1				1	
02:00		13,04	1		1			1				1	
03:00		12,66	1		1			1				1	
04:00		12,36	1		1			1				1	
05:00		12,56	1		1			1				1	
06:00		13,16	1		1			1				1	
07:00		15,10	1		1			1				1	
08:00		15,37	1		1			1				1	
09:00		15,95	1		1			1				1	
10:00		15,48	1		1			1				1	
11:00		15,75	1		1			1				1	
12:00		15,91	1		1			1				1	
13:00		15,75	1		1			1				1	
14:00		15,65	1		1			1				1	
15:00		15,40	1		1			1				1	
16:00		16,25	1		1			1				1	
17:00		18,09	1		1			1				1	
18:00		20,18	1		1			1				1	
19:00		20,13	1		1			1				1	
20:00		19,53	1		1			1				1	
21:00		18,10	1		1			1				1	
22:00		16,38	1		1			1				1	
23:00		14,57	1		1			1				1	

Δέκα φορητά βρίσκονται σε βλάβη. Μερική διακοπή από τις 15:43 - 16:37.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης



ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τετάρτη, 4 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
Τετάρτη, 4 Φεβρουάριος 2026	00:00	13,78	1		1			1			1		
	01:00	12,96	1		1			1			1		
	02:00	12,90	1		1			1			1		
	03:00	12,67	1		1			1			1		
	04:00	12,58	1		1			1			1		
	05:00	12,74	1		1			1			1		
	06:00	13,18	1		1			1			1		
	07:00	14,83	1		1			1			1		
	08:00	15,37	1		1			1			1		
	09:00	16,23	1	1	1			1			1		
	10:00	15,63	1	1							1		
	11:00	16,31	1	1							1		
	12:00	17,09	1	1							1		
	13:00	16,79	1	1							1		
	14:00	16,52	1	1							1		
	15:00	16,45	1	1							1		
	16:00	17,07	1	1							1		
	17:00	18,90	1	1							1		
	18:00	20,44	1	1							1		
	19:00	20,40	1	1							1		1
20:00	19,73	1	1							1		1	
21:00	18,78	1	1							1			
22:00	17,60	1	1							1			
23:00	15,47	1	1							1			

Δέκα φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Πέμπτη, 5 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
α ρ ε τ ε ι	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
	Πέμπτη, 5 Φεβρουάριος 2026	00:00	14,09	1	1							1	
01:00		13,51	1	1							1		
02:00		13,25	1	1							1		
03:00		12,76	1	1							1		
04:00		12,23	1	1							1		
05:00		11,96	1	1							1		
06:00		12,92	1	1							1		
07:00		14,27	1	1							1		
08:00		15,68	1	1							1		
09:00		17,39	1	1							1		
10:00		17,67	1	1							1		
11:00		18,24	1	1							1		
12:00		18,93	1	1							1		
13:00		19,18	1	1							1		
14:00		18,61	1	1							1		
15:00		18,45	1	1							1		
16:00		19,28	1	1							1		
17:00		20,22	1	1							1		
18:00		21,14	1	1							1		1
19:00		20,60	1	1							1		1
20:00		20,11	1	1							1		
21:00		18,78	1	1							1		
22:00		17,49	1	1							1		
23:00		15,46	1	1							1		

Δέκα φορητά βρίσκονται σε βλάβη.

 Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Παρασκευή, 6 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
Ρ Ε Τ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
	Παρασκευή, 6 Φεβρουάριος 2026	00:00	13,98	1	1							1	
01:00		12,74	1	1							1		
02:00		12,37	1	1							1		
03:00		12,62	1	1							1		
04:00		12,54	1	1							1		
05:00		12,68	1	1							1		
06:00		13,36	1	1							1		
07:00		14,83	1	1							1		
08:00		15,44	1	1							1		
09:00		16,58	1	1							1		
10:00		16,47	1	1							1		
11:00		16,32	1	1							1		
12:00		16,56	1	1							1		
13:00		17,17	1	1							1		
14:00		17,56	1	1							1		
15:00		17,33	1	1							1		
16:00		18,02	1	1							1		
17:00		18,76	1	1							1		
18:00		20,21	1	1							1		
19:00		19,65	1	1							1		
20:00		18,77	1	1							1		
21:00		17,72	1	1							1		
22:00		16,75	1	1							1		
23:00		15,24	1	1							1		

Δέκα φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Σάββατο, 7 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
Ρ Ε Τ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
	Σάββατο, 7 Φεβρουάριος 2026	00:00	14,11	1	1							1	
01:00		13,38	1	1							1		
02:00		13,04	1	1							1		
03:00		12,51	1	1							1		
04:00		11,78	1	1							1		
05:00		11,76	1	1							1		
06:00		12,29	1	1							1		
07:00		13,63	1	1							1		
08:00		14,19	1	1							1		
09:00		15,44	1	1							1		
10:00		15,68	1	1							1		
11:00		15,80	1	1							1		
12:00		16,03	1	1							1		
13:00		16,10	1	1							1		
14:00		16,07	1	1							1		
15:00		16,01	1	1							1		
16:00		16,80	1	1							1		
17:00		17,74	1	1							1		
18:00		19,19	1	1							1		
19:00		18,87	1	1							1		
20:00		17,95	1	1							1		
21:00		17,21	1	1							1		
22:00		16,22	1	1							1		
23:00		14,71	1	1							1		

Δέκα φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης



ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Κυριακή, 8 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
Ρ Ε Ρ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
	Κυριακή, 8 Φεβρουάριος 2026	00:00	14,07	1	1							1	
01:00		13,05	1	1							1		
02:00		12,50	1	1							1		
03:00		12,46	1	1							1		
04:00		12,25	1	1							1		
05:00		12,25	1	1							1		
06:00		12,44	1	1							1		
07:00		13,18	1	1							1		
08:00		13,37	1	1							1		
09:00		14,19	1	1							1		
10:00		14,64	1	1							1		
11:00		16,04	1	1							1		
12:00		16,86	1	1							1		
13:00		16,34	1	1							1		
14:00		15,71	1	1							1		
15:00		15,26	1	1							1		
16:00		16,03	1	1							1		
17:00		17,21	1	1							1		
18:00		18,98	1	1							1		
19:00		18,97	1	1							1		
20:00		17,99	1	1							1		
21:00		16,61	1	1							1		
22:00		15,47	1	1							1		
23:00		13,92	1	1							1		

Δέκα φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Δευτέρα, 9 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
Ρ Ε Τ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
	Δευτέρα, 9 Φεβρουάριος 2026	00:00	13,09	1	1							1	
01:00		12,41	1		1						1		
02:00		12,13	1		1						1		
03:00		12,00	1		1						1		
04:00		11,92	1		1						1		
05:00		11,85	1		1						1		
06:00		12,58	1		1						1		
07:00		14,09	1		1						1		
08:00		14,53	1	1							1		
09:00		16,04	1	1							1		
10:00		16,39	1	1							1		
11:00		16,28	1	1							1		
12:00		16,52	1	1	1						1		
13:00		16,96	1	1	1						1		
14:00		17,37	1	1							1		
15:00		17,85	1	1							1		
16:00		18,56	1	1							1		
17:00		18,78	1	1							1		
18:00		20,14	1	1							1		
19:00		19,87	1	1							1		
20:00		19,15	1	1							1		
21:00		18,06	1	1							1		
22:00		16,84	1	1							1		
23:00		15,27	1		1						1		

Δέκα φορητά βρίσκονται σε βλάβη. Μερική διακοπή από τις 08:05 - 08:10.

 Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τρίτη, 10 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
Ρ Ε Ρ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
	Τρίτη, 10 Φεβρουάριος 2026	00:00	13,80	1		1						1	
01:00		13,04	1		1						1		
02:00		12,80	1		1						1		
03:00		12,39	1		1						1		
04:00		12,17	1		1						1		
05:00		12,49	1		1						1		
06:00		13,33	1		1						1		
07:00		14,76	1		1						1		
08:00		15,17	1	1	1						1		
09:00		15,89	1	1							1		
10:00		16,17	1		1						1		
11:00		16,33	1	1	1						1		
12:00		16,25	1	1							1		
13:00		16,43	1	1							1		
14:00		16,45	1	1							1		
15:00		16,40	1	1							1		
16:00		17,28	1	1							1		
17:00		18,55	1	1							1		
18:00		19,88	1	1							1		
19:00		19,98	1	1							1		
20:00		19,35	1	1							1		
21:00		17,79	1	1							1		
22:00		16,65	1	1							1		
23:00		15,06	1	1							1		

Δέκα φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τετάρτη, 11 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
			Τετάρτη, 11 Φεβρουάριος 2026	00:00	13,97	1	1						
	01:00	13,21	1	1							1		
	02:00	12,83	1	1							1		
	03:00	12,87	1	1							1		
	04:00	12,81	1	1							1		
	05:00	12,80	1	1							1		
	06:00	13,22	1	1							1		
	07:00	15,19	1	1							1		
	08:00	15,84	1	1							1		
	09:00	17,37	1	1							1		
	10:00	18,13	1	1							1		
	11:00	17,93	1	1							1		
	12:00	17,53	1	1				1			1		
	13:00	17,26	1	1				1			1		
	14:00	17,58	1	1				1			1		
	15:00	16,55	1	1				1			1		
	16:00	17,16	1	1				1			1		
	17:00	18,92	1	1				1			1		
	18:00	20,55	1	1				1			1		
	19:00	20,76	1	1				1			1		
	20:00	20,18	1	1				1			1		
	21:00	18,79	1	1				1			1		
	22:00	17,65	1	1				1			1		
	23:00	15,97	1	1				1			1		

Δέκα φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Πέμπτη, 12 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
Ρ Ε Τ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
	Πέμπτη, 12 Φεβρουάριος 2026	00:00	15,84	1					1			1	
01:00		15,00	1					1			1		
02:00		14,30	1					1			1		
03:00		14,03	1					1			1		
04:00		14,32	1					1			1		
05:00		14,02	1					1			1		
06:00		14,89	1					1			1		
07:00		16,59	1					1			1		
08:00		17,19	1					1			1		
09:00		18,14	1					1			1		
10:00		18,33	1					1			1		
11:00		18,40	1					1			1		
12:00		18,68	1					1			1		
13:00		19,20	1					1			1		
14:00		19,58	1					1			1		1
15:00		19,26	1					1			1		
16:00		20,13	1					1				1	
17:00		21,69	1			1		1				1	
18:00		22,50	1			1		1				1	1
19:00		22,18	1			1		1				1	
20:00		20,77	1			1		1				1	
21:00		19,73	1			1		1				1	
22:00		18,92	1			1		1				1	
23:00		16,96	1			1		1				1	

Δέκα φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Παρασκευή, 13 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
Ρ Ε Τ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
			Παρασκευή, 13 Φεβρουάριος 2026	00:00	14,08	1		1			1		
01:00	13,28	1						1			1		
02:00	12,93	1						1			1		
03:00	12,68	1						1			1		
04:00	12,60	1						1			1		
05:00	12,84	1						1			1		
06:00	13,66	1						1			1		
07:00	15,24	1						1			1		
08:00	15,82	1						1			1		
09:00	17,09	1						1			1		
10:00	17,86	1						1			1		
11:00	18,51	1						1			1		
12:00	17,96	1						1			1		
13:00	18,15	1						1			1		
14:00	18,43	1						1			1		
15:00	18,29	1						1			1		1
16:00	19,13	1						1			1		1
17:00	20,21	1						1			1		1
18:00	21,27	1				1			1		1		
19:00	21,07	1				1			1		1		
20:00	19,95	1				1			1		1		
21:00	18,60	1				1			1		1		
22:00	17,35	1				1			1		1		
23:00	15,88	1				1			1		1		

Δέκα φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Σάββατο, 14 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
α ρ ε τ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
	Σάββατο, 14 Φεβρουάριος 2026	00:00	14,24	1		1			1			1	
01:00		13,29	1					1			1		
02:00		12,51	1					1			1		
03:00		12,15	1					1			1		
04:00		12,18	1					1			1		
05:00		12,52	1					1			1		
06:00		12,88	1					1			1		
07:00		14,07	1					1			1		
08:00		15,15	1					1			1		
09:00		16,39	1					1			1		
10:00		16,77	1					1			1		
11:00		16,72	1					1			1		
12:00		16,26	1					1			1		
13:00		16,47	1					1			1		
14:00		16,64	1					1			1		
15:00		16,37	1					1			1		
16:00		17,04	1					1			1		
17:00		18,11	1					1			1		
18:00		19,50	1					1			1		2
19:00		19,94	1					1			1		2
20:00		19,10	1					1			1		2
21:00		17,79	1					1			1		
22:00		17,01	1					1			1		
23:00		15,40	1					1			1		

Δέκα φορητά βρίσκονται σε βλάβη. Μερική διακοπή από τις 12:19 - 12:34.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Κυριακή, 15 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
Ρ Ε Τ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
01:00	13,55	1					1			1			
02:00	13,11	1					1			1			
03:00	12,85	1					1			1			
04:00	12,70	1					1			1			
05:00	12,90	1					1			1			
06:00	13,23	1					1			1			
07:00	13,87	1					1			1			
08:00	14,47	1					1			1			
09:00	15,69	1					1			1			
10:00	15,00	1					1				1		
11:00	16,32	1	1				1				1		
12:00	17,04	1					1				1		
13:00	16,82	1					1				1		
14:00	16,57	1					1				1		
15:00	16,32	1					1				1		
16:00	17,04	1					1				1		
17:00	18,47	1					1				1	1	
18:00	19,59	1					1				1	1	
19:00	19,40	1					1				1	3	
20:00	18,54	1			1		1				1		
21:00	17,47	1			1		1				1		
22:00	16,54	1			1		1				1		
23:00	14,55	1			1		1				1		

Δέκα φορητά βρίσκονται σε βλάβη. Μερική διακοπή από τις 10:40 - 11:02.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Δευτέρα, 16 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
Ρ Ε Τ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
	Δευτέρα, 16 Φεβρουάριος 2026	00:00	13,45	1					1				1
01:00		13,04	1					1				1	
02:00		12,67	1					1				1	
03:00		12,47	1					1				1	
04:00		12,30	1					1				1	
05:00		12,65	1					1				1	
06:00		12,89	1					1				1	
07:00		14,65	1					1				1	
08:00		15,66	1					1				1	
09:00		16,40	1					1				1	
10:00		15,91	1					1				1	
11:00		15,96	1					1				1	
12:00		16,31	1					1				1	
13:00		15,88	1					1				1	
14:00		16,40	1					1				1	
15:00		16,67	1					1				1	
16:00		17,41	1					1				1	
17:00		18,45	1					1				1	
18:00		19,61	1			1		1				1	
19:00		19,92	1			1		1				1	
20:00		19,26	1			1		1				1	
21:00		18,06	1			1		1				1	
22:00		16,57	1			1		1				1	
23:00		14,98	1			1		1				1	

Δέκα φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τρίτη, 17 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
Ρ Ε Τ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
	Τρίτη, 17 Φεβρουάριος 2026	00:00	13,97	1		1			1				1
01:00		13,43	1					1				1	
02:00		13,17	1					1				1	
03:00		12,87	1					1				1	
04:00		12,30	1					1				1	
05:00		12,04	1					1				1	
06:00		13,11	1					1				1	
07:00		14,55	1					1				1	
08:00		15,81	1					1				1	
09:00		16,63	1					1				1	
10:00		17,00	1					1				1	
11:00		17,77	1					1				1	
12:00		18,88	1					1				1	
13:00		18,90	1					1				1	
14:00		18,70	1					1				1	
15:00		19,06	1					1				1	
16:00		20,41	1		1			1				1	
17:00		21,09	1		1			1				1	
18:00		20,27	1		1			1				1	
19:00		21,00	1		1			1				1	
20:00		20,80	1		1			1				1	
21:00		19,43	1		1			1				1	
22:00		17,99	1		1			1				1	
23:00		16,07	1		1			1				1	

Δέκα φορητά βρίσκονται σε βλάβη. Προγραμματισμένη μερική διακοπή από τις 18:22 - 19:25.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τετάρτη, 18 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
Ρ Ε Τ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
	Τετάρτη, 18 Φεβρουάριος 2026	00:00	14,50	1		1			1				1
01:00		13,78	1					1				1	
02:00		13,46	1					1				1	
03:00		13,18	1					1				1	
04:00		13,24	1					1				1	
05:00		13,14	1					1				1	
06:00		13,70	1					1				1	
07:00		15,34	1					1				1	
08:00		16,45	1					1				1	
09:00		17,35	1					1				1	
10:00		17,57	1					1				1	
11:00		18,12	1					1				1	
12:00		19,02	1					1				1	
13:00		17,63	1					1				1	
14:00		17,30	1					1				1	
15:00		16,83	1					1				1	
16:00		18,01	1					1				1	
17:00		19,42	1					1				1	
18:00		20,80	1					1				1	
19:00		21,46	1			1		1				1	
20:00		21,08	1			1		1				1	
21:00		19,93	1			1		1				1	
22:00		18,89	1			1		1				1	
23:00		16,76	1			1		1				1	

Δέκα φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Πέμπτη, 19 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
Ρ Ε Τ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
	Πέμπτη, 19 Φεβρουάριος 2026	00:00	15,09	1		1			1				1
01:00		14,05	1					1				1	
02:00		13,55	1					1				1	
03:00		13,25	1					1				1	
04:00		13,28	1					1				1	
05:00		13,47	1					1				1	
06:00		13,94	1					1				1	
07:00		15,60	1					1				1	
08:00		15,94	1					1				1	
09:00		16,64	1					1				1	
10:00		16,63	1					1				1	
11:00		17,21	1					1				1	
12:00		17,23	1					1				1	
13:00		16,79	1					1				1	
14:00		16,85	1					1				1	
15:00		16,82	1					1				1	
16:00		17,58	1					1				1	
17:00		18,52	1					1				1	
18:00		20,23	1	1				1				1	
19:00		21,91	1	1				1				1	
20:00		21,77	1	1				1				1	
21:00		19,30	1	1				1				1	
22:00		17,63	1	1				1				1	
23:00		15,82	1	1				1				1	

Δέκα φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Παρασκευή, 20 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
Ρ Ε Ρ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
	Παρασκευή, 20 Φεβρουάριος 2026	00:00	14,73		1				1				1
01:00		13,83		1				1				1	
02:00		13,51		1				1				1	
03:00		12,98		1				1				1	
04:00		12,72		1				1				1	
05:00		12,88		1				1				1	
06:00		13,60		1				1				1	
07:00		15,11		1				1				1	
08:00		15,76		1				1				1	
09:00		16,15		1				1				1	
10:00		16,15		1				1				1	
11:00		16,10		1				1				1	
12:00		16,19		1				1				1	
13:00		16,00		1				1				1	
14:00		16,11		1				1				1	
15:00		16,55		1				1				1	
16:00		17,91		1				1				1	
17:00		18,71		1	1			1				1	
18:00		20,56		1	1			1				1	
19:00		20,58		1	1			1				1	
20:00		19,83		1	1			1				1	
21:00		19,10		1	1			1				1	
22:00		17,78		1	1			1				1	
23:00		16,07		1				1				1	

Δέκα φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης



ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Σάββατο, 21 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
Ρ Ε Τ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
	Σάββατο, 21 Φεβρουάριος 2026	00:00	14,50		1				1				1
01:00		13,68		1				1				1	
02:00		13,73		1				1				1	
03:00		13,88		1				1				1	
04:00		13,54		1				1				1	
05:00		13,72		1				1				1	
06:00		13,84		1				1				1	
07:00		14,79		1				1				1	
08:00		15,88		1				1				1	
09:00		17,27		1				1				1	
10:00		16,70		1				1				1	
11:00		16,48		1				1				1	
12:00		16,60		1				1				1	
13:00		16,85		1				1				1	
14:00		17,18		1				1				1	
15:00		17,29		1				1				1	
16:00		18,07		1	1			1				1	
17:00		18,53		1	1			1				1	
18:00		20,17		1	1			1				1	
19:00		20,39		1	1			1				1	
20:00		19,35		1	1			1				1	
21:00		18,29		1	1			1				1	
22:00		17,54		1	1			1				1	
23:00		15,75		1	1			1				1	

Δέκα φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Κυριακή, 22 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
α ρ ε τ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
	Κυριακή, 22 Φεβρουάριος 2026	00:00	14,98		1	1							1
01:00		13,95		1	1							1	
02:00		13,55		1	1							1	
03:00		13,25		1	1							1	
04:00		13,17		1	1							1	
05:00		13,22		1	1							1	
06:00		13,45		1	1							1	
07:00		14,38		1	1						1		
08:00		15,12		1	1						1		
09:00		16,12		1	1						1		
10:00		16,80		1	1						1		
11:00		17,36		1	1						1		
12:00		17,94		1	1						1		
13:00		17,75		1	1						1		
14:00		17,30		1	1						1		
15:00		17,60		1	1						1		
16:00		19,03		1	1						1	1	
17:00		20,46		1	1						1	1	
18:00		21,38		1	1						1	1	
19:00		21,74		1	1						1	1	
20:00		21,02		1	1				1		1	1	
21:00		19,67		1	1				1		1	1	
22:00		18,80		1	1				1			1	
23:00		16,92		1	1				1			1	

Δέκα φορητά βρίσκονται σε βλάβη. Μερική διακοπή από τις 23:24 - 23:40.

 Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Δευτέρα, 23 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
Ρ Ε Τ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
	Δευτέρα, 23 Φεβρουάριος 2026	00:00	15,64		1				1				1
01:00		14,51		1				1				1	
02:00		13,81		1				1				1	
03:00		13,21		1				1				1	
04:00		12,95		1				1				1	
05:00		13,41		1				1				1	
06:00		13,40		1				1				1	
07:00		14,33		1				1				1	
08:00		15,84		1				1				1	
09:00		18,18		1				1				1	
10:00		18,73		1				1				1	
11:00		18,48		1	1			1				1	
12:00		17,86		1	1			1				1	
13:00		16,77		1	1			1				1	
14:00		16,04		1	1			1				1	
15:00		16,19		1	1			1				1	
16:00		17,18		1	1			1				1	
17:00		18,57		1	1			1				1	
18:00		20,40		1	1			1				1	
19:00		21,25		1	1			1				1	
20:00		20,84		1	1			1				1	
21:00		19,38		1	1			1				1	
22:00		17,78		1	1			1				1	
23:00		16,04		1				1				1	

Δέκα φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τρίτη, 24 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
Ρ Ε Τ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
	Τρίτη, 24 Φεβρουάριος 2026	00:00	16,08		1				1				1
01:00		15,14		1				1				1	
02:00		14,99		1				1				1	
03:00		14,47		1				1				1	
04:00		14,60			1			1				1	
05:00		14,56			1			1				1	
06:00		15,13			1			1				1	
07:00		16,56		1				1				1	
08:00		16,98		1				1				1	
09:00		18,00		1				1				1	
10:00		17,83		1				1				1	
11:00		18,04		1				1				1	
12:00		18,53		1				1				1	
13:00		18,07		1				1				1	
14:00		17,83		1				1				1	
15:00		18,61		1				1				1	
16:00		19,81		1				1				1	
17:00		21,24		1	1			1				1	
18:00		22,85		1	1			1				1	
19:00		23,20		1	1			1				1	
20:00		22,70		1	1			1				1	
21:00		21,62		1	1			1				1	
22:00		19,84		1	1			1				1	
23:00		17,78		1				1				1	

Δέκα φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Τετάρτη, 25 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
Ρ Ε Τ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
	Τετάρτη, 25 Φεβρουάριος 2026	00:00	15,02		1				1				1
01:00		14,24		1				1				1	
02:00		13,80		1				1				1	
03:00		13,56		1				1				1	
04:00		13,13		1				1				1	
05:00		12,60		1				1				1	
06:00		13,08		1				1				1	
07:00		14,72		1				1				1	
08:00		15,45		1				1				1	
09:00		16,55		1				1				1	
10:00		16,44		1				1				1	
11:00		16,76		1				1				1	
12:00		16,87		1				1				1	
13:00		17,49		1				1				1	
14:00		17,84		1				1				1	
15:00		17,76		1				1				1	
16:00		18,39		1				1				1	
17:00		19,37		1				1				1	
18:00		21,01		1	1			1				1	
19:00		21,14		1	1			1				1	
20:00		20,28		1	1			1				1	
21:00		18,67		1	1			1				1	
22:00		17,83		1	1			1				1	
23:00		16,13		1				1				1	

Δέκα φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Πέμπτη, 26 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
Ρ Ε Τ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
	Πέμπτη, 26 Φεβρουάριος 2026	00:00	14,91		1				1				1
01:00		13,82		1				1				1	
02:00		13,24		1				1				1	
03:00		12,98		1				1				1	
04:00		13,05		1				1				1	
05:00		13,47		1				1				1	
06:00		13,74		1				1				1	
07:00		14,69		1				1				1	
08:00		15,06		1				1				1	
09:00		15,81		1				1				1	
10:00		16,55		1				1				1	
11:00		16,86		1				1				1	
12:00		18,38		1				1				1	
13:00		18,04		1				1				1	
14:00		17,54		1				1				1	
15:00		17,52		1				1				1	
16:00		18,80		1				1				1	
17:00		20,37		1	1			1				1	
18:00		22,45		1	1			1				1	
19:00		22,82		1	1			1				1	
20:00		22,16		1	1			1				1	
21:00		20,64		1	1			1				1	
22:00		19,05		1	1			1				1	
23:00		16,86		1	1			1				1	

Δέκα φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Παρασκευή, 27 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
Ρ Ε Τ Ε Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
	Παρασκευή, 27 Φεβρουάριος 2026	00:00	15,32		1				1				1
01:00		14,36		1				1				1	
02:00		13,98		1				1				1	
03:00		14,15		1				1				1	
04:00		14,03		1				1				1	
05:00		14,48		1				1				1	
06:00		14,74		1				1				1	
07:00		15,83		1				1				1	
08:00		16,50		1				1				1	
09:00		18,51		1				1				1	
10:00		18,40		1				1				1	1
11:00		18,09		1				1				1	1
12:00		18,17		1				1				1	1
13:00		18,20		1				1				1	
14:00		18,38		1				1				1	
15:00		18,54		1				1				1	
16:00		19,83		1	1			1				1	
17:00		21,46		1	1			1				1	
18:00		22,94		1	1			1				1	
19:00		23,03		1	1			1				1	
20:00		22,20		1	1			1				1	
21:00		20,91		1	1			1				1	
22:00		19,43		1	1			1				1	
23:00		17,29		1	1			1				1	

Δέκα φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Σάββατο, 28 Φεβρουάριος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
α ρ ε τ ε ι	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z(x16)
	Σάββατο, 28 Φεβρουάριος 2026	00:00	15,71		1				1				1
01:00		14,88		1				1				1	
02:00		14,64		1				1				1	
03:00		14,30		1				1				1	
04:00		14,29		1				1				1	
05:00		14,33		1				1				1	
06:00		14,76		1				1				1	
07:00		15,97		1				1				1	
08:00		17,20		1				1				1	
09:00		18,65		1				1				1	
10:00		19,09		1				1				1	
11:00		20,07		1				1				1	1
12:00		20,83	1	1				1				1	
13:00		20,07	1					1				1	1
14:00		19,23	1					1				1	
15:00		19,54	1					1				1	
16:00		20,85	1		1			1				1	
17:00		22,34	1		1			1				1	
18:00		23,63	1		1			1				1	1
19:00		23,91	1		1			1				1	1
20:00		22,94	1		1			1				1	1
21:00		21,65	1		1			1				1	
22:00		20,12	1		1			1				1	
23:00		17,97	1					1				1	

Δέκα φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης