

ΗΣ ΘΗΡΑΣ		Απολογιστική Λειτουργία για την Προηγούμενη Ημέρα											Πέμπτη, 14 Μαΐου 2026			
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000				
ΤΕ (MW)		4,016	4,016	1,788	1,788	1,788	3,257	4,000	5,000	5,000	5,000	0,510				
Η Ε Ρ Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)	Στρεφόμενη εφεδρεία (MW)	Μέση φόρτιση Μονάδων ΑΣΠ (% επί της αποδιδόμενης)	Κόστος καυσίμου (€)
Πέμπτη, 14 Μαΐου 2026	00:00	36,46	1	1			1	1		1		1		7,62	82%	8.865
	01:00	33,47	1	1			1	1		1		1		10,61	75%	8.385
	02:00	32,35	1	1			1	1		1		1		11,74	73%	8.202
	03:00	31,84	1	1			1	1		1		1		12,24	72%	8.119
	04:00	31,92	1	1			1	1		1		1		12,16	72%	8.132
	05:00	32,11	1	1			1	1		1		1		11,98	72%	8.162
	06:00	33,88	1	1			1	1		1		1		10,21	76%	8.451
	07:00	37,77	1	1			1	1		1		1		6,32	85%	9.072
	08:00	41,02	1	1			1	1		1		1		5,06	89%	9.803
	09:00	42,76	1	1			1	1		1		1		3	91%	10.191
	10:00	43,62	1	1			1	1		1		1		4	91%	10.438
	11:00	43,65	1	1			1	1		1	1	1		10,58	80%	12.256
	12:00	43,68	1	1			1	1		1	1	1		10,56	80%	11.939
	13:00	43,82	1	1			1	1		1	1	1		10,41	80%	11.963
	14:00	42,99	1	1			1	1		1	1	1		11,24	79%	11.823
	15:00	41,47	1	1			1	1		1	1	1		12,76	76%	11.563
	16:00	40,77	1	1			1	1		1	1	1		13,46	75%	11.442
	17:00	41,56	1	1			1	1		1	1	1		12,68	76%	11.578
	18:00	42,68	1	1			1	1		1	1	1		11,56	78%	11.769
19:00	43,25	1	1			1	1		1	1	1		10,98	79%	11.867	
20:00	45,59	1	1			1	1		1	1	1		8,65	84%	12.261	
21:00	46,20	1	1			1	1		1	1	1		8,04	85%	12.363	
22:00	43,92	1	1			1	1		1	1	1		10,31	81%	11.980	
23:00	40,15	1	1			1	1		1	1	1		14,09	74%	11.334	
		956,91 MWh														251.957 €

Παρατηρήσεις:

Δεν προτείνεται οποιαδήποτε αλλαγή στην απολογιστική λειτουργία. Τρία φορητά H/Z βρίσκονται σε βλάβη.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης