

ΗΣ ΘΗΡΑΣ		Απολογισμός Λειτουργίας			Σάββατο, 23 Μαΐου 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
Α Ρ Ρ Ε Σ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Σάββατο, 23 Μαΐου 2026	00:00	35,47	1	1			1	1			1	1	
	01:00	32,95	1	1			1	1			1	1	
	02:00	31,45	1	1			1	1			1	1	
	03:00	31,24	1	1			1	1			1	1	
	04:00	31,23	1	1			1	1			1	1	
	05:00	31,35	1	1			1	1			1	1	
	06:00	32,40	1	1			1	1			1	1	
	07:00	36,16	1	1			1	1			1	1	4
	08:00	39,87	1	1			1	1			1	1	4
	09:00	42,36	1	1			1	1			1	1	3
	10:00	44,52	1	1			1	1			1	1	3
	11:00	46,21	1	1			1	1		1	1	1	3
	12:00	47,43	1	1			1	1		1	1	1	2
	13:00	47,16	1	1			1	1		1	1	1	
	14:00	46,08	1	1			1	1		1	1	1	
	15:00	43,62	1	1			1	1		1	1	1	
	16:00	43,91	1	1			1	1		1	1	1	
	17:00	44,45	1	1			1	1		1	1	1	7
	18:00	45,41	1	1			1	1		1	1	1	7
	19:00	45,55	1	1			1	1		1	1	1	7
20:00	46,45	1	1			1	1		1	1	1	7	
21:00	44,70	1	1			1	1		1	1	1	7	
22:00	40,52	1	1			1	1		1	1	1	7	
23:00	37,80	1	1			1	1		1	1	1	2	

Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
Μη διαθεσιμότητα μονάδας λόγω βλάβης