

ΗΣ ΓΑΥΔΟΥ		Προτεινόμενος ΗΕΠ		Παρασκευή, 29 Μαΐου 2026			
Αποδιδόμενη Ισχύς (kW)		100	90	80	85	400	
Η Ε Ρ Ε Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5
01:00	64		1				
02:00	63		1				
03:00	62		1				
04:00	63		1				
05:00	62		1				
06:00	62		1				
07:00	62		1				
08:00	64		1				
09:00	66		1				
10:00	68		1				
11:00	68		1				
12:00	68		1				
13:00	69		1				
14:00	70		1				
15:00	71		1				
16:00	71		1				
17:00	71		1				
18:00	70		1				
19:00	71		1				
20:00	73		1	1			
21:00	77		1	1			
22:00	80		1	1			
23:00	72		1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΓΑΥΔΟΥ		Προτεινόμενος ΗΕΠ		Σάββατο, 30 Μαΐου 2026			
Αποδιδόμενη Ισχύς (kW)		100	90	80	85	400	
Η Ε Ρ Ε Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5
01:00	64		1				
02:00	61		1				
03:00	60		1				
04:00	62		1				
05:00	61		1				
06:00	61		1				
07:00	62		1				
08:00	65		1				
09:00	69		1				
10:00	72		1	1			
11:00	74		1	1			
12:00	75		1	1			
13:00	75		1	1			
14:00	75		1	1			
15:00	75		1	1			
16:00	74		1	1			
17:00	73		1	1			
18:00	73		1	1			
19:00	74		1	1			
20:00	76		1	1			
21:00	78		1	1			
22:00	79		1	1			
23:00	73		1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΓΑΥΔΟΥ		Προτεινόμενος ΗΕΠ		Κυριακή, 31 Μαΐου 2026			
Αποδιδόμενη Ισχύς (kW)		100	90	80	85	400	
Η Ε Ρ Ε Τ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5
Κυριακή, 31 Μαΐου 2026	00:00	69		1			
	01:00	67		1			
	02:00	64		1			
	03:00	63		1			
	04:00	61		1			
	05:00	60		1			
	06:00	59		1			
	07:00	61		1			
	08:00	64		1			
	09:00	70		1			
	10:00	75		1	1		
	11:00	77		1	1		
	12:00	75		1	1		
	13:00	73		1	1		
	14:00	71		1			
	15:00	70		1			
	16:00	69		1			
	17:00	68		1			
	18:00	69		1			
	19:00	72		1	1		
	20:00	75		1	1		
	21:00	78		1	1		
	22:00	76		1	1		
	23:00	73		1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΓΑΥΔΟΥ		Προτεινόμενος ΗΕΠ		Δευτέρα, 1 Ιουνίου 2026			
Αποδιδόμενη Ισχύς (kW)		100	90	80	85	400	
Η Ε Ρ Ρ Ε Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5
			Δευτέρα, 1 Ιουνίου 2026	00:00	67		1
01:00	63			1			
02:00	60			1			
03:00	59			1			
04:00	58			1			
05:00	59			1			
06:00	60			1			
07:00	64			1			
08:00	68			1			
09:00	74			1	1		
10:00	77			1	1		
11:00	78			1	1		
12:00	77			1	1		
13:00	75			1	1		
14:00	72			1	1		
15:00	70			1			
16:00	68			1			
17:00	68			1			
18:00	70			1			
19:00	74			1	1		
20:00	78			1	1		
21:00	79			1	1		
22:00	78			1	1		
23:00	76			1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΓΑΥΔΟΥ		Προτεινόμενος ΗΕΠ		Τρίτη, 2 Ιουνίου 2026			
Αποδιδόμενη Ισχύς (kW)		100	90	80	85	400	
Η Ε Ρ Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5
Τρίτη, 2 Ιουνίου 2026	00:00	68		1			
	01:00	63		1			
	02:00	60		1			
	03:00	58		1			
	04:00	57		1			
	05:00	57		1			
	06:00	58		1			
	07:00	61		1			
	08:00	66		1			
	09:00	70		1			
	10:00	73		1	1		
	11:00	75		1	1		
	12:00	75		1	1		
	13:00	75		1	1		
	14:00	74		1	1		
	15:00	72		1	1		
	16:00	71		1			
	17:00	70		1			
	18:00	71		1			
	19:00	74		1	1		
	20:00	78		1	1		
	21:00	78		1	1		
	22:00	77		1	1		
	23:00	74		1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΓΑΥΔΟΥ		Προτεινόμενος ΗΕΠ		Τετάρτη, 3 Ιουνίου 2026			
Αποδιδόμενη Ισχύς (kW)		100	90	80	85	400	
Η Ε Ρ Ε Τ Ε	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5
01:00	67		1				
02:00	65		1				
03:00	63		1				
04:00	61		1				
05:00	61		1				
06:00	61		1				
07:00	64		1				
08:00	69		1				
09:00	78		1	1			
10:00	81		1	1			
11:00	83		1	1			
12:00	83		1	1			
13:00	80		1	1			
14:00	81		1	1			
15:00	79		1	1			
16:00	78		1	1			
17:00	76		1	1			
18:00	76		1	1			
19:00	78		1	1			
20:00	81		1	1			
21:00	85		1	1			
22:00	90		1	1			
23:00	78		1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΓΑΥΔΟΥ		Προτεινόμενος ΗΕΠ		Πέμπτη, 4 Ιουνίου 2026			
Αποδιδόμενη Ισχύς (kW)		100	90	80	85	400	
Η Ε Ρ Ε Τ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5
01:00	68		1				
02:00	64		1				
03:00	62		1				
04:00	60		1				
05:00	60		1				
06:00	61		1				
07:00	65		1				
08:00	70		1				
09:00	74		1	1			
10:00	77		1	1			
11:00	79		1	1			
12:00	80		1	1			
13:00	80		1	1			
14:00	81		1	1			
15:00	80		1	1			
16:00	79		1	1			
17:00	77		1	1			
18:00	77		1	1			
19:00	78		1	1			
20:00	81		1	1			
21:00	84		1	1			
22:00	87		1	1			
23:00	79		1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης