

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Απολογισμός Λειτουργίας	Τετάρτη, 13 Μαΐου 2026						
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6	G7
	Τετάρτη, 13 Μαΐου 2026	00:00	67		1		1		
01:00		66		1		1			
02:00		61		1		1			
03:00		62		1		1			
04:00		64		1		1			
05:00		64		1		1			
06:00		57		1		1			
07:00		59		1		1			
08:00		65		1		1			
09:00		65		1		1			
10:00		62		1		1			
11:00		64		1		1			
12:00		65		1		1			
13:00		59		1		1			
14:00		57		1		1			
15:00		57		1		1			
16:00		65		1		1			
17:00		67		1		1			
18:00		73		1		1			
19:00		86		1		1			
20:00		93		1		1			
21:00		94		1		1			
22:00		82		1		1			
23:00		75		1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Απολογισμός Λειτουργίας	Πέμπτη, 14 Μαΐου 2026						
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6	G7
			Πέμπτη, 14 Μαΐου 2026	00:00	67		1		1
01:00	59			1		1			
02:00	65			1		1			
03:00	62			1		1			
04:00	59			1		1			
05:00	62			1		1			
06:00	59						1		
07:00	60						1		
08:00	63						1		
09:00	64						1		
10:00	0								
11:00	0								
12:00	0								
13:00	84			1			1		
14:00	77						1		
15:00	74						1		
16:00	66						1		
17:00	59						1		
18:00	59						1		
19:00	75						1		
20:00	84						1		
21:00	93						1		
22:00	88						1		
23:00	76						1		

Το διάστημα 10:00 με 14:00 πραγματοποιήθηκαν προγραμματισμένες εργασίες στον ΤΣΠ

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Απολογισμός Λειτουργίας	Παρασκευή, 15 Μαΐου 2026						
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6	G7
	Παρασκευή, 15 Μαΐου 2026	00:00	70					1	
01:00		61					1		
02:00		60					1		
03:00		61					1		
04:00		61					1		
05:00		60					1		
06:00		54					1		
07:00		65					1		
08:00		63					1		
09:00		68					1		
10:00		78					1		
11:00		74					1		
12:00		72					1		
13:00		74					1		
14:00		72					1		
15:00		70					1		
16:00		67					1		
17:00		58					1		
18:00		69					1		
19:00		75					1		
20:00	82					1			
21:00	99					1			
22:00	82					1			
23:00	77					1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Απολογισμός Λειτουργίας	Σάββατο, 16 Μαΐου 2026						
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6	G7
	Σάββατο, 16 Μαΐου 2026	00:00	68					1	
01:00		61					1		
02:00		59					1		
03:00		60					1		
04:00		62					1		
05:00		59					1		
06:00		61					1		
07:00		72					1		
08:00		72					1		
09:00		76					1		
10:00		78					1		
11:00		81					1		
12:00		80					1		
13:00		79					1		
14:00		71					1		
15:00		61					1		
16:00		74					1		
17:00		75					1		
18:00		80					1		
19:00		84					1		
20:00	89					1			
21:00	112					1			
22:00	94					1			
23:00	87					1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Απολογισμός Λειτουργίας	Κυριακή, 17 Μαΐου 2026						
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6	G7
	Κυριακή, 17 Μαΐου 2026	00:00	75					1	
01:00		72					1		
02:00		71					1		
03:00		68					1		
04:00		68					1		
05:00		68					1		
06:00		66					1		
07:00		71					1		
08:00		85					1		
09:00		74					1		
10:00		72					1		
11:00		77					1		
12:00		79					1		
13:00		81					1		
14:00		74					1		
15:00		63					1		
16:00		62					1		
17:00		63					1		
18:00		70					1		
19:00		71					1		
20:00	88					1			
21:00	102					1			
22:00	97					1			
23:00	76					1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Απολογισμός Λειτουργίας	Δευτέρα, 18 Μαΐου 2026						
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Ρ Ε Π Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6	G7
	Δευτέρα, 18 Μαΐου 2026	00:00	68					1	
01:00		64					1		
02:00		63					1		
03:00		62					1		
04:00		64					1		
05:00		64					1		
06:00		62					1		
07:00		77					1		
08:00		81					1		
09:00		71					1		
10:00		68					1		
11:00		70					1		
12:00		71					1		
13:00		73					1		
14:00		76					1		
15:00		73					1		
16:00		79					1		
17:00		78					1		
18:00		73					1		
19:00		81					1		
20:00	86					1			
21:00	105					1			
22:00	90					1			
23:00	80					1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Απολογισμός Λειτουργίας	Τρίτη, 19 Μαΐου 2026						
Αποδιδόμενη Ισχύς (kW)			80	80	80	90	200	180	400
Ρ Ε Ρ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6	G7
			Τρίτη, 19 Μαΐου 2026	00:00	73				
01:00	65						1		
02:00	65						1		
03:00	61						1		
04:00	59						1		
05:00	61						1		
06:00	59						1		
07:00	66						1		
08:00	81						1		
09:00	76						1		
10:00	79						1		
11:00	71						1		
12:00	59						1		
13:00	55						1		
14:00	59						1		
15:00	52						1		
16:00	54						1		
17:00	61						1		
18:00	72						1		
19:00	61						1		
20:00	70						1		
21:00	75						1		
22:00	77						1		
23:00	67						1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης