

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Προτεινόμενος ΗΕΠ		Πέμπτη, 7 Μαΐου 2026					
Αποδιδόμενη Ισχύς (kW)		80	80	80	90	200	180	400	
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
01:00	61					1			
02:00	58					1			
03:00	59					1			
04:00	60					1			
05:00	60					1			
06:00	56					1			
07:00	59					1			
08:00	60					1			
09:00	59					1			
10:00	59					1			
11:00	58					1			
12:00	58					1			
13:00	58					1			
14:00	57					1			
15:00	54					1			
16:00	54					1			
17:00	55					1			
18:00	56					1			
19:00	61					1			
20:00	68					1			
21:00	78					1			
22:00	73					1			
23:00	69					1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Προτεινόμενος ΗΕΠ		Παρασκευή, 8 Μαΐου 2026					
Αποδιδόμενη Ισχύς (kW)		80	80	80	90	200	180	400	
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
Παρασκευή, 8 Μαΐου 2026	00:00	70					1		
	01:00	65					1		
	02:00	64					1		
	03:00	63					1		
	04:00	62					1		
	05:00	61					1		
	06:00	59					1		
	07:00	60					1		
	08:00	62					1		
	09:00	63					1		
	10:00	64					1		
	11:00	62					1		
	12:00	61					1		
	13:00	60					1		
	14:00	58					1		
	15:00	55					1		
	16:00	52					1		
	17:00	51					1		
	18:00	53					1		
	19:00	60					1		
	20:00	68					1		
	21:00	78					1		
	22:00	80					1		
	23:00	76					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Προτεινόμενος ΗΕΠ		Σάββατο, 9 Μαΐου 2026					
Αποδιδόμενη Ισχύς (kW)		80	80	80	90	200	180	400	
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
01:00	64					1			
02:00	60					1			
03:00	59					1			
04:00	59					1			
05:00	58					1			
06:00	57					1			
07:00	56					1			
08:00	57					1			
09:00	61					1			
10:00	66					1			
11:00	70					1			
12:00	72					1			
13:00	74					1			
14:00	75					1			
15:00	74					1			
16:00	72					1			
17:00	69					1			
18:00	67					1			
19:00	69					1			
20:00	73					1			
21:00	82					1			
22:00	87					1			
23:00	81					1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Προτεινόμενος ΗΕΠ		Κυριακή, 10 Μαΐου 2026					
Αποδιδόμενη Ισχύς (kW)		80	80	80	90	200	180	400	
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
01:00	68					1			
02:00	66					1			
03:00	64					1			
04:00	64					1			
05:00	64					1			
06:00	63					1			
07:00	62					1			
08:00	61					1			
09:00	62					1			
10:00	64					1			
11:00	66					1			
12:00	71					1			
13:00	75					1			
14:00	79					1			
15:00	79					1			
16:00	75					1			
17:00	72					1			
18:00	70					1			
19:00	72					1			
20:00	78					1			
21:00	87					1			
22:00	89					1			
23:00	82					1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Προτεινόμενος ΗΕΠ		Δευτέρα, 11 Μαΐου 2026					
Αποδιδόμενη Ισχύς (kW)		80	80	80	90	200	180	400	
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
01:00	70					1			
02:00	67					1			
03:00	65					1			
04:00	65					1			
05:00	64					1			
06:00	62					1			
07:00	62					1			
08:00	64					1			
09:00	65					1			
10:00	65					1			
11:00	68					1			
12:00	70					1			
13:00	71					1			
14:00	71					1			
15:00	69					1			
16:00	68					1			
17:00	68					1			
18:00	69					1			
19:00	73					1			
20:00	77					1			
21:00	88					1			
22:00	88					1			
23:00	83					1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Προτεινόμενος ΗΕΠ		Τρίτη, 12 Μαΐου 2026					
Αποδιδόμενη Ισχύς (kW)		80	80	80	90	200	180	400	
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
01:00	67					1			
02:00	63					1			
03:00	64					1			
04:00	65					1			
05:00	64					1			
06:00	61					1			
07:00	65					1			
08:00	65					1			
09:00	66					1			
10:00	68					1			
11:00	70					1			
12:00	71					1			
13:00	70					1			
14:00	66					1			
15:00	60					1			
16:00	59					1			
17:00	58					1			
18:00	62					1			
19:00	68					1			
20:00	79					1			
21:00	96					1			
22:00	90					1			
23:00	80					1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΕΡΕΙΚΟΥΣΑΣ		Προτεινόμενος ΗΕΠ		Τετάρτη, 13 Μαΐου 2026					
Αποδιδόμενη Ισχύς (kW)		80	80	80	90	200	180	400	
Η Ε Ρ Ε Ι Κ Ο Υ Σ Α Σ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (kW)	G1	G2	G3	G4	G5	G6	G7
01:00	63					1			
02:00	60					1			
03:00	60					1			
04:00	61					1			
05:00	60					1			
06:00	57					1			
07:00	60					1			
08:00	60					1			
09:00	61					1			
10:00	62					1			
11:00	62					1			
12:00	63					1			
13:00	63					1			
14:00	62					1			
15:00	60					1			
16:00	58					1			
17:00	56					1			
18:00	57					1			
19:00	60					1			
20:00	68					1			
21:00	80					1			
22:00	78					1			
23:00	72					1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης