



ΗΣ ΟΘΩΝΩΝ		Απολογισμός Λειτουργίας	Τετάρτη, 6 Μαΐου 2026					
Αποδιδόμενη Ισχύς (kW)			80	80	80	180	200	190
Η Ρ Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6
	Τετάρτη, 6 Μαΐου 2026	00:00	68					1
01:00		66					1	
02:00		64					1	
03:00		62					1	
04:00		61					1	
05:00		60					1	
06:00		59					1	
07:00		60					1	
08:00		63					1	
09:00		64	1		1			
10:00		57	1		1			
11:00		56					1	
12:00		54					1	
13:00		52					1	
14:00		50					1	
15:00		49					1	
16:00		48					1	
17:00		51					1	
18:00		70					1	
19:00		56					1	
20:00		63					1	
21:00		78					1	
22:00		76					1	
23:00		77					1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΟΘΩΝΩΝ		Απολογισμός Λειτουργίας	Πέμπτη, 7 Μαΐου 2026					
Αποδιδόμενη Ισχύς (kW)			80	80	80	180	200	190
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6
			Πέμπτη, 7 Μαΐου 2026	00:00	73			
01:00	67						1	
02:00	66						1	
03:00	61						1	
04:00	59						1	
05:00	59						1	
06:00	56						1	
07:00	56						1	
08:00	58						1	
09:00	50						1	
10:00	58						1	
11:00	53						1	
12:00	50						1	
13:00	55						1	
14:00	53						1	
15:00	49						1	
16:00	48						1	
17:00	51						1	
18:00	56						1	
19:00	51						1	
20:00	60						1	
21:00	79						1	
22:00	79						1	
23:00	71						1	

 Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΟΘΩΝΩΝ		Απολογισμός Λειτουργίας	Παρασκευή, 8 Μαΐου 2026					
Αποδιδόμενη Ισχύς (kW)			80	80	80	180	200	190
Η Ρ Ρ Ρ Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6
Παρασκευή, 8 Μαΐου 2026	00:00	60					1	
	01:00	59					1	
	02:00	59					1	
	03:00	57					1	
	04:00	55					1	
	05:00	57					1	
	06:00	57					1	
	07:00	57					1	
	08:00	59					1	
	09:00	71					1	
	10:00	69					1	
	11:00	61					1	
	12:00	60					1	
	13:00	67					1	
	14:00	64					1	
	15:00	60					1	
	16:00	62					1	
	17:00	60					1	
	18:00	62					1	
	19:00	59					1	
	20:00	66					1	
	21:00	88					1	
	22:00	90					1	
	23:00	80					1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης



ΗΣ ΟΘΩΝΩΝ		Απολογισμός Λειτουργίας	Σάββατο, 9 Μαΐου 2026					
Αποδιδόμενη Ισχύς (kW)			80	80	80	180	200	190
Η Ρ Α Ρ Ε Τ Ε	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6
	Σάββατο, 9 Μαΐου 2026	00:00	71					1
01:00		72					1	
02:00		68					1	
03:00		66					1	
04:00		65					1	
05:00		63					1	
06:00		64					1	
07:00		56					1	
08:00		63					1	
09:00		57					1	
10:00		61					1	
11:00		59					1	
12:00		62					1	
13:00		60					1	
14:00		55					1	
15:00		49					1	
16:00		51					1	
17:00		49					1	
18:00		56					1	
19:00		66					1	
20:00		70					1	
21:00		101					1	
22:00		94					1	
23:00		85					1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΟΘΩΝΩΝ		Απολογισμός Λειτουργίας	Κυριακή, 10 Μαΐου 2026					
Αποδιδόμενη Ισχύς (kW)			80	80	80	180	200	190
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6
01:00	71					1		
02:00	70					1		
03:00	69					1		
04:00	68					1		
05:00	67					1		
06:00	65					1		
07:00	67					1		
08:00	67					1		
09:00	68					1		
10:00	68					1		
11:00	69					1		
12:00	63					1		
13:00	71					1		
14:00	58					1		
15:00	52					1		
16:00	53					1		
17:00	55					1		
18:00	51					1		
19:00	60					1		
20:00	60					1		
21:00	76					1		
22:00	87					1		
23:00	84					1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΟΘΩΝΩΝ		Απολογισμός Λειτουργίας	Δευτέρα, 11 Μαΐου 2026					
Αποδιδόμενη Ισχύς (kW)			80	80	80	180	200	190
Η Ρ Α Ρ Ε Τ Ε	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6
	Δευτέρα, 11 Μαΐου 2026	00:00	70					1
01:00		68					1	
02:00		64					1	
03:00		64					1	
04:00		62					1	
05:00		62					1	
06:00		57					1	
07:00		62					1	
08:00		63					1	
09:00		64					1	
10:00		64					1	
11:00		55					1	
12:00		64					1	
13:00		66					1	
14:00		57					1	
15:00		56					1	
16:00		69					1	
17:00		67					1	
18:00		67					1	
19:00		74					1	
20:00		70					1	
21:00		82					1	
22:00		85					1	
23:00		75					1	

 Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΟΘΩΝΩΝ		Απολογισμός Λειτουργίας	Τρίτη, 12 Μαΐου 2026					
Αποδιδόμενη Ισχύς (kW)			80	80	80	180	200	190
Η Ρ Ε Π Ε	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (kW)	G1	G2	G3	G4	G5	G6
01:00	71					1		
02:00	69					1		
03:00	69					1		
04:00	68					1		
05:00	68					1		
06:00	66					1		
07:00	68					1		
08:00	68					1		
09:00	66					1		
10:00	63					1		
11:00	69					1		
12:00	71					1		
13:00	71					1		
14:00	65					1		
15:00	64					1		
16:00	62					1		
17:00	64					1		
18:00	62					1		
19:00	69					1		
20:00	75					1		
21:00	85					1		
22:00	92					1		
23:00	75					1		

Γενική διακοπή λόγω βλάβης στο δίκτυο στις 21:10.

- Μη διαθεσιμότητα μονάδας λόγω συντήρησης
- Μη διαθεσιμότητα μονάδας λόγω βλάβης