

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τετάρτη, 1 Απρίλιος 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
α ρ ε τ η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
			Τετάρτη, 1 Απρίλιος 2026	00:00	22,50	1	1				1		
01:00	20,90	1		1				1			1		
02:00	19,74	1		1				1			1		
03:00	19,05	1		1				1			1		
04:00	18,86	1		1				1			1		
05:00	18,98	1		1				1			1		
06:00	20,42	1		1				1			1		
07:00	22,43	1		1				1			1		
08:00	22,80	1		1				1			1		
09:00	23,74	1		1				1			1		
10:00	24,25	1		1				1			1		
11:00	24,64	1		1				1			1		
12:00	24,57	1		1				1			1		
13:00	24,33	1		1				1			1		
14:00	24,08	1		1				1			1		
15:00	23,70	1		1				1			1		
16:00	24,33	1		1				1			1		
17:00	25,09	1		1				1			1		1
18:00	25,48	1		1				1			1		1
19:00	26,74	1		1				1			1		3
20:00	29,32	1		1				1			1		6
21:00	28,66	1		1				1			1		5
22:00	26,77	1		1				1			1		3
23:00	23,97	1		1				1			1		

Τρία φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Πέμπτη, 2 Απρίλιος 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
α ρ ε τ η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
			Πέμπτη, 2 Απρίλιος 2026	00:00	22,31	1	1				1		
01:00	20,90	1		1				1			1		
02:00	19,99	1		1				1			1		
03:00	19,81	1		1				1			1		
04:00	19,41	1		1				1			1		
05:00	19,36	1		1				1			1		
06:00	20,56	1		1				1			1		
07:00	22,67	1		1				1			1		
08:00	23,95	1		1				1			1		
09:00	26,87	1		1				1			1	1	
10:00	28,39	1		1				1			1	1	
11:00	29,12	1		1				1			1	1	
12:00	29,32	1		1				1			1	1	
13:00	29,94	1		1				1			1	1	
14:00	29,52	1		1				1			1	1	
15:00	29,24	1		1				1			1	1	
16:00	30,18	1		1				1			1	1	
17:00	30,25	1		1				1			1	1	
18:00	29,76	1		1				1			1	1	
19:00	30,29	1		1				1			1	1	
20:00	31,70	1		1				1			1	1	
21:00	30,93	1		1				1			1	1	
22:00	28,64	1		1				1			1	1	
23:00	26,18	1		1				1			1		2

Τρία φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Παρασκευή, 3 Απρίλιος 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	11,150	1,000	
α ρ ε τ ε π	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
			Παρασκευή, 3 Απρίλιος 2026	00:00	22,56	1	1				1		
01:00	21,13	1		1				1			1		
02:00	20,21	1		1				1			1		
03:00	20,02	1		1				1			1		
04:00	19,62	1		1				1			1		
05:00	19,57	1		1				1			1		
06:00	20,78	1		1				1			1		
07:00	22,91	1		1				1			1		
08:00	24,21	1		1				1			1		
09:00	27,17	1		1				1			1	1	
10:00	28,70	1		1				1			1	1	
11:00	29,43	1		1				1			1	1	
12:00	29,64	1		1				1			1	1	
13:00	30,26	1		1				1			1	1	
14:00	29,84	1		1				1			1	1	
15:00	29,56	1		1				1			1	1	
16:00	30,51	1		1				1			1	1	
17:00	30,58	1		1				1			1	1	
18:00	30,08	1		1				1			1	1	
19:00	30,62	1		1				1			1	1	
20:00	32,04	1		1				1			1	1	
21:00	31,26	1		1				1			1	1	
22:00	28,95	1		1				1			1	1	
23:00	26,47	1		1				1			1		2

Τρία φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Σάββατο, 4 Απρίλιος 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
α ρ χ η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
			Σάββατο, 4 Απρίλιος 2026	00:00	22,83	1	1				1		
01:00	21,38	1		1				1			1		
02:00	20,45	1		1				1			1		
03:00	20,26	1		1				1			1		
04:00	19,86	1		1				1			1		
05:00	19,81	1		1				1			1		
06:00	21,03	1		1				1			1		
07:00	23,19	1		1				1			1		
08:00	24,50	1		1				1			1		
09:00	27,49	1		1				1		1	1		
10:00	29,04	1		1				1		1	1		
11:00	29,79	1		1				1		1	1		
12:00	29,99	1		1				1		1	1		
13:00	30,63	1		1				1		1	1		
14:00	30,19	1		1				1		1	1		
15:00	29,91	1		1				1		1	1		
16:00	30,88	1		1				1		1	1		
17:00	30,95	1		1				1		1	1		
18:00	31,44	1		1				1		1	1		
19:00	32,99	1		1				1		1	1		1
20:00	32,43	1		1				1		1	1		1
21:00	31,64	1		1				1		1	1		
22:00	29,30	1		1				1		1	1		
23:00	26,78	1		1				1		1	1		

Τρία φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Κυριακή, 5 Απρίλιος 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
Ρ Ε Τ Ε Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
			Κυριακή, 5 Απρίλιος 2026	00:00	22,69	1	1				1		
01:00	21,26	1		1				1			1		
02:00	20,33	1		1				1			1		
03:00	20,14	1		1				1			1		
04:00	19,74	1		1				1			1		
05:00	19,69	1		1				1			1		
06:00	20,90	1		1				1			1		
07:00	23,05	1		1				1			1		
08:00	24,35	1		1				1			1		
09:00	27,33	1		1				1			1	1	
10:00	28,87	1		1				1			1	1	
11:00	29,61	1		1				1			1	1	
12:00	29,82	1		1				1			1	1	
13:00	30,44	1		1				1			1	1	
14:00	30,01	1		1				1			1	1	
15:00	29,73	1		1				1			1	1	
16:00	30,69	1		1				1			1	1	
17:00	30,76	1		1				1			1	1	
18:00	31,26	1		1				1			1	1	
19:00	32,80	1		1				1			1	1	
20:00	32,23	1		1				1			1	1	
21:00	31,45	1		1				1			1	1	
22:00	29,13	1		1				1			1	1	
23:00	26,63	1		1				1			1	1	

Τρία φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα, 6 Απρίλιος 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
Ρ Ε Τ Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
			Δευτέρα, 6 Απρίλιος 2026	00:00	22,96	1	1				1		
01:00	21,51	1		1				1			1		
02:00	20,57	1		1				1			1		
03:00	20,38	1		1				1			1		
04:00	19,98	1		1				1			1		
05:00	19,93	1		1				1			1		
06:00	21,15	1		1				1			1		
07:00	23,33	1		1				1			1		
08:00	24,65	1		1				1			1		
09:00	27,66	1		1				1		1	1		
10:00	29,22	1		1				1		1	1		
11:00	29,96	1		1				1		1	1		
12:00	30,17	1		1				1		1	1		
13:00	30,81	1		1				1		1	1		
14:00	30,37	1		1				1		1	1		
15:00	30,09	1		1				1		1	1		
16:00	31,06	1		1				1		1	1		
17:00	31,13	1		1				1		1	1		
18:00	31,62	1		1				1		1	1		
19:00	32,17	1		1				1		1	1		
20:00	32,62	1		1				1		1	1		1
21:00	31,82	1		1				1		1	1		
22:00	29,47	1		1				1		1	1		
23:00	26,94	1		1				1		1	1		

Τρία φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τρίτη, 7 Απρίλιος 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
α ρ ε π ε ρ α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωρικού Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
			Τρίτη, 7 Απρίλιος 2026	00:00	24,97	1	1				1		
01:00	23,36	1		1				1			1		
02:00	24,62	1		1				1			1		
03:00	24,51	1		1				1			1		
04:00	24,39	1		1				1			1		
05:00	24,39	1		1				1			1		
06:00	26,00	1		1				1		1	1		
07:00	26,72	1		1				1		1	1		
08:00	27,14	1		1				1		1	1		
09:00	29,07	1		1				1		1	1		
10:00	29,11	1		1				1		1	1		
11:00	29,51	1		1				1		1	1		
12:00	28,92	1		1				1		1	1		
13:00	29,09	1		1				1		1	1		
14:00	29,36	1		1				1		1	1		
15:00	29,56	1		1				1		1	1		
16:00	30,52	1		1				1		1	1		
17:00	31,54	1		1				1		1	1		
18:00	33,09	1		1				1		1	1		2
19:00	33,75	1		1				1		1	1		2
20:00	34,97	1		1				1		1	1		
21:00	33,76	1		1				1		1	1		
22:00	31,41	1		1				1		1	1		
23:00	27,91	1		1				1		1	1		

Τρία φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τετάρτη, 8 Απρίλιος 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
α ρ τ ε π ι	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
			Τετάρτη, 8 Απρίλιος 2026	00:00	24,35	1	1				1		
01:00	22,78	1		1				1			1		
02:00	24,00	1		1				1			1		
03:00	23,90	1		1				1			1		
04:00	23,78	1		1				1			1		
05:00	23,78	1		1				1			1		
06:00	25,35	1		1				1		1	1		
07:00	26,05	1		1				1		1	1		
08:00	26,46	1		1				1		1	1		
09:00	28,34	1		1				1		1	1		
10:00	28,38	1		1				1		1	1		
11:00	28,77	1		1				1		1	1		
12:00	28,20	1		1				1		1	1		
13:00	28,36	1		1				1		1	1		
14:00	28,63	1		1				1		1	1		
15:00	28,82	1		1				1		1	1		
16:00	29,76	1		1				1		1	1		
17:00	30,75	1		1				1		1	1		
18:00	32,27	1		1				1		1	1		1
19:00	32,91	1		1				1		1	1		1
20:00	34,10	1		1				1		1	1		3
21:00	32,92	1		1				1		1	1		1
22:00	30,62	1		1				1		1	1		
23:00	27,22	1		1				1		1	1		

Τρία φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Πέμπτη, 9 Απρίλιος 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
α ρ ε τ η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
			Πέμπτη, 9 Απρίλιος 2026	00:00	26,23	1	1			1	1		
01:00	25,69	1		1			1	1			1		
02:00	24,81	1		1			1	1			1		
03:00	24,45	1		1			1	1			1		
04:00	23,81	1		1			1	1			1		
05:00	24,05	1		1			1	1			1		
06:00	25,41	1		1			1	1			1		
07:00	27,62	1		1			1	1			1		
08:00	29,57	1		1			1	1		1	1		
09:00	30,80	1		1			1	1		1	1		
10:00	30,49	1		1			1	1		1	1		
11:00	30,37	1		1			1	1		1	1		
12:00	30,63	1		1			1	1		1	1		
13:00	30,29	1		1			1	1		1	1		
14:00	30,14	1		1			1	1		1	1		
15:00	30,75	1		1			1	1		1	1		
16:00	31,29	1		1			1	1		1	1		
17:00	32,15	1		1			1	1		1	1		
18:00	32,69	1		1			1	1		1	1		
19:00	32,49	1		1			1	1		1	1		
20:00	32,50	1		1			1	1		1	1		
21:00	32,02	1		1			1	1		1	1		
22:00	29,92	1		1			1	1		1	1		
23:00	28,71	1		1			1	1		1	1		

Τρία φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Παρασκευή, 10 Απρίλιος 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
α ρ ε π η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
			Παρασκευή, 10 Απρίλιος 2026	00:00	23,25	1	1				1		
01:00	21,75	1		1				1			1		
02:00	22,92	1		1				1			1		
03:00	22,82	1		1				1			1		
04:00	22,71	1		1				1			1		
05:00	22,71	1		1				1			1		
06:00	24,20	1		1				1			1		
07:00	24,88	1		1			1	1			1		
08:00	25,27	1		1			1	1			1		
09:00	27,07	1		1			1	1			1		
10:00	27,10	1		1			1	1			1		
11:00	27,48	1		1			1	1			1		
12:00	26,93	1		1			1	1			1		
13:00	27,09	1		1			1	1			1		
14:00	27,34	1		1			1	1			1		
15:00	27,52	1		1			1	1			1		
16:00	28,42	1		1				1		1	1		
17:00	30,36	1		1				1		1	1		
18:00	31,81	1		1				1		1	1		
19:00	32,43	1		1				1		1	1		1
20:00	33,56	1		1				1		1	1		2
21:00	32,44	1		1				1		1	1		1
22:00	30,25	1		1				1		1	1		
23:00	26,99	1		1				1		1	1		

Τρία φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Σάββατο, 11 Απρίλιος 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
Ρ Ε Τ Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
			Σάββατο, 11 Απρίλιος 2026	00:00	23,44	1	1				1		
01:00	21,92	1		1				1			1		
02:00	23,10	1		1				1			1		
03:00	23,01	1		1				1			1		
04:00	22,89	1		1				1			1		
05:00	22,89	1		1				1			1		
06:00	24,40	1		1				1			1		
07:00	25,08	1		1				1		1	1		
08:00	25,48	1		1				1		1	1		
09:00	27,28	1		1				1		1	1		
10:00	27,32	1		1				1		1	1		
11:00	27,70	1		1				1		1	1		
12:00	27,15	1		1				1		1	1		
13:00	27,30	1		1				1		1	1		
14:00	27,56	1		1				1		1	1		
15:00	27,74	1		1				1		1	1		
16:00	28,65	1		1				1		1	1		
17:00	31,61	1		1				1		1	1		
18:00	33,07	1		1				1		1	1		1
19:00	33,69	1		1				1		1	1		2
20:00	34,83	1		1				1		1	1		3
21:00	33,70	1		1				1		1	1		2
22:00	31,49	1		1				1		1	1		
23:00	28,21	1		1				1		1	1		

Τρία φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Κυριακή, 12 Απρίλιος 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
Ρ Ε Τ Ε Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
			Κυριακή, 12 Απρίλιος 2026	00:00	22,20	1	1				1		
01:00	20,77	1		1				1			1		
02:00	21,89	1		1				1			1		
03:00	21,80	1		1				1			1		
04:00	21,69	1		1				1			1		
05:00	21,69	1		1				1			1		
06:00	23,12	1		1				1			1		
07:00	23,76	1		1				1			1		
08:00	24,14	1		1				1			1		
09:00	25,85	1		1			1	1			1		
10:00	25,88	1		1			1	1			1		
11:00	26,24	1		1			1	1			1		
12:00	25,72	1		1			1	1			1		
13:00	25,87	1		1			1	1			1		
14:00	26,11	1		1			1	1			1		
15:00	26,28	1		1			1	1			1		
16:00	27,14	1		1			1	1			1		
17:00	30,00	1		1				1		1	1		
18:00	31,38	1		1				1		1	1		
19:00	31,97	1		1				1		1	1		
20:00	32,75	1		1				1		1	1		1
21:00	31,98	1		1				1		1	1		
22:00	29,88	1		1				1		1	1		
23:00	26,78	1		1				1		1	1		

Τρία φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα, 13 Απρίλιος 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
α ρ ε π η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
			Δευτέρα, 13 Απρίλιος 2026	00:00	23,39	1	1				1		
	01:00	21,88	1	1				1			1		
	02:00	23,06	1	1				1			1		
	03:00	22,96	1	1				1			1		
	04:00	22,84	1	1				1			1		
	05:00	22,85	1	1				1			1		
	06:00	24,35	1	1				1			1		
	07:00	25,03	1	1			1	1			1		
	08:00	25,43	1	1			1	1			1		
	09:00	27,23	1	1			1	1			1		
	10:00	27,26	1	1			1	1			1		
	11:00	27,64	1	1			1	1			1		
	12:00	27,09	1	1			1	1			1		
	13:00	27,25	1	1			1	1			1		
	14:00	27,50	1	1			1	1			1		
	15:00	27,69	1	1			1	1			1		
	16:00	28,59	1	1				1		1	1		
	17:00	30,55	1	1				1		1	1		
	18:00	32,01	1	1				1		1	1		
	19:00	32,62	1	1				1		1	1		1
	20:00	33,76	1	1				1		1	1		2
	21:00	32,63	1	1				1		1	1		1
	22:00	30,43	1	1				1		1	1		
	23:00	27,15	1	1				1		1	1		

Τρία φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τρίτη, 14 Απρίλιος 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
Ρ Ε Τ Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
			Τρίτη, 14 Απρίλιος 2026	00:00	23,58	1	1				1		
01:00	22,06	1		1				1			1		
02:00	23,24	1		1				1			1		
03:00	23,14	1		1				1			1		
04:00	23,03	1		1				1			1		
05:00	23,03	1		1				1			1		
06:00	24,54	1		1				1			1		
07:00	25,23	1		1				1		1	1		
08:00	25,63	1		1				1		1	1		
09:00	27,45	1		1				1		1	1		
10:00	27,48	1		1				1		1	1		
11:00	27,86	1		1				1		1	1		
12:00	27,31	1		1				1		1	1		
13:00	27,47	1		1				1		1	1		
14:00	27,72	1		1				1		1	1		
15:00	27,91	1		1				1		1	1		
16:00	28,82	1		1				1		1	1		
17:00	31,30	1		1				1		1	1		
18:00	32,27	1		1				1		1	1		
19:00	32,89	1		1				1		1	1		1
20:00	33,54	1		1				1		1	1		2
21:00	32,90	1		1				1		1	1		1
22:00	30,68	1		1				1		1	1		
23:00	27,38	1		1				1		1	1		

Τρία φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τετάρτη, 15 Απρίλιος 2026								
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000		
Ρ	Ε	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
				Τετάρτη, 15 Απρίλιος 2026	00:00	22,47	1	1					1	
01:00	21,02	1	1						1			1		
02:00	22,15	1	1						1			1		
03:00	22,06	1	1						1			1		
04:00	21,95	1	1						1			1		
05:00	21,95	1	1						1			1		
06:00	23,39	1	1						1			1		
07:00	24,04	1	1						1			1		
08:00	24,43	1	1						1			1		
09:00	26,16	1	1					1	1			1		
10:00	26,19	1	1					1	1			1		
11:00	26,56	1	1					1	1			1		
12:00	26,03	1	1					1	1			1		
13:00	26,18	1	1					1	1			1		
14:00	26,42	1	1					1	1			1		
15:00	26,60	1	1					1	1			1		
16:00	27,47	1	1					1	1			1		
17:00	30,36	1	1						1		1	1		
18:00	31,76	1	1						1		1	1		
19:00	32,35	1	1						1		1	1		1
20:00	33,14	1	1						1		1	1		2
21:00	32,36	1	1						1		1	1		1
22:00	30,24	1	1						1		1	1		
23:00	27,10	1	1						1		1	1		

Τρία φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Πέμπτη, 16 Απρίλιος 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
α ρ ε τ η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Πέμπτη, 16 Απρίλιος 2026	00:00	25,57	1	1			1	1		1			
	01:00	24,22	1	1			1	1		1			
	02:00	22,76	1	1			1	1		1			
	03:00	22,01	1	1			1	1		1			
	04:00	22,09	1	1			1	1		1			
	05:00	22,51	1	1			1	1		1			
	06:00	23,72	1	1			1	1		1			
	07:00	25,95	1	1			1	1		1			
	08:00	27,49	1	1			1	1		1			1
	09:00	29,53	1	1			1	1		1	1		
	10:00	30,50	1	1			1	1		1	1		
	11:00	31,84	1	1			1	1		1	1		
	12:00	31,34	1	1			1	1		1	1		
	13:00	32,07	1	1			1	1		1	1		
	14:00	31,67	1	1			1	1		1	1		
	15:00	31,19	1	1			1	1		1	1		
	16:00	32,55	1	1			1	1		1	1		
	17:00	33,63	1	1			1	1		1	1		
	18:00	34,03	1	1			1	1		1	1		
	19:00	35,05	1	1			1	1		1	1		
	20:00	35,24	1	1			1	1		1	1		1
	21:00	33,73	1	1			1	1		1	1		
	22:00	31,39	1	1			1	1		1	1		
	23:00	27,53	1	1			1	1		1	1		

Τρία φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Παρασκευή, 17 Απρίλιος 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
α ρ ε π η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
			Παρασκευή, 17 Απρίλιος 2026	00:00	25,98	1	1			1	1		1
01:00	24,61	1		1			1	1		1			
02:00	23,12	1		1			1	1		1			
03:00	22,36	1		1			1	1		1			
04:00	22,45	1		1			1	1		1			
05:00	22,87	1		1			1	1		1			
06:00	24,10	1		1			1	1		1			
07:00	26,37	1		1			1	1		1			
08:00	27,93	1		1			1	1		1			2
09:00	30,00	1		1			1	1		1	1		
10:00	30,99	1		1			1	1		1	1		
11:00	32,35	1		1			1	1		1	1		
12:00	31,85	1		1			1	1		1	1		
13:00	32,59	1		1			1	1		1	1		
14:00	32,17	1		1			1	1		1	1		
15:00	31,69	1		1			1	1		1	1		
16:00	33,07	1		1			1	1		1	1		
17:00	34,17	1		1			1	1		1	1		
18:00	34,58	1		1			1	1		1	1		
19:00	35,61	1		1			1	1		1	1		1
20:00	35,80	1		1			1	1		1	1		1
21:00	34,27	1		1			1	1		1	1		
22:00	31,89	1		1			1	1		1	1		
23:00	27,98	1		1			1	1		1	1		

Τρία φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Σάββατο, 18 Απρίλιος 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
α ρ χ η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
			Σάββατο, 18 Απρίλιος 2026	00:00	25,31		1			1	1		1
01:00	23,59			1			1	1		1	1		
02:00	22,88			1			1	1		1	1		
03:00	22,49			1			1	1		1	1		
04:00	22,19			1			1	1		1	1		
05:00	22,32			1			1	1		1	1		
06:00	23,24			1			1	1		1	1		
07:00	26,05			1			1	1		1	1		
08:00	29,35			1			1	1		1	1		1
09:00	31,06			1			1	1		1	1	1	
10:00	32,53			1			1	1		1	1	1	
11:00	33,34			1			1	1		1	1	1	
12:00	32,99			1			1	1		1	1	1	
13:00	33,24			1			1	1		1	1	1	
14:00	32,82			1			1	1		1	1	1	
15:00	33,56			1			1	1		1	1	1	
16:00	33,93			1			1	1		1	1	1	
17:00	34,67			1			1	1		1	1	1	
18:00	35,78			1			1	1		1	1	1	
19:00	36,40			1			1	1		1	1	1	
20:00	36,29			1			1	1		1	1	1	
21:00	34,40			1			1	1		1	1	1	
22:00	32,50			1			1	1		1	1	1	
23:00	28,40			1			1	1		1	1		

Τρία φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Κυριακή, 19 Απρίλιος 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
Ρ Ε Τ Ε Ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
			Κυριακή, 19 Απρίλιος 2026	00:00	24,79		1			1	1		1
01:00	23,11			1			1	1		1	1		
02:00	22,41			1			1	1		1	1		
03:00	22,02			1			1	1		1	1		
04:00	21,73			1			1	1		1	1		
05:00	21,86			1			1	1		1	1		
06:00	22,76			1			1	1		1	1		
07:00	25,51			1			1	1		1	1		
08:00	28,75			1			1	1		1	1		
09:00	30,43			1			1	1		1	1	1	
10:00	31,86			1			1	1		1	1	1	
11:00	32,66			1			1	1		1	1	1	
12:00	32,31			1			1	1		1	1	1	
13:00	32,56			1			1	1		1	1	1	
14:00	32,14			1			1	1		1	1	1	
15:00	32,87			1			1	1		1	1	1	
16:00	33,23			1			1	1		1	1	1	
17:00	33,96			1			1	1		1	1	1	
18:00	35,04			1			1	1		1	1	1	
19:00	35,65			1			1	1		1	1	1	
20:00	35,55			1			1	1		1	1	1	
21:00	33,69			1			1	1		1	1	1	
22:00	31,83			1			1	1		1	1	1	
23:00	27,82			1			1	1		1	1		

Τρία φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα, 20 Απρίλιος 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
α ρ ε π ε ρ	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Δευτέρα, 20 Απρίλιος 2026	00:00	26,37		1			1	1		1	1		
	01:00	24,59		1			1	1		1	1		
	02:00	23,84		1			1	1		1	1		
	03:00	23,43		1			1	1		1	1		
	04:00	23,12		1			1	1		1	1		
	05:00	23,26		1			1	1		1	1		
	06:00	24,21		1			1	1		1	1		
	07:00	27,14		1			1	1		1	1		
	08:00	30,59		1			1	1		1	1	1	
	09:00	32,37		1			1	1		1	1	1	
	10:00	33,89		1			1	1		1	1	1	
	11:00	34,74		1			1	1		1	1	1	
	12:00	34,38		1			1	1		1	1	1	
	13:00	34,63		1			1	1		1	1	1	
	14:00	34,20		1			1	1		1	1	1	
	15:00	34,97		1			1	1		1	1	1	
	16:00	35,36		1			1	1		1	1	1	
	17:00	36,13		1			1	1		1	1	1	
	18:00	37,28		1			1	1		1	1	1	
	19:00	37,93		1			1	1		1	1	1	
20:00	37,82		1			1	1		1	1	1		
21:00	35,84		1			1	1		1	1	1		
22:00	33,87		1			1	1		1	1	1		
23:00	29,60		1			1	1		1	1		1	

Τρία φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τρίτη, 21 Απρίλιος 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
α ρ ε π η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωραιοῦ Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
			Τρίτη, 21 Απρίλιος 2026	00:00	26,75		1			1	1		1
01:00	25,01			1			1	1		1	1		
02:00	24,50			1			1	1		1	1		
03:00	23,58			1			1	1		1	1		
04:00	23,10			1			1	1		1	1		
05:00	23,08			1			1	1		1	1		
06:00	24,60			1			1	1		1	1		
07:00	27,84			1			1	1		1	1		
08:00	30,37			1			1	1		1	1	1	
09:00	32,84			1			1	1		1	1	1	
10:00	34,80			1			1	1		1	1	1	
11:00	35,15			1			1	1		1	1	1	
12:00	36,18			1			1	1		1	1	1	
13:00	37,09			1			1	1		1	1	1	
14:00	36,75			1			1	1		1	1	1	
15:00	36,22			1			1	1		1	1	1	
16:00	36,20			1			1	1		1	1	1	
17:00	35,91			1			1	1		1	1	1	
18:00	37,17			1			1	1		1	1	1	
19:00	38,32			1			1	1		1	1	1	1
20:00	38,88			1			1	1		1	1	1	1
21:00	36,89			1			1	1		1	1	1	
22:00	34,50			1			1	1		1	1	1	
23:00	30,69			1			1	1		1	1	1	

Τρία φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τετάρτη, 22 Απρίλιος 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
α ρ χ η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
			Τετάρτη, 22 Απρίλιος 2026	00:00	27,41					1	1		1
	01:00	25,63					1	1		1	1	1	
	02:00	24,61					1	1		1	1	1	
	03:00	24,19					1	1		1	1	1	
	04:00	24,14					1	1		1	1	1	
	05:00	25,04					1	1		1	1	1	
	06:00	26,16					1	1		1	1	1	
	07:00	28,46					1	1		1	1	1	
	08:00	31,01					1	1		1	1	1	
	09:00	32,05		1			1	1		1	1	1	
	10:00	32,53		1			1	1		1	1	1	
	11:00	32,00		1			1	1		1	1	1	
	12:00	31,80		1			1	1		1	1	1	
	13:00	31,68		1			1	1		1	1	1	
	14:00	31,60		1			1	1		1	1	1	
	15:00	31,38		1			1	1		1	1	1	
	16:00	32,31		1			1	1		1	1	1	
	17:00	32,95		1			1	1		1	1	1	
	18:00	34,70		1			1	1		1	1	1	
	19:00	36,44		1			1	1		1	1	1	
	20:00	37,63		1			1	1		1	1	1	1
	21:00	35,89		1			1	1		1	1	1	
	22:00	33,47		1			1	1		1	1	1	
	23:00	29,76					1	1		1	1	1	

Τρία φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Πέμπτη, 23 Απρίλιος 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
α ρ χ η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωραιοῦ Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
			Πέμπτη, 23 Απρίλιος 2026	00:00	26,72					1	1		1
01:00	24,99						1	1		1	1	1	
02:00	23,99						1	1		1	1	1	
03:00	23,59						1	1		1	1	1	
04:00	23,53						1	1		1	1	1	
05:00	24,42						1	1		1	1	1	
06:00	25,51						1	1		1	1	1	
07:00	27,75						1	1		1	1	1	
08:00	30,24						1	1		1	1	1	
09:00	31,24						1	1		1	1	1	
10:00	31,72						1	1		1	1	1	1
11:00	31,20						1	1		1	1	1	
12:00	31,01						1	1		1	1	1	
13:00	30,89						1	1		1	1	1	
14:00	30,81						1	1		1	1	1	
15:00	30,59						1	1		1	1	1	
16:00	31,50						1	1		1	1	1	
17:00	32,13			1			1	1		1	1	1	
18:00	33,83			1			1	1		1	1	1	
19:00	35,53			1			1	1		1	1	1	
20:00	36,69			1			1	1		1	1	1	
21:00	34,99			1			1	1		1	1	1	
22:00	32,63			1			1	1		1	1	1	
23:00	29,02						1	1		1	1	1	

Τρία φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Παρασκευή, 24 Απρίλιος 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
α ρ ε τ η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωραιοῦ Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
			Παρασκευή, 24 Απρίλιος 2026	00:00	27,13		1			1			1
01:00	25,54			1			1			1	1	1	
02:00	24,99			1			1			1	1	1	
03:00	24,17			1			1			1	1	1	
04:00	23,99			1			1			1	1	1	
05:00	24,07			1			1			1	1	1	
06:00	25,34			1			1			1	1	1	
07:00	28,76			1			1			1	1	1	
08:00	30,56			1			1			1	1	1	
09:00	33,46			1	1		1			1	1	1	
10:00	34,01			1	1		1			1	1	1	
11:00	33,50			1	1		1			1	1	1	
12:00	33,83			1	1		1			1	1	1	
13:00	34,31			1	1		1			1	1	1	
14:00	33,44			1	1		1			1	1	1	
15:00	32,96			1	1		1			1	1	1	
16:00	33,80			1	1		1			1	1	1	
17:00	34,26			1	1		1			1	1	1	
18:00	35,50			1	1		1			1	1	1	
19:00	36,26			1	1		1			1	1	1	1
20:00	37,14			1	1		1			1	1	1	2
21:00	35,29			1	1		1			1	1	1	
22:00	33,64			1	1		1			1	1	1	
23:00	29,87			1			1			1	1	1	

Τρία φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Σάββατο, 25 Απρίλιος 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
α ρ χ η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
			Σάββατο, 25 Απρίλιος 2026	00:00	27,63		1			1			1
01:00	25,03			1			1			1	1	1	
02:00	24,15			1			1			1	1	1	
03:00	23,78			1			1			1	1	1	
04:00	23,55			1			1			1	1	1	
05:00	23,84			1			1			1	1	1	
06:00	25,04			1			1			1	1	1	
07:00	28,20			1			1			1	1	1	
08:00	30,99			1			1			1	1	1	
09:00	33,39			1	1		1			1	1	1	
10:00	35,05			1	1		1			1	1	1	
11:00	35,65			1	1		1			1	1	1	1
12:00	35,70			1	1		1			1	1	1	1
13:00	34,80			1	1		1			1	1	1	
14:00	33,67			1	1		1			1	1	1	
15:00	34,84			1	1		1			1	1	1	
16:00	37,00			1	1		1			1	1	1	2
17:00	38,73			1	1		1			1	1	1	4
18:00	39,51			1	1		1			1	1	1	5
19:00	39,71			1	1		1			1	1	1	5
20:00	39,97			1	1		1			1	1	1	5
21:00	38,45			1	1		1			1	1	1	4
22:00	35,78			1	1		1			1	1	1	
23:00	31,85			1			1			1	1	1	

Τρία φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Κυριακή, 26 Απρίλιος 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
α ρ ε τ ε π	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
			Κυριακή, 26 Απρίλιος 2026	00:00	27,36		1			1			1
01:00	24,79			1			1			1	1	1	
02:00	23,91			1			1			1	1	1	
03:00	23,54			1			1			1	1	1	
04:00	23,31			1			1			1	1	1	
05:00	23,61			1			1			1	1	1	
06:00	24,79			1			1			1	1	1	
07:00	27,93			1			1			1	1	1	
08:00	30,69			1			1			1	1	1	
09:00	33,06			1	1		1			1	1	1	
10:00	34,71			1	1		1			1	1	1	
11:00	35,29			1	1		1			1	1	1	
12:00	35,35			1	1		1			1	1	1	
13:00	34,46			1	1		1			1	1	1	
14:00	33,34			1	1		1			1	1	1	
15:00	34,50			1	1		1			1	1	1	
16:00	36,63			1	1		1			1	1	1	1
17:00	38,35			1	1		1			1	1	1	3
18:00	39,12			1	1		1			1	1	1	4
19:00	39,32			1	1		1			1	1	1	4
20:00	39,58			1	1		1			1	1	1	5
21:00	38,07			1	1		1			1	1	1	4
22:00	35,43			1	1		1			1	1	1	
23:00	31,54			1			1			1	1	1	

Τρία φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Δευτέρα, 27 Απρίλιος 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
α ρ τ ε π	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Δευτέρα, 27 Απρίλιος 2026	00:00	27,55		1			1			1	1	1	
	01:00	24,96		1			1			1	1	1	
	02:00	24,08		1			1			1	1	1	
	03:00	23,71		1			1			1	1	1	
	04:00	23,48		1			1			1	1	1	
	05:00	23,77		1			1			1	1	1	
	06:00	24,97		1			1			1	1	1	
	07:00	28,12		1			1			1	1	1	
	08:00	30,90		1			1			1	1	1	
	09:00	33,29		1	1		1			1	1	1	
	10:00	34,95		1	1		1			1	1	1	
	11:00	35,54		1	1		1			1	1	1	
	12:00	35,59		1	1		1			1	1	1	
	13:00	34,70		1	1		1			1	1	1	
	14:00	33,57		1	1		1			1	1	1	
	15:00	34,74		1	1		1			1	1	1	
	16:00	36,89		1	1		1			1	1	1	1
	17:00	38,62		1	1		1			1	1	1	4
	18:00	39,39		1	1		1			1	1	1	5
	19:00	39,59		1	1		1			1	1	1	5
	20:00	39,86		1	1		1			1	1	1	5
	21:00	38,33		1	1		1			1	1	1	4
	22:00	35,68		1	1		1			1	1	1	
	23:00	31,76		1			1			1	1	1	

Τρία φορητά βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τρίτη, 28 Απρίλιος 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
Η Ε Ρ Ρ α	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
			Τρίτη, 28 Απρίλιος 2026	00:00	30,72	1	1			1			1
01:00	28,46	1		1			1			1	1		
02:00	26,94	1		1			1			1	1		
03:00	26,03	1		1			1			1	1		
04:00	25,93	1		1			1			1	1		
05:00	26,25	1		1			1			1	1		
06:00	27,13	1		1			1			1	1		
07:00	30,70	1		1			1			1	1		
08:00	34,14	1		1			1			1	1	1	
09:00	36,66	1		1			1			1	1	1	
10:00	36,58	1		1			1			1	1	1	
11:00	36,29	1		1			1			1	1	1	
12:00	37,80	1		1			1			1	1	1	
13:00	38,41	1		1			1			1	1	1	
14:00	38,45	1		1			1			1	1	1	
15:00	37,80	1		1			1			1	1	1	
16:00	38,07	1		1			1			1	1	1	
17:00	38,66	1		1			1			1	1	1	
18:00	39,78	1		1			1			1	1	1	
19:00	40,47	1		1			1			1	1	1	
20:00	41,62	1		1			1			1	1	1	2
21:00	41,46	1		1			1			1	1	1	2
22:00	38,71	1		1			1			1	1	1	
23:00	35,34	1		1			1			1	1	1	

Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

	Μη διαθεσιμότητα μονάδας λόγω συντήρησης
	Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τετάρτη, 29 Απριλίου 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
Α Ρ Χ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Τετάρτη, 29 Απριλίου 2026	00:00	30,42	1	1			1			1	1		1
	01:00	29,63	1	1			1			1	1		
	02:00	28,12	1	1			1			1	1		
	03:00	27,14	1	1			1			1	1		
	04:00	26,77	1	1			1			1	1		
	05:00	27,19	1	1			1			1	1		
	06:00	28,92	1	1			1			1	1		
	07:00	31,76	1	1			1			1	1	1	
	08:00	34,56	1	1			1			1	1	1	
	09:00	36,33	1	1			1			1	1	1	
	10:00	37,14	1	1			1			1	1	1	
	11:00	37,37	1	1			1			1	1	1	
	12:00	37,54	1	1			1			1	1	1	
	13:00	37,44	1	1			1			1	1	1	
	14:00	36,80	1	1			1			1	1	1	
	15:00	35,76	1	1			1			1	1	1	
	16:00	35,09	1	1			1			1	1	1	
	17:00	35,30	1	1			1			1	1	1	
18:00	36,91	1	1			1			1	1	1		
19:00	39,25	1	1			1			1	1	1	2	
20:00	41,07	1	1			1			1	1	1	3	
21:00	40,84	1	1			1			1	1	1	3	
22:00	38,42	1	1			1			1	1	1		
23:00	34,92	1	1			1			1	1	1		

Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Πέμπτη, 30 Απριλίου 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
Ρ Ε Σ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Πέμπτη, 30 Απριλίου 2026	00:00	30,02	1	1			1			1	1		1
	01:00	28,13	1	1			1			1	1		
	02:00	26,39	1	1			1			1	1		
	03:00	25,74	1	1			1			1	1		
	04:00	25,98	1	1			1			1	1		
	05:00	26,24	1	1			1			1	1		
	06:00	27,65	1	1			1			1	1		1
	07:00	31,58	1	1			1			1	1		3
	08:00	34,23	1	1			1			1	1	1	
	09:00	35,21	1	1			1			1	1	1	
	10:00	35,94	1	1			1			1	1	1	
	11:00	35,84	1	1			1			1	1	1	
	12:00	35,64	1	1			1			1	1	1	
	13:00	35,44	1	1			1			1	1	1	
	14:00	34,99	1	1			1			1	1	1	
	15:00	34,16	1	1			1			1	1	1	
	16:00	33,27	1	1			1			1	1	1	
	17:00	33,95	1	1			1			1	1	1	
	18:00	35,65	1	1			1			1	1	1	
19:00	36,63	1	1			1			1	1	1		
20:00	38,98	1	1			1			1	1	1	2	
21:00	39,53	1	1			1			1	1	1	3	
22:00	36,94	1	1			1			1	1	1		
23:00	33,81	1	1			1			1	1	1		

Η μονάδα G31 λειτουργεί με μειωμένη απόδοση λόγω βλάβης. Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης