

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα				Τρίτη, 5 Μαΐου 2026							
Αποδιδόμενη Ισχύς (MW)		7,200	7,200	3,500	3,500	3,500	5,800	7,543	9,234	10,150	10,150	1,000	
Η Ε Σ Τ Ε Ρ Α	Χρονική στιγμή	Πρόβλεψη Μέσου Ημερήσιου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G29	G30	G31	G32	H/Z (x16)
Τρίτη, 5 Μαΐου 2026	00:00	31,13	1	1			1			1	1	1	
	01:00	29,54	1	1			1			1	1	1	
	02:00	28,24	1	1			1			1	1		
	03:00	27,77	1	1			1			1	1		
	04:00	28,21	1	1			1			1	1		
	05:00	28,24	1	1			1			1	1		
	06:00	28,51	1	1			1			1	1		
	07:00	29,82	1	1			1			1	1		2
	08:00	33,16	1	1			1			1	1	1	
	09:00	35,14	1	1			1			1	1	1	
	10:00	36,79	1	1			1			1	1	1	
	11:00	39,10	1	1			1			1	1	1	2
	12:00	38,69	1	1			1			1	1	1	2
	13:00	39,72	1	1			1			1	1	1	3
	14:00	39,93	1	1			1			1	1	1	3
	15:00	39,04	1	1			1			1	1	1	2
	16:00	38,91	1	1			1			1	1	1	2
	17:00	38,92	1	1			1			1	1	1	2
	18:00	40,14	1	1			1			1	1	1	4
	19:00	41,58	1	1			1			1	1	1	5
20:00	43,14	1	1			1			1	1	1	7	
21:00	41,36	1	1			1			1	1	1	5	
22:00	38,85	1	1			1			1	1	1	2	
23:00	36,10	1	1			1			1	1	1		

Η μονάδα G31 λειτουργεί με μειωμένη απόδοση λόγω βλάβης. Τρία φορητά Η/Ζ βρίσκονται σε βλάβη.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης